



Preparatory study on lighting systems 'Lot 37'

Annexes

*Specific contract N° ENER/C3/2012-418 Lot 1/06/SI2.668525
Implementing framework contract ENER/C3/2012-418 Lot 1*

Paul Van Tichelen, Wai Chung Lam, Paul Waide, René Kemna, Lieven Vanhooydonck,
Leo Wierda

Contact VITO: Paul Van Tichelen



ANNEX A ADDITIONAL, UNLIMITED LIST OF STANDARDS RELATED TO THE STUDY

Standards about radiation, EMC and similar

EN 14255-1: Measurement and assessment of personal exposures to incoherent optical radiation
Ultraviolet radiation emitted by artificial sources in the workplace

EN 14255-2: Measurement and assessment of personal exposures to incoherent optical radiation
Visible and infrared radiation emitted by artificial sources in the workplace

EN 14255-4: Measurement and assessment of personal exposures to incoherent optical radiation
Terminology and quantities used in UV-, visible and IR-exposure measurements

EN 55015: Limits and methods of measurement of radio disturbance characteristics of electrical
lighting and similar equipment

EN 61000-3-2: Electromagnetic compatibility (EMC) Limits. Limits for harmonic current emissions
(equipment input current ≤ 16 A per phase)

EN 61000-3-3: Electromagnetic compatibility (EMC) - Part 3-3: Limits - Limitation of voltage
changes, voltage fluctuations and flicker in public low-voltage supply systems, for equipment with
rated current ≤ 16 A per phase and not subject to conditional connection

EN 61000-4-1: Electromagnetic compatibility (EMC) - Part 4-1: Testing and measurement
techniques - Overview of EN 61000-4 series

EN 61000-4-15: Electromagnetic compatibility (EMC) - Part 4-15: Testing and measurement
techniques - Flickermeter - Functional and design specifications

EN 61547: Equipment for general lighting purposes - EMC immunity requirements

Standards about lighting

EN 16276: Evacuation Lighting in Road Tunnels

EN 50512: Electrical installations for lighting and beaconing of aerodromes - Advanced Visual
Docking Guidance Systems (A-VDGS)

Standards related to control systems

EN 62386-101: Digital addressable lighting interface. General requirements. System

EN 62386-102: Digital addressable lighting interface. General requirements. Control gear.

EN 62386-103: Digital addressable lighting interface. Part 103. General requirements. Control
devices.

EN 62386-201: Digital addressable lighting interface. Particular requirements for control gear. Fluorescent lamps (device type 0).

EN 62386-202: Digital addressable lighting interface. Particular requirements for control gear. Self-contained emergency lighting (device type 1).

EN 62386-203: Digital addressable lighting interface Particular requirements for control gear. Discharge lamps (excluding fluorescent lamps) (device type 2).

EN 62386-204: Digital addressable lighting interface Particular requirements for control gear. Low voltage halogen lamps (device type 3).

EN 62386-205: Digital addressable lighting interface Particular requirements for control gear. Supply voltage controller for incandescent lamps (device type 4).

EN 62386-206: Digital addressable lighting interface Particular requirements for control gear. Conversion from digital signal into d.c. voltage (device type 5).

EN 62386-207: Digital addressable lighting interface Particular requirements for control gear. LED modules (device type 6).

EN 62386-208: Digital addressable lighting interface. Particular requirements for control gear. Switching function (device type 7).

EN 62386-209: Digital addressable lighting interface. Particular requirements for control gear. Colour control (device type 8).

EN 62386-210: Digital addressable lighting interface Particular requirements for control gear. Sequencer (device type 9).

EN 50428: Switches for household and similar fixed electrical installations - Collateral standard - Switches and related accessories for use in home and building electronic systems (HBES)

EN 60669-1: Switches for household and similar fixed-electrical installations - Part 1: General requirements

EN 60669-2-1: Switches for household and similar fixed electrical installations - Part 2-1: Particular requirements - Electronic switches

EN 60669-2-2: Switches for household and similar fixed electrical installations Particular requirements. Electromagnetic remote-control switches (RCS)

EN 60669-2-3: Switches for household and similar fixed electrical installations. Particular requirements Time-delay switches (TDS)

EN 60669-2-4: Switches for household and similar fixed electrical installations - Part 2-4: Particular requirements - Isolating switches

EN 60669-2-5: Switches for household and similar fixed electrical installations - Part 2-5: Particular requirements - Switches and related accessories for use in home and building electronic systems (HBES)

Standards about luminaires

EN 60598-1: Luminaires - Part 1: General requirements and tests

EN 60598-2-1: Luminaires - Part 2-1: Particular requirements - Fixed general purpose luminaires

EN 60598-2-2: Luminaires - Part 2-2: Particular requirements - Recessed luminaires

EN 60598-2-3: Luminaires - Part 2-3: Particular requirements - Luminaires for road and street lighting

EN 60598-2-4: Luminaires - Part 2-4: Particular requirements - Portable general purpose luminaires

EN 60598-2-5: Luminaires - Part 2-5: Particular requirements – Floodlights.

EN 60598-2-6: Luminaires - Part 2-6: Particular requirements - Luminaires with built-in transformers or convertors for filament lamps

EN 60598-2-7: Luminaires. Particular requirements. Portable luminaires for garden use.

EN 60598-2-8: Luminaires - Part 2-8: Particular requirements – Hand lamps

EN 60598-2-10: Luminaires - Part 2-10: Particular requirements - Portable luminaires for children

EN 60598-2-11: Luminaires - Part 2-11: Particular requirements - Aquarium luminaires

EN 60598-2-13: Luminaires - Part 2-13: Particular requirements - Ground recessed luminaires

EN 60598-2-18: Luminaires - Part 2-18: Particular requirements - Luminaires for swimming pools and similar applications

EN 60598-2-19: Luminaires - Part 2: Particular requirements - Air-handling luminaires (safety requirements)

EN 60598-2-20: Luminaires - Part 2-20: Particular requirements - Lighting chains

EN 60598-2-22: Luminaires - Part 2-22: Particular requirements - Luminaires for emergency lighting

EN 60598-2-23: Luminaires. Particular requirements - Extra low voltage lighting systems for filament lamps

EN 60598-2-24: Luminaires - Part 2-24: Particular requirements - Luminaires with limited surface temperatures

EN 60598-2-25: Luminaires. Part 2-25: Particular requirements. Luminaires for use in clinical areas of hospitals and health care buildings.

IEC 62717: LED MODULES FOR GENERAL LIGHTING Performance requirements

CIE DIS 024/E: 2015: Light Emitting Diodes (LEDs) and LED Assemblies – Terms and Definitions

Standards about lamps

EN 61231: International lamp coding system (ILCOS)

EN 60357: Tungsten halogen lamps (non-vehicle) - Performance specifications

EN 60432-2: Incandescent lamps - Safety specifications - Part 2: Tungsten halogen lamps for domestic and similar general lighting purposes.

EN 60432-3: Incandescent lamps - Safety specifications - Part 3: Tungsten-halogen lamps (non-vehicle)

EN 60630: Maximum lamp outlines for incandescent lamps

EN 60662: High-pressure sodium vapour lamps. Performance specifications

EN 60968: Self-ballasted lamps for general lighting services - Safety requirements

EN 61195: Double-capped fluorescent lamps. Safety specifications

EN 61199: Single-capped fluorescent lamps - Safety specifications

EN 61341: Method of measurement of centre beam intensity and beam angle(s) of reflector lamps

EN 61549: Miscellaneous lamps

EN 62035: Discharge lamps (excluding fluorescent lamps) - Safety specifications

EN 62532: Fluorescent induction lamps - Safety specifications

EN 62639: Fluorescent induction lamps - Performance specification

Standards about lamp control gear

EN 60923: Auxiliaries for lamps - Ballasts for discharge lamps (excluding tubular fluorescent lamps) - Performance requirements

EN 60927: Auxiliaries for lamps - Starting devices (other than glow starters) - Performance requirements

EN 60929: AC and/or DC-supplied electronic control gear for tubular fluorescent lamps. Performance requirements

EN 62442-1: Energy performance of lamp control-gear - Part 1: Control-gear for fluorescent lamps - Method of measurement to determine the total input power of control-gear circuits and the efficiency of the control-gear

EN 60155: Glow-starters for fluorescent lamps

EN 61048: Auxiliaries for lamps - Capacitors for use in tubular fluorescent and other discharge lamp circuits - General and safety requirements

EN 61347-1: Lamp control-gear - Part 1: General and safety requirements

EN 61347-2-1: Lamp control-gear - Part 2-1: Particular requirements for starting devices (other than glow starters)

EN 61347-2-2: Lamp control-gear - Part 2-2: Particular requirements for DC or AC supplied electronic step-down convertors for filament lamps

EN 61347-2-3: Lamp control-gear - Part 2-3: Particular requirements for AC and/or Dc supplied electronic control gear for fluorescent lamps

EN 61347-2-4: Lamp control-gear - Part 2-4: Particular requirements for DC supplied electronic ballasts for general lighting

EN 61347-2-8: Lamp control-gear - Part 2-8: Particular requirements for ballasts for fluorescent lamps

EN 61347-2-9: Lamp control-gear – Part 2-9: Particular requirements for electromagnetic control-gear for discharge lamps (excluding fluorescent lamps)

EN 61347-2-11: Lamp control-gear. - Part 2-11: Particular requirements for miscellaneous electronic circuits used with luminaires.

EN 61347-2-12: Lamp control-gear - Part 2-12: Particular requirements for DC or AC supplied electronic ballasts for discharge lamps (excluding fluorescent lamps)

Standards about lamp caps and holders

EN 60061-1: Lamp caps and holders together with gauges for the control of interchangeability and safety - Part 1: Lamp caps

EN 60061-2: Lamp caps and holders together with gauges for the control of interchangeability and safety - Part 2: Lamp-holders

EN 60061-3: Lamp caps and holders together with gauges for the control of interchangeability and safety - Part 3: Gauges

EN 60061-4: Lamp caps and holders together with gauges for the control of interchangeability and safety - Part 4: Guidelines and general information

EN 60238: Edison screw lamp-holders

EN 60360: Standard method of measurement of lamp cap temperature rise

EN 60838-1: Miscellaneous lamp-holders - Part 1: General requirements and tests

EN 60838-2-1: Miscellaneous lamp-holders - Part 2-1: Particular requirements – Lamp-holders S14

EN 60838-2-2: Miscellaneous lamp-holders - Part 2-2: Particular requirements - Connectors for LED-modules

Standards related to LED

EN 62560: Self-ballasted LED-lamps for general lighting services by voltage > 50 V - Safety specifications

EN 62612: Self-ballasted LED lamps for general lighting services with supply voltages > 50 V - Performance requirements

EN 62031: LED modules for general lighting - Safety specifications

EN 61347-2-13: Lamp control-gear - Part 2-13: Particular requirements for DC or AC supplied electronic control-gear for LED modules

EN 62384: DC or AC supplied electronic control gear for LED modules. Performance requirements

Important standards in development

Project EN 62504: General lighting - Light emitting diode (LED) products and related equipment - Terms and definitions

Project EN 60838-2-3: Miscellaneous lamp-holders - Part 2-3: Particular requirements – Lamp-holders for double-capped linear LED lamps

Project EN 62442-2: Energy performance of lamp control-gear - Part 2: Control-gear for high intensity discharge lamps (excluding fluorescent lamps) - Method of measurement to determine the efficiency of control-gear

Project EN 62442-3: Energy performance of lamp control-gear - Part 3: Control-gear for halogen lamps and LED modules - Method of measurement to determine the efficiency of the control-gear

Project EN 62722-1: Luminaire performance - Part 1: General Requirements

Project EN 62722-2-1: Luminaire performance - Part 2-1: Particular requirements for LED luminaires

ANNEX B MEERP GUIDELINE TASK 2 MARKETS

TASK 2 MARKETS

2.1 Generic economic data

Identify and report

- a. EU Production;
- b. Extra-EU Trade;
- c. Intra-EU Trade;
- d. EU sales and trade= production + import - export.

Data should relate to the latest full year for which at least half of the Member States have reported to Eurostat. Preferably data should be in physical volume (e.g. units) and in money units and split up per Member State.

Information for this subtask should be derived from official EU statistics so as to be coherent with official data used in EU industry and trade policy.

2.2 Market and stock data

In physical units, for EU-27, for each of the categories as defined in 1.1 and for reference years

- a. 1990 (Kyoto and "20-20-20" reference);
- b. 2010 (or most recent real data);
- c. 2013-2016 (forecast, presumable entry into force of measures);
- d. 2020-2030-2050 (forecast, years in which all new ecodesigns of today will be absorbed by the market).

the following parameters are to be identified:

- a. Installed base ("stock") and penetration rate;
- b. Annual sales growth rate (% or physical units);
- c. Average Product Life (in years), in service, and a rough indication of the spread (e.g. standard deviation);
- d. Total sales/ real EU-consumption, (also in €, when available);
- e. Replacement sales (derived);
- f. New sales (derived).

2.3 Market trends

2.3.1. General market trends (growth/ decline, if applicable per segment), trends in product-design and product-features.

2.3.2 Market channels and production structure; identification of the major players (associations, large companies, share SMEs, employment);

2.3.3 Trends in product design/ features, illustrated by recent consumer association tests (valuable, but not necessarily fully representative of the diversity of products put on the market);

2.4 Consumer expenditure base data

For each of the categories defined in subtask 1.1, determine:

- a. Average EU consumer prices, incl. VAT (for consumer prices; streetprice)/ excl. VAT (for B2B products), in Euro.
- b. Consumer prices of consumables (detergent, toner, paper, etc.) (€/kg or €/piece);
- c. Repair and Maintenance costs (€/product life);
- d. Installation costs (for installed appliances only);
- e. Disposal tariffs/ taxes (€/product);

For electricity, fossil fuel, water, interest, inflation and discount rates use values for Jan. 2011 in MEERP Chapter 2, including the average annual price increases mentioned there .

For regional differentiation of consumer prices (for sensitivity analysis) also see Chapter 2

2.5 Recommendations

Make recommendations on

2.5.1 refined product scope from the economical/ commercial perspective (e.g. exclude niche markets)

2.5.2 barriers and opportunities for Ecodesign from the economical/ commercial perspective

ANNEX C SALES OF LIGHT SOURCES

The data in this annex have been taken from the MELISA model (see par. **Error! Reference source not found.** of main text) that was used for the scenario analyses in Task 7 of the Light Sources study ¹. The data provided here are not presented in the Light Sources reports but could be useful as reference for the Lighting Systems study.

Sales and Stock in LFL application group

Table 0-1 Sales data in mln units per year for lamp types of the LFL-application group.
Per base case, for all sectors, residential and non-residential

LFL - EU-28 SALES mln units TOTAL, All Sectors		1990	2010	2015	2020	2025	2030
LFL	T12	80	6	0	0	0	0
	T8 Halophosphor	95	68	0	0	0	0
	T8 tri-phosphor	71	216	204	197	146	78
	T5 new (14 - 80w) including Circular	0	68	67	78	49	36
	T5 old (4 - 13W), Special FL, Others	23	32	21	21	14	6
	LFL (total)	269	390	292	296	209	120
LED	LED retrofit for LFL replacement	0	0	9	36	72	88
	LED luminaire for LFL replacement	0	0	4	30	108	206
	LED for LFL (total)	0	0	13	66	180	294

LFL - EU-28 SALES mln units RESIDENTIAL		1990	2010	2015	2020	2025	2030
LFL	T12	5	0	0	0	0	0
	T8 Halophosphor	6	4	0	0	0	0
	T8 tri-phosphor	5	14	17	13	7	7
	T5 new (14 - 80w) including Circular	0	4	4	0	0	0
	T5 old (4 - 13W), Special FL, Others	1	2	1	2	1	1
	LFL (total)	17	25	22	15	8	8
LED	LED retrofit for LFL replacement	0	0	1	3	2	3
	LED luminaire for LFL replacement	0	0	1	2	4	10
	LED for LFL (total)	0	0	2	4	6	13

LFL - EU-28 SALES mln units NON-RESIDENTIAL		1990	2010	2015	2020	2025	2030
LFL	T12	75	6	0	0	0	0
	T8 Halophosphor	89	63	0	0	0	0
	T8 tri-phosphor	67	203	187	184	140	70
	T5 new (14 - 80w) including Circular	0	64	63	77	48	36
	T5 old (4 - 13W), Special FL, Others	21	30	19	20	13	6
	LFL (total)	252	365	270	281	201	111
LED	LED retrofit for LFL replacement	0	0	8	33	70	86
	LED luminaire for LFL replacement	0	0	3	28	104	196
	LED for LFL (total)	0	0	11	62	174	281

¹ <http://ecodesign-lightsources.eu/documents>

Table 0-2 Stock data in mln units for lamp types of the LFL-application group. Per base case, for all sectors, residential and non-residential

LFL - EU-28 STOCK mln units TOTAL, All Sectors		1990	2010	2015	2020	2025	2030
LFL	T12	318	41	8	1	0	0
	T8 Halophosphor	367	498	64	9	0	0
	T8 tri-phosphor	431	1002	1473	1454	1216	797
	T5 new (14 - 80w) including Circular	0	295	595	696	659	502
	T5 old (4 - 13W), Special FL, Others	119	203	135	120	98	60
	LFL (total)	1235	2040	2274	2281	1973	1359
LED	LED retrofit for LFL replacement	0	0	17	162	416	683
	LED luminaire for LFL replacement	0	0	7	110	466	1157
	LED for LFL (total)	0	0	24	272	882	1840

LFL - EU-28 STOCK mln units RESIDENTIAL		1990	2010	2015	2020	2025	2030
LFL	T12	59	12	5	1	0	0
	T8 Halophosphor	59	109	59	9	0	0
	T8 tri-phosphor	66	135	191	236	239	210
	T5 new (14 - 80w) including Circular	0	19	42	50	52	53
	T5 old (4 - 13W), Special FL, Others	18	35	33	27	23	20
	LFL (total)	202	310	330	325	314	283
LED	LED retrofit for LFL replacement	0	0	4	15	26	38
	LED luminaire for LFL replacement	0	0	2	8	21	55
	LED for LFL (total)	0	0	6	23	47	94

LFL - EU-28 STOCK mln units NON-RESIDENTIAL		1990	2010	2015	2020	2025	2030
LFL	T12	260	29	3	0	0	0
	T8 Halophosphor	308	389	4	0	0	0
	T8 tri-phosphor	365	867	1282	1218	977	587
	T5 new (14 - 80w) including Circular	0	276	553	645	607	449
	T5 old (4 - 13W), Special FL, Others	100	168	102	93	75	40
	LFL (total)	1033	1730	1944	1956	1659	1076
LED	LED retrofit for LFL replacement	0	0	13	147	390	644
	LED luminaire for LFL replacement	0	0	5	101	445	1102
	LED for LFL (total)	0	0	19	248	835	1746




Figure 0-1 Sales data in mln units per year for lamp types of the LFL-application group. Data are for all sectors (residential and non-residential), but around 92% of sales is in the non-residential sector.




Figure 0-2 Stock data in mln units for lamp types of the LFL-application group. Data are for all sectors (residential and non-residential), but around 85% of stock is in the non-residential sector.

Sales and Stock in HID application group

Table 0-3 Sales data in mln units per year for lamp types of the HID-application group.
Per base case, for all sectors = non-residential sector (no residential sales)

HID - EU-28 SALES mln units		1990	2010	2015	2020	2025	2030
TOTAL, All Sectors= Non-Residential							
HID	HPM	8	5	2	0	0	0
	HPS	7	15	13	10	5	2
	MH	2	21	20	15	6	1
	HID (total)	17	41	35	25	11	3
LED	LED retrofit for HID replacement	0	0	1	3	5	6
	LED luminaire for HID replacement	0	0	6	12	20	26
	LED for HID (total)	0	0	7	15	25	32




Figure 0-3 Sales data in mln units for lamp types of the HID-application group. Per base case, for all sectors = non-residential sector (no residential sales)

Table 0-4 Stock data in mln units for lamp types of the HID-application group. Per base case, for all sectors = non-residential sector (no residential stock)

HID - EU-28 STOCK mln units		1990	2010	2015	2020	2025	2030
TOTAL, All Sectors= Non-Residential							
HID	HPM	15	10	4	0	0	0
	HPS	22	47	41	32	19	6
	MH	3	39	42	31	14	2
	HID (total)	40	96	87	64	33	9
LED	LED retrofit for HID replacement	0	0	4	11	20	29
	LED luminaire for HID replacement	0	0	17	47	85	119
	LED for HID (total)	0	0	21	58	105	147




Figure 0-4 Stock data in mln units for lamp types of the HID-application group. Per base case, for all sectors = non-residential sector (no residential stock)

Sales and Stock in CFLni application group

Table 0-5 Sales data in mln units per year for lamp types of the CFLni-application group. Per base case, for all sectors, residential and non-residential

CFLni - EU-28 SALES mln units TOTAL, All Sectors		1990	2010	2015	2020	2025	2030
CFLni	CFLni	23	87	66	47	29	8
	CFLni (total)	23	87	66	47	29	8
LED	LED retrofit for CFLni replacement	0	0	2	7	10	12
	LED luminaire for CFLni replacement	0	0	9	27	39	49
	LED for CFLni (total)	0	0	12	34	49	62

CFLni - EU-28 SALES mln units RESIDENTIAL		1990	2010	2015	2020	2025	2030
CFLni	CFLni	7	26	16	13	11	3
	CFLni (total)	7	26	16	13	11	3
LED	LED retrofit for CFLni replacement	0	0	1	2	3	3
	LED luminaire for CFLni replacement	0	0	2	7	14	12
	LED for CFLni (total)	0	0	3	9	17	15

CFLni - EU-28 SALES mln units NON-RESIDENTIAL		1990	2010	2015	2020	2025	2030
CFLni	CFLni	16	61	49	34	18	5
	CFLni (total)	16	61	49	34	18	5
LED	LED retrofit for CFLni replacement	0	0	2	5	6	9
	LED luminaire for CFLni replacement	0	0	7	20	26	37
	LED for CFLni (total)	0	0	9	25	32	47




Figure 0-5 Sales data in mln units per year for lamp types of the CFLni-application group. Per base case, for all sectors (residential + non-residential)

Table 0-6 Stock data in mln units for lamp types of the CFLni-application group.
Per base case, for all sectors, residential and non-residential

CFLni - EU-28 STOCK mln units TOTAL, All Sectors		1990	2010	2015	2020	2025	2030
CFLni	CFLni	128	575	630	549	389	223
	CFLni (total)	128	575	630	549	389	223
LED	LED retrofit for CFLni replacement	0	0	4	29	74	121
	LED luminaire for CFLni replacement	0	0	15	116	295	484
	LED for CFLni (total)	0	0	19	145	369	605

CFLni - EU-28 STOCK mln units RESIDENTIAL		1990	2010	2015	2020	2025	2030
CFLni	CFLni	50	248	291	277	219	152
	CFLni (total)	50	248	291	277	219	152
LED	LED retrofit for CFLni replacement	0	0	1	7	22	38
	LED luminaire for CFLni replacement	0	0	4	29	86	151
	LED for CFLni (total)	0	0	5	36	108	189

CFLni - EU-28 STOCK mln units NON-RESIDENTIAL		1990	2010	2015	2020	2025	2030
CFLni	CFLni	78	328	339	272	169	71
	CFLni (total)	78	328	339	272	169	71
LED	LED retrofit for CFLni replacement	0	0	3	22	52	83
	LED luminaire for CFLni replacement	0	0	11	87	209	333
	LED for CFLni (total)	0	0	14	108	261	417




Figure 0-6 Stock data in mln units for lamp types of the CFLni-application group.
Per base case, for all sectors (residential + non-residential)

Sales and Stock in DLS application group

Table 0-7 Sales data in mln units per year for lamp types of the DLS-application group.
Per base case, for all sectors, residential and non-residential

DLS - EU-28 SALES mln units TOTAL, All Sectors		1990	2010	2015	2020	2025	2030
DLS	HL LV R	20	150	145	108	54	12
	HL MV X (DLS)	0	162	126	0	0	0
	GLS R (DLS)	173	72	8	0	0	0
	DLS (total)	193	384	279	108	54	12
LED	LED retrofit for DLS replacement	0	5	72	78	45	32
	LED luminaire for DLS replacement	0	1	18	32	26	30
	LED for DLS (total)	0	6	90	111	72	62

DLS - EU-28 SALES mln units RESIDENTIAL		1990	2010	2015	2020	2025	2030
DLS	HL LV R	10	75	73	52	25	6
	HL MV X (DLS)	0	129	101	0	0	0
	GLS R (DLS)	138	58	6	0	0	0
	DLS (total)	149	262	180	52	25	6
LED	LED retrofit for DLS replacement	0	4	51	49	20	13
	LED luminaire for DLS replacement	0	1	13	21	12	13
	LED for DLS (total)	0	5	64	70	32	25

DLS - EU-28 SALES mln units NON-RESIDENTIAL		1990	2010	2015	2020	2025	2030
DLS	HL LV R	10	75	73	55	29	7
	HL MV X (DLS)	0	32	25	0	0	0
	GLS R (DLS)	35	14	2	0	0	0
	DLS (total)	45	122	99	55	29	7
LED	LED retrofit for DLS replacement	0	1	21	29	25	19
	LED luminaire for DLS replacement	0	0	5	12	14	17
	LED for DLS (total)	0	1	26	41	39	36




Figure 0-7 Sales data in mln units per year for lamp types of the DLS-application group.
Per base case, for all sectors (residential + non-residential)

Table 0-8 Stock data in mln units per year for lamp types of the DLS-application group.
Per base case, for all sectors, residential and non-residential

DLS - EU-28 STOCK mln units TOTAL, All Sectors		1990	2010	2015	2020	2025	2030
DLS	HL LV R	63	636	662	542	316	106
	HL MV X (DLS)	0	458	480	28	0	0
	GLS R (DLS)	379	189	41	0	0	0
	DLS (total)	442	1283	1182	570	316	106
LED	LED retrofit for DLS replacement	0	8	192	723	970	1158
	LED luminaire for DLS replacement	0	1	47	231	356	505
	LED for DLS (total)	0	10	239	955	1326	1664

DLS - EU-28 STOCK mln units RESIDENTIAL		1990	2010	2015	2020	2025	2030
DLS	HL LV R	32	318	331	267	151	49
	HL MV X (DLS)	0	366	385	23	0	0
	GLS R (DLS)	303	152	33	0	0	0
	DLS (total)	334	836	749	290	151	49
LED	LED retrofit for DLS replacement	0	7	137	508	628	709
	LED luminaire for DLS replacement	0	1	34	162	224	289
	LED for DLS (total)	0	8	171	670	852	997

DLS - EU-28 STOCK mln units NON-RESIDENTIAL		1990	2010	2015	2020	2025	2030
DLS	HL LV R	32	318	330	275	166	57
	HL MV X (DLS)	0	92	95	6	0	0
	GLS R (DLS)	76	38	8	0	0	0
	DLS (total)	108	447	433	281	166	57
LED	LED retrofit for DLS replacement	0	1	55	216	341	450
	LED luminaire for DLS replacement	0	0	13	69	132	217
	LED for DLS (total)	0	2	69	284	474	666




Figure 0-8 Stock data in mln units for lamp types of the DLS-application group.
Per base case, for all sectors (residential + non-residential)

Sales and Stock in NDLS application group

Table 0-9 Sales data in mln units per year for lamp types of the NDLS-application group. Per base case, for all sectors, residential and non-residential

NDLS - EU-28 SALES mln units TOTAL, All Sectors		1990	2010	2015	2020	2025	2030
NDLS	CFLi	28	480	155	104	30	16
	HL MV E (NDLS)	0	172	336	34	0	0
	GLS X (NDLS)	1514	624	50	0	0	0
	HL LV C (G4,GY6.35)	52	52	38	18	5	0
	HL MV C (G9)	0	70	60	29	6	0
	HL MV L (R7s)	15	45	33	12	1	0
	GLS Storage	0	112	187	0	0	0
	HL Storage	0	90	124	10	0	0
	NDLS (total)	1609	1644	983	206	42	17
LED	LED retrofit for NDLS replacement	0	2	200	647	238	135
	LED luminaire for NDLS replacement	0	0	52	283	149	129
	LED for NDLS (total)	0	3	252	930	387	264

NDLS - EU-28 SALES mln units RESIDENTIAL		1990	2010	2015	2020	2025	2030
NDLS	CFLi	17	288	90	60	17	9
	HL MV E (NDLS)	0	138	267	26	0	0
	GLS X (NDLS)	1212	500	43	0	0	0
	HL LV C (G4,GY6.35)	26	26	18	7	2	0
	HL MV C (G9)	0	56	48	23	4	0
	HL MV L (R7s)	12	36	27	10	1	0
	GLS Storage	0	112	187	0	0	0
	HL Storage	0	90	124	10	0	0
	NDLS (total)	1266	1244	803	135	24	9
LED	LED retrofit for NDLS replacement	0	2	167	451	132	64
	LED luminaire for NDLS replacement	0	0	43	198	84	65
	LED for NDLS (total)	0	3	210	649	215	129

NDLS - EU-28 SALES mln units NON-RESIDENTIAL		1990	2010	2015	2020	2025	2030
NDLS	CFLi	11	192	65	44	13	7
	HL MV E (NDLS)	0	34	69	8	0	0
	GLS X (NDLS)	303	125	8	0	0	0
	HL LV C (G4,GY6.35)	26	26	20	11	3	0
	HL MV C (G9)	0	14	12	6	1	0
	HL MV L (R7s)	3	9	6	2	0	0
	GLS Storage	0	0	0	0	0	0
	HL Storage	0	0	0	0	0	0
	NDLS (total)	343	400	180	71	17	8
LED	LED retrofit for NDLS replacement	0	0	33	196	106	71
	LED luminaire for NDLS replacement	0	0	9	86	66	64
	LED for NDLS (total)	0	0	42	282	172	135

Table 0-10 Stock data in mln units per year for lamp types of the NDLS-application group. Per base case, for all sectors, residential and non-residential

NDLS - EU-28 STOCK mln units TOTAL, All Sectors		1990	2010	2015	2020	2025	2030
NDLS	CFLi	197	3109	3946	3055	1345	656
	HL MV E (NDLS)	0	402	1041	398	1	0
	GLS X (NDLS)	3315	1734	152	1	0	0
	HL LV C (G4,GY6.35)	192	230	186	112	41	7
	HL MV C (G9)	0	214	213	127	32	3
	HL MV L (R7s)	29	103	77	33	4	0
	GLS Storage	0	187	471	6	0	0
	HL Storage	0	90	417	126	0	0
	NDLS (total)	3733	6069	6502	3858	1423	666
LED	LED retrofit for NDLS replacement	0	4	356	2777	4712	5462
	LED luminaire for NDLS replacement	0	0	92	1006	2050	2650
	LED for NDLS (total)	0	4	448	3783	6761	8112

NDLS - EU-28 STOCK mln units RESIDENTIAL		1990	2010	2015	2020	2025	2030
NDLS	CFLi	118	1865	2362	1802	769	375
	HL MV E (NDLS)	0	322	832	309	1	0
	GLS X (NDLS)	2648	1387	124	1	0	0
	HL LV C (G4,GY6.35)	94	115	91	47	16	3
	HL MV C (G9)	0	171	170	100	25	2
	HL MV L (R7s)	23	82	62	27	3	0
	GLS Storage	0	187	471	6	0	0
	HL Storage	0	90	417	126	0	0
	NDLS (total)	2884	4219	4528	2418	814	380
LED	LED retrofit for NDLS replacement	0	4	298	2104	3297	3668
	LED luminaire for NDLS replacement	0	0	77	753	1396	1702
	LED for NDLS (total)	0	4	374	2856	4693	5370

NDLS - EU-28 STOCK mln units NON-RESIDENTIAL		1990	2010	2015	2020	2025	2030
NDLS	CFLi	79	1244	1584	1253	576	281
	HL MV E (NDLS)	0	80	209	89	0	0
	GLS X (NDLS)	666	347	29	0	0	0
	HL LV C (G4,GY6.35)	97	115	95	65	25	4
	HL MV C (G9)	0	43	42	26	7	1
	HL MV L (R7s)	6	21	15	6	1	0
	GLS Storage	0	0	0	0	0	0
	HL Storage	0	0	0	0	0	0
	NDLS (total)	848	1849	1974	1439	608	286
LED	LED retrofit for NDLS replacement	0	0	58	673	1415	1794
	LED luminaire for NDLS replacement	0	0	15	253	653	948
	LED for NDLS (total)	0	0	73	926	2068	2742




Figure 0-9 Sales data in mln units per year for lamp types of the NDLS-application group. Per base case, for all sectors (residential + non-residential)




Figure 0-10 Stock data in mln units for lamp types of the NDLS-application group. Per base case, for all sectors (residential + non-residential)

ANNEX D SALES OF BALLASTS AND CONTROL GEARS

The tables and graphs at the end of this annex present the Eurostat data for magnetic and electronic ballast. These data include production, import, export and apparent consumption (sales), expressed in quantities (units) and in values (euros). The presented data are for the following ProdCom codes:

- 27115013 - Inductors for discharge lamps or tubes (assumed to represent magnetic ballasts)
- 27115015 - Ballasts for discharge lamps or tubes (excluding inductors) (assumed to represent electronic ballasts)

The data can be summarized as follows:

- In 2013 around 600 million **magnetic ballasts** were sold in EU-28, representing a total value of around 165 million euros, for an average value of 0.27 euros/ballast.
As regards sales quantities there is no clear trend: since 2005 the annual sales go up and down, varying from 600 to 900 million units per year.
As regards sales values, the last ten years show a downward trend, even if with ups and downs.
- In 2013 around 70 million **electronic ballasts** were sold in EU-28, representing a total value of around 550 million euros, for an average value of 8.11 euros/ballast.
As regards sales quantities there is a downward trend, from 150 million units in 2006-2007 to 70 million units in 2013.
As regards sales values, the last ten years show an upward trend, from around 300 million euros in 2003 to around 600 million euros in 2011, with stabilization in the last two years.

For several reasons, these Eurostat data are puzzling and retained unreliable, see remarks in the main text, par. **Error! Reference source not found.**

Table 0-11 Eurostat EU-15 data 1995-2002 and EU-28 data 2003-2013, Magnetic ballast (PRC-code 27115013).

Magnetic ballast	EU-15									EU-28									
year	1995	1996	1997	1998	1999	2000	2001	2002	2003	2004	2005	2006	2007	2008	2009	2010	2011	2012	2013
Production Quantity (mln units)	116	132	143	169	157	202	226	334	498	615	639	782	803	787	635	798	900	672	600
Import Quantity (mln units)	18	13	16	19	46	50	25	16	114	106	97	193	118	111	60	56	39	39	32
Export Quantity (mln units)	40	49	57	49	35	43	55	60	48	54	49	47	46	37	29	32	32	33	30
Apparent Sales (mln units)	94	96	102	139	168	209	196	290	564	667	687	928	874	860	667	822	907	678	602
Production Value (mln euro)	272	297	335	332	302	404	443	433	380	370	320	339	389	373	271	328	328	263	238
Import Value (mln euro)	6	20	16	20	18	33	35	42	33	34	34	34	44	46	29	50	48	49	34
Export Value (mln euro)	82	100	107	105	74	106	144	112	110	136	112	103	104	101	73	88	110	112	106
Apparent Sales (mln euro)	196	216	243	248	246	331	335	362	303	268	242	270	329	317	227	291	266	200	165
Production Value (euro/unit)	2.34	2.26	2.35	1.96	1.93	2.01	1.96	1.30	0.76	0.60	0.50	0.43	0.48	0.47	0.43	0.41	0.36	0.39	0.40
Import Value (euro/unit)	0.35	1.50	0.98	1.06	0.38	0.65	1.42	2.60	0.29	0.32	0.35	0.18	0.37	0.41	0.49	0.89	1.22	1.24	1.06
Export Value (euro/unit)	2.03	2.03	1.89	2.13	2.09	2.45	2.63	1.87	2.30	2.52	2.29	2.20	2.25	2.76	2.56	2.77	3.39	3.41	3.59
Apparent Value (euro/unit)	2.08	2.27	2.38	1.78	1.47	1.59	1.70	1.25	0.54	0.40	0.35	0.29	0.38	0.37	0.34	0.35	0.29	0.29	0.27




Figure 0-11: Eurostat EU-15 data 1995-2002 and EU-28 data 2003-2013 for Magnetic ballast. Top: quantities; bottom: monetary value.

Table 0-12 Eurostat EU-15 data 1995-2002 and EU-28 data 2003-2013, Electronic ballast (PRC-code 27115015).

Electronic ballast year	EU-15								EU-28										
	1995	1996	1997	1998	1999	2000	2001	2002	2003	2004	2005	2006	2007	2008	2009	2010	2011	2012	2013
Production Quantity (mln units)	15	87	112	121	138	116	112	134	66	66	84	78	81	73	67	69	59	54	46
Import Quantity (mln units)	38	31	49	46	35	23	26	35	54	66	65	98	98	70	44	62	71	60	54
Export Quantity (mln units)	13	18	28	28	44	33	30	44	22	27	23	27	30	30	24	28	30	31	31
Apparent Sales (mln units)	39	100	133	140	130	106	109	126	98	105	125	149	149	113	87	103	100	82	68
Production Value (mln euro)	208	313	331	395	425	305	307	295	292	374	373	399	432	436	465	535	516	475	461
Import Value (mln euro)	28	40	81	117	119	137	163	189	124	129	141	200	215	240	204	264	330	292	278
Export Value (mln euro)	39	54	69	96	143	162	154	189	162	175	154	208	207	195	159	204	205	195	187
Apparent Sales (mln euro)	196	300	342	416	402	280	315	294	253	328	360	391	439	482	510	595	641	572	553
Production Value (euro/unit)	14.33	3.60	2.96	3.25	3.08	2.64	2.74	2.19	4.41	5.70	4.46	5.14	5.32	5.99	6.97	7.78	8.80	8.84	10.12
Import Value (euro/unit)	0.73	1.31	1.65	2.52	3.40	5.88	6.15	5.34	2.31	1.95	2.18	2.03	2.19	3.44	4.65	4.23	4.62	4.87	5.17
Export Value (euro/unit)	3.05	2.96	2.48	3.46	3.28	4.85	5.15	4.30	7.46	6.61	6.59	7.59	6.89	6.55	6.68	7.17	6.92	6.22	5.97
Apparent Value (euro/unit)	5.01	3.01	2.57	2.97	3.10	2.65	2.90	2.34	2.59	3.11	2.88	2.63	2.94	4.27	5.88	5.79	6.38	6.94	8.11




Figure 0-12: Eurostat EU-15 data 1995-2002 and EU-28 data 2003-2013 for Electronic ballast. Top: quantities; bottom: monetary value.

ANNEX E SALES OF LUMINAIRES

Table 0-13 Eurostat EU-15 data 1995-2002 and EU-28 data 2003-2013, Electric table, desk, bedside or floor-standing lamps (PRC-code 27402200).

Desk luminaires etc.	EU-15									EU-28									
year	1995	1996	1997	1998	1999	2000	2001	2002	2003	2004	2005	2006	2007	2008	2009	2010	2011	2012	2013
Production Quantity (mln units)	24	27	27	25	22	23	25	27	32	25	20	22	22	19	13	14	16	14	16
Import Quantity (mln units)	12	13	15	14	14	18	18	17	30	29	24	26	31	25	17	23	21	23	23
Export Quantity (mln units)	7	7	8	7	5	6	6	6	8	7	7	9	8	7	5	6	6	7	8
Apparent Sales (mln units)	29	34	34	32	31	35	36	38	54	46	38	39	45	37	25	31	31	30	31
Production Value (mln euro)	420	480	464	551	630	620	669	665	509	446	436	462	453	470	416	396	455	376	401
Import Value (mln euro)	205	228	269	304	410	495	469	429	473	513	527	546	638	615	539	677	611	595	577
Export Value (mln euro)	115	120	143	144	138	163	172	160	125	133	143	182	172	180	155	162	170	187	197
Apparent Sales (mln euro)	510	588	590	710	901	951	966	934	857	826	820	826	918	905	800	912	896	783	782
Production Value (euro/unit)	17.5	17.5	17.5	22.0	28.6	27.0	26.8	24.8	16.0	17.8	21.8	21.2	20.4	24.3	31.8	29.0	29.1	26.4	25.1
Import Value (euro/unit)	17.5	17.5	17.5	22.0	28.6	27.0	26.8	24.8	16.0	17.8	21.8	21.2	20.4	24.3	31.8	29.0	29.1	26.4	25.1
Export Value (euro/unit)	17.5	17.5	17.5	22.0	28.6	27.0	26.8	24.8	16.0	17.8	21.8	21.2	20.4	24.3	31.8	29.0	29.1	26.4	25.1
Apparent Value (euro/unit)	17.5	17.5	17.5	22.0	28.6	27.0	26.8	24.8	16.0	17.8	21.8	21.2	20.4	24.3	31.8	29.0	29.1	26.4	25.1




Figure 0-13: Eurostat EU-15 data 1995-2002 and EU-28 data 2003-2013 for Electric table, desk, bedside or floor-standing lamps. Top: quantities; bottom: monetary value.

Table 0-14 Eurostat EU-15 data 1995-2002 and EU-28 data 2003-2013, Chandeliers and other electric ceiling or wall lighting fittings (excluding those used for lighting public open spaces or thoroughfares) (PRC-code 27402500).

Chandeliers etc.	EU-15									EU-28									
year	1995	1996	1997	1998	1999	2000	2001	2002	2003	2004	2005	2006	2007	2008	2009	2010	2011	2012	2013
Production Quantity (mln)	186	300	252	307	285	232	237	328	361	342	344	321	327	288	160	200	160	180	180
Import Quantity (mln units)	13	21	22	27	34	37	39	51	46	56	63	64	71	63	38	59	45	59	57
Export Quantity (mln units)	32	52	53	55	56	51	47	59	47	53	58	59	62	60	34	43	38	51	55
Apparent Sales (mln units)	166	269	221	279	262	218	229	321	359	345	349	326	335	291	165	216	167	188	183
Production Value (mln euro)	297	317	321	404	360	360	400	441	515	466	468	488	536	531	429	466	495	483	504
Import Value (mln euro)	204	227	279	354	423	576	660	689	650	762	859	974	116	116	103	136	137	157	160
Export Value (mln euro)	516	554	674	721	713	787	797	791	669	722	786	901	102	110	910	100	116	135	152
Apparent Sales (mln euro)	265	285	281	367	331	338	386	431	513	470	475	495	550	537	441	503	516	505	511
Production Value (euro/unit)	16.0	10.6	12.7	13.2	12.6	15.5	16.9	13.5	14.3	13.6	13.6	15.2	16.4	18.4	26.8	23.3	30.9	26.8	28.0
Import Value (euro/unit)	16.0	10.6	12.7	13.2	12.6	15.5	16.9	13.5	14.3	13.6	13.6	15.2	16.4	18.4	26.8	23.3	30.9	26.8	28.0
Export Value (euro/unit)	16.0	10.6	12.7	13.2	12.6	15.5	16.9	13.5	14.3	13.6	13.6	15.2	16.4	18.4	26.8	23.3	30.9	26.8	28.0
Apparent Value (euro/unit)	16.0	10.6	12.7	13.2	12.6	15.5	16.9	13.5	14.3	13.6	13.6	15.2	16.4	18.4	26.8	23.3	30.9	26.8	28.0




Figure 0-14: Eurostat EU-15 data 1995-2002 and EU-28 data 2003-2013 for Chandeliers and other electric ceiling or wall lighting fittings (excluding those used for lighting public open spaces or thoroughfares). Top: quantities; bottom: monetary value.

Table 0-15 Eurostat EU-15 data 1995-2002 and EU-28 data 2003-2013, Electric lamps and lighting fittings, of plastic and other materials, of a kind used for filament lamps and tubular fluorescent lamps (PRC-code 27403930).

Luminaires for LFL and filam.	EU-15									EU-28									
year	1995	1996	1997	1998	1999	2000	2001	2002	2003	2004	2005	2006	2007	2008	2009	2010	2011	2012	2013
Production Quantity (mln)	48	80	91	108	98	76	73	68	108	82	72	67	84	131	109	104	88	86	79
Import Quantity (mln units)	5	8	11	15	14	13	16	15	24	21	23	22	27	43	36	48	42	50	55
Export Quantity (mln units)	12	21	26	29	21	17	21	18	21	16	15	15	19	33	29	28	24	27	27
Apparent Sales (mln units)	42	67	76	94	91	72	68	65	111	87	79	74	92	141	117	124	106	109	106
Production Value (mln euro)	130	144	147	160	197	220	180	199	203	217	211	226	272	261	230	250	295	297	283
Import Value (mln euro)	144	140	175	226	274	369	395	427	450	554	661	751	868	862	760	114	140	173	197
Export Value (mln euro)	314	378	420	430	424	493	522	521	391	412	441	519	624	666	600	677	800	932	986
Apparent Sales (mln euro)	113	120	122	139	182	207	167	190	209	231	233	249	296	281	246	296	356	378	382
Production Value (euro/unit)	27.1	18.0	16.2	14.8	20.1	28.9	24.7	29.4	18.8	26.5	29.3	33.9	32.2	20.0	21.1	24.0	33.5	34.7	36.0
Import Value (euro/unit)	27.1	18.0	16.2	14.8	20.1	28.9	24.7	29.4	18.8	26.5	29.3	33.9	32.2	20.0	21.1	24.0	33.5	34.7	36.0
Export Value (euro/unit)	27.1	18.0	16.2	14.8	20.1	28.9	24.7	29.4	18.8	26.5	29.3	33.9	32.2	20.0	21.1	24.0	33.5	34.7	36.0
Apparent Value (euro/unit)	27.1	18.0	16.2	14.8	20.1	28.9	24.7	29.4	18.8	26.5	29.3	33.9	32.2	20.0	21.1	24.0	33.5	34.7	36.0




Figure 0-15: Eurostat EU-15 data 1995-2002 and EU-28 data 2003-2013 for Electric lamps and lighting fittings, of plastic and other materials, of a kind used for filament lamps and tubular fluorescent lamps. Top: quantities; bottom: monetary value.

ANNEX F NON-RESIDENTIAL BUILDINGS AND ROOMS

F1 Introduction

This annex regards lighting in EU-28 non-residential buildings. It handles the following major topics:

- Determination of the areas per building type (sector) and per room type (activity), based on data in the 'Building heat demand report' 2 (chapter E2).
- Determination of the total required lighting (lux) at task level, by multiplication of the building/room areas with the lighting requirements from standards, mainly from EN 12464-1 (chapter E3).
- Determination of the corresponding total installed lighting power, by multiplication of the total required lux with the P_{jlx} (W/m²/lux) values proposed in EN 15193 (chapter E4).
- Determination of the effective operating hours per building type/room type, considering the potential hours and occupancy-related factors proposed in EN 15193, and estimates for the daylight-related factors (chapter E5).
- Determination of the corresponding lighting energy consumption, by multiplication of the installed powers and the operating hours (chapter E6).

The results are compared to the 2013-values from the MELISA model.

F2 Determination of Building Areas

F2.1 Sources

The reference areas for lighting in buildings have been derived starting from the report on EU-28 Building Heat Demand ². In particular the following tables from that report have been mainly used:

- Table 13: provides the % of area that is typical for a given type of building (sector) and the % of area occupied by some types of secondary spaces (activities) such as circulation areas, toilets, meeting rooms, technical service areas, etc. ³.
- Table 15: EU-28 total areas in M m², for primary and secondary sector buildings
- Table 16: EU-28 total areas in M m², for tertiary sector buildings
- Table 17: EU-28 total areas in M m², for public and community sector buildings

F2.2 References for required area subdivisions

² "Average EU building heat load for HVAC equipment", final report, René Kemna (VHK) for the European Commission, August 2014 (chapter 4, volumes and surfaces)

³ It is not specified that the numbers in this table apply to areas in terms of m², and in some cases there are some doubts on this, but the numbers anyway provide a good indication of the subdivision of the building area over the various activities.

The proposed standard EN 15193 ⁴ has been used as a main reference for the building area subdivision that would be necessary. This standard distinguishes the building types (or sectors) shown in Table 0-16 (in this case for the definition of default annual operating hours).

As regards the types of rooms / activity types inside these buildings, the most relevant subdivisions are those used for the definition of occupancy factors (or absence factors) and for the required illumination levels. Table 0-17 shows an example of room types being distinguished in prEN 15193-1 for the definition of absence factors.

Required illumination levels (in terms of lux in the task area or in the immediately surrounding area) are defined in EN 12464 (indoor lighting of workplaces) and EN 12193 (sports facilities). An indication for the level of illumination in residential buildings is provided in prEN 15193.

The room types / activity types in EN 12464 and EN 12193 are very detailed and not reported here. It would be impossible to determine the illuminated areas in terms of m² for all these room types.

Table 0-16 Building types distinguished for the definition of operation hours (from EN 15193-1 table B.3.3.2)

Building type	Default annual operating hours		
	t_D	t_N	t_{tot}
Domestic buildings	1 820	1 680	3 800
Offices	2 250	250	2 500
Education buildings	1 800	200	2 000
Hospitals	3 000	2 000	5 000
Hotels	3 000	2 000	5 000
Restaurants	1 250	1 250	2 500
Sports facilities	2 000	2 000	4 000
Wholesale and retail services	3 000	2 000	5 000
Manufacturing factories	2 500	1 500	4 000

⁴ prEN 15193-1:2014 Energy performance of buildings - Module M9 – Energy requirements for lighting - Part 1: Specifications,
and Draft prCEN/TR 15193-2 "Energy performance of buildings Energy requirements for lighting - Part 2: Technical Report to EN 15193-1" (under approval)

Table 0-17 Room types distinguished for the definition of Absence Factors F_A (from EN 15193-1 table E.2)

Overall building calculation		Room by room calculation		
Building type	F_A	Building type	Room type	F_A
Domestic buildings	0,00	Domestic buildings	Living room	0,30
			Bedroom	0,40
			Room for children or retired persons	0,30
			Dining room	0,70
			Kitchen	0,60
			Bathroom	0,80
			Toilet	0,90
			Entrance hall	0,80
			Corridor, stairs	0,70
			Storeroom	0,90
			Cellar	0,95
			Laundry	0,98
			Larder	0,98
			Workroom	0,60
			Home workshop	0,80
			Garage	0,95
Offices	0,20	Offices	Cellular office 1 person.	0,40
			Cellular office 2-6 persons.	0,30
			Open plan office >6persons sensing/30m ²	0,00
			Open plan office >6persons sensing/10m ²	0,20
			Corridor (dimmed)	0,40
			Entrance hall	0,00
			Showroom/Expo	0,60
			Bathroom	0,90
			Rest room	0,50
			Storage room/Cloakroom	0,90
			Technical plant room	0,98
			Copying/Server room	0,50
			Conference room	0,50
			Archives	0,98
Educational buildings	0,20	Educational buildings	Classroom	0,25
			Room for group activities	0,30
			Corridor (dimmed)	0,60
			Junior common room	0,50
			Lecture hall	0,40
			Staff room	0,40
			Gymnasium/Sports hall	0,30
			Dining hall	0,20
			Teachers' staff common room	0,40
			Copying/storage room	0,40
			Kitchen	0,20
			Library	0,40
Hospitals	0,00	Hospitals	Wards/Bedroom	0,00
			Examination/Treatment	0,40
			Pre-Operation	0,40
			Recovery ward	0,00
			Operating theatre	0,00
			Corridors	0,00
			Culvert/conduct/(dimmed)	0,70
			Waiting area	0,00
			Entrance hall	0,00
			Day room	0,20
			Laboratory	0,20
Manufacturing factory	0,00	Manufacturing factory	Assembly hall	0,00
			Smaller assembly room	0,20
			Storage rack area	0,40
			Open storage area	0,20
			Painting room	0,20

Hotels and restaurants	0,00	Hotels and restaurants	Entrance hall/Lobby	0,00
			Corridor (dimmed)	0,40
			Hotel room	0,60
			Dining hall/cafeteria	0,00
			Kitchen	0,00
			Conference room	0,40
			Kitchen/storage	0,50
Wholesale and retail service	0,00	Wholesale and retail service	Sales area	0,00
			Store room	0,20
			Store room, cold stores	0,60
		Other areas	Waiting areas	0,00
			Stairs (dimmed)	0,20
			Theatrical stage and auditorium	0,00
			Congress hall/Exhibition hall	0,50
			museum/ Exhibition hall	0,00
			Library/Reading area	0,00
			Library /Archive	0,90
			Sports hall	0,30
			Car parks office - Private	0,95
			Car parks - Public	0,80

F2.3 Subdivision of building areas

It would be ideal to subdivide the total building areas from the source document (par. E2.1) according to the building and room types of Table 0-16 and Table 0-17. In that case required illumination levels and absence factors would be readily available. The information from the source document (see par. E2.1) does not always allow such a subdivision, but an attempt has been made to get as close as possible.

Table 0-18 shows the derived detailed subdivision of the total EU-28 Non-Residential Building Area over the various building types and room types.

Table 0-19 provides a summary per building type. The new estimated total EU-28 non-residential building area of 11773 M m² is approximately twice as large as previously estimated in Task 0 based on Waide(2013)⁵ (see also Task 1 report, par. 1.6.3).

Table 0-20 provides a summary per room type. Note that there are still some building types in this table (under Entertainment and Miscellaneous), for which a subdivision in room types would be preferable, but there is no reference information for this.

As regards the Manufacturing sector, some further subdivision of 'production area' would be helpful, and it is a bit strange that the source documents do not provide a 'storage/ warehouse/shipment' area here (counted as part of the Retail/trade sector ?).

⁵ Waide (2013): 'The scope for energy and CO2 savings in the EU through the use of building automation technology', <http://www.leonardo-energy.org/>

Table 0-18 Subdivision of the total EU-28 non-residential building area over building types and room types (VHK, 2015). Areas are given in M m² (10⁶ m²)

Area data derived from report on Building Heat Demand		
	% of area	EU-28 total area M m ²
Total Manufacturing / Industry	100.0 %	2461
Production Area	60%	1476
Reception / Circulation Areas	10%	246
Common toilets, showers, wardrobes	10%	246
Offices	10%	246
Technical Service Rooms	10%	246
Total Retail & Wholesale / Trade	100.0 %	2382
Shops < 30 m ²	27%	643
Shops > 30 m ²	17%	402
Reception / Circulation Areas	19%	450
Common toilets and wardrobes	5%	113
Storeroom / Warehouse	32%	774
Hotel & Restaurant (total)	100.0 %	754
Rooms (excl. toilet/shower)	18%	138
Toilet/Shower in rooms	4%	34
Common toilets/wardrobes	4%	27
Reception/ Circulation areas	7%	49
Breakfast / Eating areas	38%	285
Coffee-shops, Bars, Discotheques	10%	78
Offices	2%	11
Meeting Rooms	4%	33
Kitchen	8%	60
Technical areas	5%	40
Education Total	100.0 %	1302
Crèche, play area	2%	24
(Pre-)Primary resting area	5%	63
Class Rooms	34%	440
Meeting Rooms	12%	160
Library	3%	45
Teacher's Room	2%	25
Computer education area	3%	45
Reception/ Circulation Area	17%	225
Common toilets / wardrobes	5%	69
Standard Offices	10%	134
Technical Service Rooms	5%	71
Hospitals/ Healthcare Total	100.0 %	907
Wards / Bedrooms	21%	191
Dayroom / Eating Room	7%	67
Examination / Treatment Rooms	20%	180
Waiting Area	12%	111
Reception / Circulation Areas	14%	129
Common toilets, wardrobes, showers	9%	80
Standard offices	5%	49
Laboratories	7%	66
Technical Service / Production Areas	4%	34

Area data derived from report on Building Heat Demand		
	% of area	EU-28 total area M m ²
Offices Total	100.0 %	2115
Cellular office	31%	660
Open Plan Office (Landscape office)	29%	609
Reception/ Circulation Area	20%	423
Common toilets / wardrobes / showers	7%	148
Meeting Rooms	8%	169
Copying, Server, Archive, Technical areas	5%	106
Sports Total	100.0 %	544
Sports Hall	44%	242
Common toilets / wardrobes / showers	19%	102
Reception/ Circulation Area	12%	66
Mensa, Restaurant, Bar, Resting area	12%	66
Offices	12%	68
Parking in structures	100 %	290
public access	90%	262
private access (offices)	10%	28
Stations, Airports, similar (Total)	100 %	107
passenger/client (waiting) area	40%	43
reception and circulation areas	30%	32
customs and security	5%	5
common toilets, wardrobes, etc.	10%	11
offices	15%	16
Entertainment and news (Total)		617
Video and Movie production and Cinemas		152
Radio and TV		107
Theatre, Dancing, Amusement park		358
Miscellaneous (Total)		294
Prisons		34
Fire service activities		4
Waste disposal / sewage		37
Political and religious (incl. churches)		152
Libraries, museums, zoo		67
Overall Total Non-Residential		11773

Table 0-19 Summary of areas (M m²) per building type and comparison with data used in the Lot37 exploratory study (VITO, table 1-2 *Error! Bookmark not defined.*)

	EU-27 area M m ²		Share % of total	
	Lot 37	Current	Task 0	Current
sector	VITO	analysis		analysis
Education	1001	1302	17%	11%
Hotels & Restaurants	648	754	11%	6%
Hospitals (&HealthCare)	412	907	7%	8%
Retail (&Wholesale)	883	2382	15%	20%
Offices	1354	2115	23%	18%
Sports	530	544	9%	5%
Industry	530	2461	9%	21%
Other	530	1308	9%	11%
Total Non-Residential	5888	11773	100 %	100 %
Residential	17810	21218		

Table 0-20 Summary of non-residential building areas (M m²) per room type

Subdivision per type of space in Non-Residential buildings	EU-28 area M m ²	Share % of total
Circulation areas	1620	13.8%
Manufacturing area	1476	12.5%
Toilets, showers, wardrobes	829	7.0%
Storeroom / Warehouse	774	6.6%
Offices (cellular)	660	5.6%
Shops < 30 m ²	643	5.5%
Offices (open space)	609	5.2%
Class rooms and similar	573	4.9%
Offices (general, small) ⁶	525	4.5%
Technical / service areas	502	4.3%
Eating / drinking areas	496	4.2%
Shops > 30 m ²	402	3.4%
Meeting rooms	362	3.1%
Theatre, Dancing, Amusement park	358	3.0%
Parking in structures	290	2.5%
Sports Hall	242	2.1%
Hospital wards/bedrooms	191	1.6%
Examination / Treatment Rooms	180	1.5%

⁶ Offices (cellular) and Offices (open space) are in office buildings. Offices (general, small) are in other building types.

Subdivision per type of space in Non-Residential buildings	EU-28 area M m²	Share % of total
Waiting areas	179	1.5%
Political and religious (incl. churches)	152	1.3%
Video and Movie production and Cinemas	152	1.3%
Hotel rooms (excl. toilet/shower)	138	1.2%
Libraries, museums, zoo	112	1.0%
Radio and TV	107	0.9%
Laboratories	66	0.6%
Kitchens	60	0.5%
Waste disposal / sewage	37	0.3%
Prisons	34	0.3%
Fire service activities	4	0.0%
Total non-residential building area	11773	100.0%

F3 Determination of Installed Capacity (lumens)

In this chapter, the building/room areas (m^2) of chapter E2 are multiplied by the lighting requirements ($\text{lux} = \text{lm}/\text{m}^2$, at task level) from EN 12464-1:2007.

The general lighting scale is 20 - 30 - 50 - 75 - 100 - 150 - 200 - 300 - 500 - 750 - 1000 - 1500 - 2000 - 3000 - 5000 Lux.

Standard EN-12464 distinguishes:

- Task area
- Surrounding area: immediately surrounding the task area, at least 0.5 m wide. Illumination in this area can be 1 scale value less than in the task area, e.g. if the task area requires 500 lux, the surrounding area can have 300 lux ⁷.
- Background area: at least 3 m around the surrounding area. The minimum light requirement is 1/3 of that in the surrounding area, e.g. 100 lux in the above example ⁸.

For most building/room types, three lighting requirements have been estimated: E_{task} , E_{surround} , and $E_{\text{background}}$ (all in lux). In addition an estimate has been made for the subdivision of the total building/room area over these three area types: W_{task} , W_{surround} and $W_{\text{background}}$ (all in percent weight). This permits the calculation of the factor F_{ca} ⁹:

$$F_{\text{ca}} = (E_{\text{task}} * W_{\text{task}} + E_{\text{surround}} * W_{\text{surround}} + E_{\text{background}} * W_{\text{background}}) / E_{\text{task}}$$

and the calculation of an average lighting requirement on the entire building/room area:

$$E_{\text{avg}} = F_{\text{ca}} * E_{\text{task}}$$

Multiplying this average lux requirement with the corresponding entire EU-28 area for the room type, an estimate of the total required lighting at task level is obtained for the room type:

$$LM_{\text{tot}} (\text{room type}) = E_{\text{avg}} (\text{room type}) * \text{Area} (\text{room type})$$

in $\text{lux} * \text{m}^2 = \text{lm}$ (but at task level).

The contributions of the various room types can be summed to a total 'installed' lighting capacity for the sector, and next the sector totals can be summed to a total for all non-residential buildings.

The above lighting requirement is the one that has to be maintained, also after a degradation of lamps, luminaires and room surfaces with time. The initially installed

⁷ According to table C.2 of EN 15193, the surrounding area lighting is equal to the task lighting if the latter is 150 lux or smaller. As stated in some references, in case of spaces with continuous work, 200 lux is a minimum.

⁸ prEN 15193 recognizes the existence of the background area but states that it is not feasible to compute possible savings for this area, and consequently does NOT consider it when computing the factor F_{ca} .

⁹ See EN 15193, annex C. For calculations of the simplified method in EN 15193, the task lux (E_{task}) on the entire building/room area is used. The correction factor F_{ca} reflects that a part of the area is lighted to a lower level than E_{task} . In this note F_{ca} has been adapted to include also the background area.

lighting capacity will therefore be higher by a factor (1/MF). For the tables presented in this note, the Maintenance Factor MF = 0.8, which is the default value in EN 15193.

The computational inputs and outputs are shown in Table 0-21 (full list), Table 0-22 (summary per building type/sector) and Table 0-23 (summary per room/activity type).

Conclusions:

- 1- The total EU-28 required lighting capacity for non-residential buildings, taking into account the effects of a maintenance factor MF=0.8, is 3648 Glm (at task level). The MELISA model for 2013 gives an installed lighting capacity of 5660 Glm (at lamp level) ¹⁰. This would imply an average utilization factor of $3648/5660 = 64\%$, a value that could be reasonable.
- 2- Office buildings account for 25% of the required lighting capacity, followed by Manufacturing/Industry (24%), Retail/Wholesale/Trade (15%) and Educational Buildings (12%). All other building types together account for 25%.
- 3- As regards room/activity types, circulation areas have the largest area share (13.8%), but they have a relatively low lighting requirement and consequently represent 'only' 6.4% of the total required lighting capacity.
- 4- Manufacturing areas have the highest share (16.2%) of the total required lighting capacity, but this is also due to the fact that this item is not further subdivided.
- 5- Offices have been split in cellular offices (9.0%), open space offices (9.6%), and general-small offices (7.2%) ¹¹ that together account for 25.8% of the total required lighting capacity.
- 6- Taking small shops (6.2%) and large shops (3.9%) together, they represent 10% of the total required lighting capacity.
- 7- Meeting rooms (5.7%), class rooms (5.3%) and toilets/showers/wardrobes (5.3%) have comparable total required lighting capacities.

Notes:

- In some cases the task/surround/background subdivision is not so adequate, and the values in the three columns have a different meaning, as explained in following comments.
- For Production areas (an important item with high influence) the standard gives a large variety of reference values for a large variety of reference tasks. Values above 500 lux are for specific precision tasks and will have a minor associated area. Values of 500 and 300 lux are most common. Some tasks have requirements lower than 300 lux. In this case the task/surround/background columns with values 500, 300, 100 lux have been used to represent different tasks, and their weight is managed through the assigned area percentages.
- For Examination/Treatment rooms in healthcare, the same problem exists as for production areas, and the same approach has been chosen.

¹⁰ The tables in MELISA give 6760 Glm, but this includes outdoor lighting. As a rough estimate, all HID lamps are used outdoor, corresponding to 1100 Glm. This leaves for indoor $6760-1100 = 5660$ Glm.

¹¹ The first two types are inside office buildings, the latter are offices in other buildings.

- For Sports Halls, the most specific reference is EN 12193. Also here there is a wide range of lighting requirements, depending on competition level (classes I, II, III) and type of sport. In general: 500-750 lux, class I (high competition level), 300-500 lux, class II (low competition level), 200-300 lux, class III (recreational, school). In this case the task/surround/background columns with values 500, 300, 200 lux have been used to represent different situations, and their weight is managed through the assigned area percentages.
- The buildings listed under Entertainment and Miscellaneous are not split in room/activity types and therefore no lighting requirement references were available. For a large part these values are (educated) guesses, but their impact on the overall result is relatively small (around 6% in task lumens).
- In principle, special purpose lamps are excluded. For this reason areas for greenhouses and livestock breeding are not listed. Food display lighting in the retail sector is supposed to be excluded. Stage lighting in theatres and studios is also excluded. Emergency lighting is excluded.
- In principle, only indoor lighting is considered, but there are some border areas where this is vague, for example roof-top parking, zoo, amusement park, railway stations, waste disposal/sewage, ...
- There may be some issues regarding the distinction between local and general lighting, e.g. reception lighting in entrance halls, local reading lights in a library, spot-lighting in shops and museums, blackboard lighting in class rooms, local table lighting in restaurants. It is vague in how far the local lighting contribution has been grasped with the general task requirements used in this note.

Table 0-21 Estimate of the 'installed' lighting capacity at task level for non-residential buildings, full list (indoor lighting only, special purpose lamps excluded, source: VHK 2015)

cyan fields are inputs, can be changed	Area		Lighting Requirements			Relative Area Weights			Required, task level			Installed, task level			% of total lumen
	% of total area	EU-28 Area M m2	Task area lux	Surround area lux	Background area lux	Task area %	Surround area %	Background area %	Fca	Entire area average req. lux	EU-28 lm required at task level Giga lm	MF	Entire area average inst. lux	EU-28 lm installed at task level Giga lm	
Total Manufacturing / Industry	20.9%	2461	403	248	83	38%	45%	16%	69%	279	685	0.8	348	857	23.5%
Production Area	12.5%	1476	500	300	100	30%	50%	20%	64%	320	472	0.8	400	591	16.2%
Reception / Circulation Areas	2.1%	246	125	75	25	80%	20%	0%	92%	115	28	0.8	144	35	1.0%
Common toilets, showers, wardrobes	2.1%	246	200	150	50	70%	30%	0%	93%	185	46	0.8	231	57	1.6%
Offices	2.1%	246	500	300	100	60%	30%	10%	80%	400	98	0.8	500	123	3.4%
Technical Service Rooms	2.1%	246	200	150	50	50%	40%	10%	83%	165	41	0.8	206	51	1.4%
Total Retail & Wholesale / Trade	20.2%	2382	197	133	44	75%	22%	4%	91%	179	425	0.8	223	532	14.6%
Shops < 30 m2	5.5%	643	300	200	67	80%	20%	0%	93%	280	180	0.8	350	225	6.2%
Shops > 30 m2	3.4%	402	300	200	67	80%	20%	0%	93%	280	113	0.8	350	141	3.9%
Reception / Circulation Areas	3.8%	450	125	75	25	80%	20%	0%	92%	115	52	0.8	144	65	1.8%
Common toilets and wardrobes	1.0%	113	200	150	50	70%	30%	0%	93%	185	21	0.8	231	26	0.7%
Storeroom / Warehouse	6.6%	774	100	75	25	50%	30%	20%	78%	78	60	0.8	97	75	2.1%
Hotel & Restaurant (total)	6.4%	754	255	175	58	52%	43%	7%	82%	210	158	0.8	262	198	5.4%
Rooms (excl. toilet/shower)	1.2%	138	300	200	67	20%	60%	20%	64%	193	27	0.8	242	33	0.9%
Toilet/Shower in rooms	0.3%	34	200	150	50	70%	30%	0%	93%	185	6	0.8	231	8	0.2%
Common toilets/wardrobes	0.2%	27	200	150	50	70%	30%	0%	93%	185	5	0.8	231	6	0.2%
Reception/ Circulation areas	0.4%	49	125	75	25	80%	20%	0%	92%	115	6	0.8	144	7	0.2%
Breakfast / Eating areas	2.4%	285	200	150	50	50%	50%	0%	88%	175	50	0.8	219	62	1.7%
Coffeeshops, Bars, Discotheques	0.7%	78	200	150	50	30%	50%	20%	73%	145	11	0.8	181	14	0.4%
Offices	0.1%	11	500	300	100	60%	30%	10%	80%	400	5	0.8	500	6	0.2%
Meeting Rooms	0.3%	33	500	300	100	80%	20%	0%	92%	460	15	0.8	575	19	0.5%
Kitchen	0.5%	60	500	300	100	80%	20%	0%	92%	460	27	0.8	575	34	0.9%
Technical areas	0.3%	40	200	150	50	50%	40%	10%	83%	165	7	0.8	206	8	0.2%
Education Total	11.1%	1302	306	193	64	72%	24%	2%	88%	270	352	0.8	338	440	12.1%
Creche, play area	0.2%	24	300	200	67	80%	20%	0%	93%	280	7	0.8	350	8	0.2%
(Pre-)Primary resting area	0.5%	63	200	150	50	80%	20%	0%	95%	190	12	0.8	238	15	0.4%
Class Rooms	3.7%	440	300	200	67	80%	20%	0%	93%	280	123	0.8	350	154	4.2%

	Area		Lighting Requirements			Relative Area Weights			Required, task level			Installed, task level			
cyan fields are inputs, can be changed	% of total area	EU-28 Area M m2	Task area lux	Surround area lux	Background area lux	Task area %	Surround area %	Background area %	Fca	Entire area average req. lux	EU-28 lm required at task level Giga lm	MF	Entire area average inst. lux	EU-28 lm installed at task level Giga lm	% of total lumen
Meeting Rooms	1.4%	160	500	300	100	80%	20%	0%	92%	460	73	0.8	575	92	2.5%
Library	0.4%	45	500	200	67	30%	60%	10%	55%	277	13	0.8	346	16	0.4%
Teacher's Room	0.2%	25	300	200	67	80%	20%	0%	93%	280	7	0.8	350	9	0.2%
Computer education area	0.4%	45	300	200	67	80%	20%	0%	93%	280	13	0.8	350	16	0.4%
Reception/ Circulation Area	1.9%	225	125	75	25	80%	20%	0%	92%	115	26	0.8	144	32	0.9%
Common toilets / wardrobes	0.6%	69	200	150	50	70%	30%	0%	93%	185	13	0.8	231	16	0.4%
Standard Offices	1.1%	134	500	300	100	60%	30%	10%	80%	400	54	0.8	500	67	1.8%
Technical Service Rooms	0.6%	71	200	150	50	50%	40%	10%	83%	165	12	0.8	206	15	0.4%
Hospitals/Healthcare Total	7.7%	907	308	178	59	59%	32%	6%	79%	242	219	0.8	303	274	7.5%
Wards / Bedrooms	1.6%	191	300	100	33	30%	60%	10%	51%	153	29	0.8	192	37	1.0%
Dayroom / Eating Room	0.6%	67	200	150	50	50%	50%	0%	88%	175	12	0.8	219	15	0.4%
Examination / Treatment Rooms	1.5%	180	500	300	100	60%	30%	10%	80%	400	72	0.8	500	90	2.5%
Waiting Area	0.9%	111	200	150	50	80%	20%	0%	95%	190	21	0.8	238	26	0.7%
Reception / Circulation Areas	1.1%	129	125	75	25	80%	20%	0%	92%	115	15	0.8	144	18	0.5%
Common toilets, wardrobes, showers	0.7%	80	200	150	50	70%	30%	0%	93%	185	15	0.8	231	19	0.5%
Standard offices	0.4%	49	500	300	100	60%	30%	10%	80%	400	20	0.8	500	25	0.7%
Laboratories	0.6%	66	500	300	100	80%	20%	0%	92%	460	31	0.8	575	38	1.0%
Technical Service / Production Areas	0.3%	34	200	150	50	50%	40%	10%	83%	165	6	0.8	206	7	0.2%
Offices Total	18.0%	2115	389	237	79	71%	25%	4%	87%	339	718	0.8	424	897	24.6%
Cellular office	5.6%	660	500	300	100	60%	30%	10%	80%	400	264	0.8	500	330	9.0%
Open Plan Office (Landscape office)	5.2%	609	500	300	100	80%	20%	0%	92%	460	280	0.8	575	350	9.6%
Reception/ Circulation Area	3.6%	423	125	75	25	80%	20%	0%	92%	115	49	0.8	144	61	1.7%
Common toilets / wardrobes / showers	1.3%	148	200	150	50	70%	30%	0%	93%	185	27	0.8	231	34	0.9%
Meeting Rooms	1.4%	169	500	300	100	80%	20%	0%	92%	460	78	0.8	575	97	2.7%
Copying, Server, Archive, Technical areas	0.9%	106	200	150	50	70%	30%	0%	93%	185	20	0.8	231	24	0.7%
Sports Total	4.6%	544	362	226	120	38%	47%	16%	73%	263	143	0.8	329	179	4.9%
Sports Hall	2.1%	242	500	300	200	20%	60%	20%	64%	320	77	0.8	400	97	2.7%
Common toilets / wardrobes / showers	0.9%	102	200	150	50	70%	30%	0%	93%	185	19	0.8	231	24	0.6%
Reception/ Circulation Area	0.6%	66	125	75	25	80%	20%	0%	92%	115	8	0.8	144	9	0.3%
Mensa, Restaurant, Bar, Resting area	0.6%	66	200	150	50	70%	30%	0%	93%	185	12	0.8	231	15	0.4%
Offices	0.6%	68	500	300	100	60%	30%	10%	80%	400	27	0.8	500	34	0.9%

	Area		Lighting Requirements			Relative Area Weights			Required, task level			Installed, task level			
cyan fields are inputs, can be changed	% of total area	EU-28 Area M m2	Task area lux	Surround area lux	Background area lux	Task area %	Surround area %	Background area %	Fca	Entire area average req. lux	EU-28 lm required at task level Giga lm	MF	Entire area average inst. lux	EU-28 lm installed at task level Giga lm	% of total lumen
Parking in structures	2.5%	290	75	50	17	60%	30%	10%	82%	62	18	0.8	77	22	0.6%
public access	2.2%	262	75	50	17	60%	30%	10%	82%	62	16	0.8	77	20	0.6%
private access (offices)	0.2%	28	75	50	17	60%	30%	10%	82%	62	2	0.8	77	2	0.1%
Stations, Airports, similar (Total)	0.9%	107	238	158	53	71%	25%	4%	88%	209	22	0.8	261	28	0.8%
passenger/client (waiting) area	0.4%	42.8	200	150	50	80%	20%	0%	95%	190	8	0.8	238	10	0.3%
reception and circulation areas	0.3%	32.1	125	75	25	80%	20%	0%	92%	115	4	0.8	144	5	0.1%
customs and security	0.0%	5.35	500	300	100	60%	30%	10%	80%	400	2	0.8	500	3	0.1%
common toilets, wardrobes, etc.	0.1%	10.7	200	150	50	70%	30%	0%	93%	185	2	0.8	231	2	0.1%
offices	0.1%	16.05	500	300	100	60%	30%	10%	80%	400	6	0.8	500	8	0.2%
Entertainment and news (Total)	5.2%	617	217	159	53	80%	20%	0%	95%	206	127	0.8	257	159	4.3%
Video and Movie production and Cinemas	1.3%	152	200	150	50	80%	20%	0%	95%	190	29	0.8	238	36	1.0%
Radio and TV	0.9%	107	300	200	67	80%	20%	0%	93%	280	30	0.8	350	37	1.0%
Theater, Dancing, Amusementpark	3.0%	358	200	150	50	80%	20%	0%	95%	190	68	0.8	238	85	2.3%
Miscellaneous (Total)	2.5%	294	184	123	41	80%	20%	0%	93%	172	50	0.8	215	63	1.7%
Prisons	0.3%	34	200	150	50	80%	20%	0%	95%	190	6	0.8	238	8	0.2%
Fire service activities	0.0%	4	200	150	50	80%	20%	0%	95%	190	1	0.8	238	1	0.0%
Waste disposal / sewage	0.3%	37	200	150	50	80%	20%	0%	95%	190	7	0.8	238	9	0.2%
Political and religious (incl. churches)	1.3%	152	125	75	25	80%	20%	0%	92%	115	17	0.8	144	22	0.6%
Libraries, museums, zoo	0.6%	67	300	200	67	80%	20%	0%	93%	280	19	0.8	350	23	0.6%
Total Non-Residential (task level)	100.0%	11773	305	192	66	59%	32%	8%	81%	248	2918	0.8	310	3648	100.0%
MELISA 2013 non-residential (lamp level)														6760	
MELISA 2013 outdoor (all HID)														1100	
MELISA 2013 indoor (lamp level)														5660	
implied utilization factor														64%	

Table 0-22 Estimate of the 'installed' lighting capacity at task level for non-residential buildings, summary per building type/sector (indoor lighting only, special purpose lamps excluded, source: VHK 2015)

									Required, task level			Installed, task level			
Summary per type of building	Area		Lighting Requirements			Relative Area Weights			Fca	Entire area average req. lux	EU-28 lm required at task level Giga lm	MF	Entire area average inst. lux	EU-28 lm installed at task level Giga lm	% of total lumen
	% of total area	EU-28 Area M m2	Task area lux	Surround area lux	Background area lux	Task area %	Surround area %	Background area %							
Office buildings	18.0%	2115	389	237	79	71%	25%	4%	87%	339	718	0.8	424	897	24.6%
Manufacturing / Industry	20.9%	2461	403	248	83	38%	45%	16%	69%	279	685	0.8	348	857	23.5%
Retail & Wholesale / Trade	20.2%	2382	197	133	44	75%	22%	4%	91%	179	425	0.8	223	532	14.6%
Educational buildings	11.1%	1302	306	193	64	72%	24%	2%	88%	270	352	0.8	338	440	12.1%
Hospitals/Healthcare	7.7%	907	308	178	59	59%	32%	6%	79%	242	219	0.8	303	274	7.5%
Hotels & Restaurants	6.4%	754	255	175	58	52%	43%	7%	82%	210	158	0.8	262	198	5.4%
Sports buildings	4.6%	544	362	226	120	38%	47%	16%	73%	263	143	0.8	329	179	4.9%
Entertainment and news	5.2%	617	217	159	53	80%	20%	0%	95%	206	127	0.8	257	159	4.3%
Miscellaneous buildings	2.5%	294	184	123	41	80%	20%	0%	93%	172	50	0.8	215	63	1.7%
Stations, Airports, similar	0.9%	107	238	158	53	71%	25%	4%	88%	209	22	0.8	261	28	0.8%
Parking in structures	2.5%	290	75	50	17	60%	30%	10%	82%	62	18	0.8	77	22	0.6%
Total Non-Residential (task level)	100.0%	11773	305	192	66	59%	32%	8%	81%	248	2918	0.8	310	3648	100.0%
MELISA 2013 (lamp level)														5660	
implied utilization factor														64%	

Table 0-23 Estimate of the 'installed' lighting capacity at task level for non-residential buildings, summary per room/activity type (indoor lighting only, special purpose lamps excluded, source: VHK 2015)

Summary per type of space	Area		Lighting Requirements			Relative Area Weights			Required, task level			Installed, task level			
	% of total area	EU-28 Area M m2	Task area lux	Surround area lux	Background area lux	Task area %	Surround area %	Background area %	Fca	Average required lux	EU-28 required Giga lm	MF	Average installed lux	EU-28 installed Giga lm	% of total lumen
manufacturing area	12.5%	1476	500	300	100	30%	50%	20%	64%	320	472	0.8	400	591	16.2%
offices (open space)	5.2%	609	500	300	100	80%	20%	0%	92%	460	280	0.8	575	350	9.6%
offices (cellular)	5.6%	660	500	300	100	60%	30%	10%	80%	400	264	0.8	500	330	9.0%
offices (general, small)	4.5%	525	500	300	100	60%	30%	10%	80%	400	210	0.8	500	262	7.2%
circulation areas	13.8%	1620	125	75	25	80%	20%	0%	92%	115	186	0.8	144	233	6.4%
Shops < 30 m2	5.5%	643	300	200	67	80%	20%	0%	93%	280	180	0.8	350	225	6.2%
meeting rooms	3.1%	362	500	300	100	80%	20%	0%	92%	460	166	0.8	575	208	5.7%
Class rooms and similar	4.9%	573	289	194	65	80%	20%	0%	93%	270	155	0.8	338	193	5.3%
toilets, showers, wardrobes	7.0%	829	200	150	50	70%	30%	0%	93%	185	153	0.8	231	192	5.3%
Shops > 30 m2	3.4%	402	300	200	67	80%	20%	0%	93%	280	113	0.8	350	141	3.9%
technical / service areas	4.3%	502	203	152	51	54%	38%	8%	85%	172	86	0.8	215	108	3.0%
eating / drinking areas	4.2%	496	200	150	50	50%	47%	3%	86%	172	85	0.8	215	106	2.9%
Sports Hall	2.1%	242	500	300	200	20%	60%	20%	64%	320	77	0.8	400	97	2.7%
Examination / Treatment Rooms	1.5%	180	500	300	100	60%	30%	10%	80%	400	72	0.8	500	90	2.5%
Theatre, Dancing, Amusement park	3.0%	358	200	150	50	80%	20%	0%	95%	190	68	0.8	238	85	2.3%
Storeroom / Warehouse	6.6%	774	100	75	25	50%	30%	20%	78%	78	60	0.8	97	75	2.1%
waiting areas	1.5%	179	214	157	52	80%	20%	0%	95%	203	36	0.8	253	45	1.2%
Libraries, museums, zoo	1.0%	112	381	200	67	53%	36%	4%	73%	279	31	0.8	348	39	1.1%
Laboratories	0.6%	66	500	300	100	80%	20%	0%	92%	460	31	0.8	575	38	1.0%
Radio and TV	0.9%	107	300	200	67	80%	20%	0%	93%	280	30	0.8	350	37	1.0%
Hospital wards/bedrooms	1.6%	191	300	100	33	30%	60%	10%	51%	153	29	0.8	192	37	1.0%
Video and Movie prod. and Cinemas	1.3%	152	200	150	50	80%	20%	0%	95%	190	29	0.8	238	36	1.0%
Kitchens	0.5%	60	500	300	100	80%	20%	0%	92%	460	27	0.8	575	34	0.9%
Hotel rooms (excl. toilet/shower)	1.2%	138	300	200	67	20%	60%	20%	64%	193	27	0.8	242	33	0.9%
Political and religious (incl. churches)	1.3%	152	125	75	25	80%	20%	0%	92%	115	17	0.8	144	22	0.6%
Parking in structures	2.5%	290	75	50	17	60%	30%	10%	82%	62	18	0.8	77	22	0.6%
Waste disposal / sewage	0.3%	37	200	150	50	80%	20%	0%	95%	190	7	0.8	238	9	0.2%
Prisons	0.3%	34	200	150	50	80%	20%	0%	95%	190	6	0.8	238	8	0.2%
Fire service activities	0.0%	4	200	150	50	80%	20%	0%	95%	190	1	0.8	238	1	0.0%
Total Non-Residential (task level)	100%	11773	305	192	66	59%	32%	8%	81%	248	2918	0.8	310	3648	100.0


F4 Determination of Installed Power

F4.1 Source

The installed lighting power is calculated by multiplying the required lighting capacity ($\text{lux} \cdot \text{m}^2 = \text{lm}$) of chapter E3 by the power density values P_{Jlx} ($\text{W}/\text{m}^2/\text{lux} = \text{W}/\text{lm}$) suggested in prEN15193-1 table C.1. These values depend on room surface dimensions, the height distance between luminaire and task plane, and the upward flux fractions (UFF) of the luminaires (direct or indirect lighting). For convenience the table is reported below.

Table 0-24 Power densities P_{Jlx} ($\text{W}/\text{m}^2/\text{lux}$) according to prEN 15193 table C.1. Valid for $\text{MF}=0.8$, 60 luminaire lumens per circuit Watt, reflection coefficients 0.7/0.5/0.2.

room index k	upward flux fraction (UFF)			
	10%	30%	70%	90%
	dir	dir/ind	ind/dir	ind
0.60	0.037	0.043	0.064	0.087
0.80	0.032	0.038	0.053	0.070
1.00	0.030	0.035	0.046	0.060
1.25	0.027	0.033	0.041	0.051
1.50	0.026	0.031	0.037	0.046
2.00	0.024	0.029	0.033	0.039
2.50	0.023	0.028	0.030	0.035
3.00	0.022	0.027	0.029	0.032
4.00	0.021	0.026	0.026	0.029
5.00	0.021	0.025	0.025	0.027



Approximate equations (slightly underestimate P_{Jlx} for $k < 0.8$):

$$\begin{aligned} \text{UFF 10\%: } P_{\text{Jlx}} &= 0.0300 \cdot k^{-0.266}, R^2=0.95 \\ \text{UFF 70\%: } P_{\text{Jlx}} &= 0.0469 \cdot k^{-0.440}, R^2=0.97 \end{aligned}$$

$$\begin{aligned} \text{UFF 30\%: } P_{\text{Jlx}} &= 0.0356 \cdot k^{-0.246}, R^2=0.96 \\ \text{UFF 90\%: } P_{\text{Jlx}} &= 0.0604 \cdot k^{-0.553}, R^2=0.98 \end{aligned}$$

The P_{Jlx} values of the table are valid for:

- room index $k \geq 0.6$; if $k > 5$, use $k=5$.
- maintenance factor $MF=0.8$.
- an efficacy of 60 luminaire lumens per circuit Watt. This is expected to include the power consumption of ballasts/control gears.
- reflection coefficients of ceiling (70%), walls (50%) and floor (20%). This is not explicitly stated, but these values are used as defaults elsewhere in the standard.

The room index k is calculated as $k = (L \cdot W) / (h_m \cdot (L + W))$, where L and W are the room length and width, and h_m is the vertical distance between the luminaires and the task level plane (not always identical to the room height).

For given room dimensions (L, W), the room index value k decreases (higher installed power) when height h_m is increased.

For a given height h_m of the luminaires with respect to the task plane, the room index value k increases (lower installed power) when room dimensions (L, W) are increased.

F4.2 Estimates for power density

The table for the determination of P_{jlx} has two entries: upward flux fraction UFF and room index k .

As an EU-28 average, it has been assumed that upward flux fractions vary from 10% (direct lighting) to 30% (direct/indirect lighting). This means that areas with high UFF (50-90%, less efficient) have been assumed to be compensated by areas with low UFF (10-20%, more efficient), so that the average does not exceed $UFF=30\%$.

Even for a specific room/activity type the variety of room dimensions and luminaire heights is practically infinite, so it is not an easy task to estimate an European average. The estimate has been performed by assuming three different sets of typical room dimensions (L, W, h_m) for each room/activity type, more or less corresponding to small (low k), medium, and large (high k) and then assigning (guessed) area-weights to these three types. Each of the three variants also has a corresponding UFF value, that has usually been chosen high (30%) for small spaces (low k) and low (10%) for large spaces (high k), in order to create a larger variation in P_{jlx} values.

For each of the three room variants the P_{jlx} power density values are derived from the table in prEN 15193 and then weight-averaged.

The assumed room dimensions, room index, upward flux fractions, power densities and average-weighted power density are shown in Table 0-26. The average P_{jlx} values range from 0.021 W/lm for parkings to 0.035 W/lm for technical service rooms, with an overall average of 0.030 W/lm. The latter average has also been used for the buildings in the Entertainment and Miscellaneous sectors, where no subdivision in room types is available.

F4.3 Estimates for installed power

The installed power is estimated, according to prEN 15193 simplified method, as:

$$P = \text{Area (m}^2\text{)} \cdot E_{\text{task (lux)}} \cdot F_{\text{ca (-)}} \cdot P_{jlx} \text{ (W/m}^2\text{/lux)} \cdot F_{\text{mf}} \text{ (Watt)}$$

The values for P_{jlx} are reportedly valid for a maintenance factor $MF=0.8$. It has therefore been assumed that the increase in installed lumen/power due to MF is already

accounted for in the Pjlx values. Consequently the factor (1/MF) is not included in this formula. The data presented here are for MF=0.8, so that the correction factor $F_{mf} = 0.8/MF = 1.0$.

The values for Pjlx are valid for an overall efficacy of 60 luminaire lumens per circuit Watt (assumed to include ballast power), in tables hereafter also referred as 60 LL/W. If light source types are used that lead to a different efficacy, prEN 15193 prescribes the use of a correction factor FL as shown in Table 0-25. Such a correction factor has NOT been applied yet, because it would require deriving a mix of light source types for each room/activity type: this is a time-consuming activity that could be done in a future extension of this study. The factor FL has been taken into account during the comparison with the MELISA values, see 'conclusions'.

The estimated installed lighting power and its density are shown in the last columns of Table 0-26 (full list), Table 0-27 (summary per building type) and Table 0-28 (summary per room/activity type).

Table 0-25 Values for the efficiency factor FL according to EN 15193-2, table C.10

Lamp type	Median value for FL	Range of values for FL
Metal Halide	0.99	0.93 – 1.10
CFL	1.56	1.32 – 1.93
LED	0.86	0.69 – 0.97
LFL T5 (16 mm)	0.90	0.79 – 1.04
LFL T8 (26 mm)	0.95	0.84 – 1.11
Halogen	4.49	3.27 – 5.39
High Pressure Sodium	1.01	0.94 – 1.06
Incandescent	6.36	6.13 – 6.65

Conclusions:

- 1- The total EU-28 installed lighting power in non-residential buildings, considering a maintenance factor MF=0.8, and an efficacy of 60 luminaire lumens per circuit Watt, is estimated at 87 GW¹². Using the MELISA mix of lamp types for the non-residential sector¹³ and the efficacy correction factors of Table 0-25, a correction factor FL=1.28 results, and the estimate for the installed power would become $87 \times 1.28 = 111$ GW. The MELISA model for 2013 gives an installed lighting power of 106 GW¹⁴, which is a very close match.
- 2- The estimated power density is 7.4 W/m² (@ 60 lm/W luminaire efficacy), which should be corrected to $7.4 \times 1.28 = 9.5$ W/m² if the MELISA mix of lamp types is assumed. The MELISA value for 2013 is 9.0 W/m².
- 3- As regards the building/sector types, the percent shares of total installed lighting power are close to the percent shares of total required lighting capacity at task level. The reason for this is that all power density values Pjlx are estimated to be close to the average of 0.030 W/m²/lux (values vary from 0.029

¹² This is understood to be inclusive ballast/control gear power, but exclusive controls and standby.

¹³ excluding HID, assumed for outdoor use

¹⁴ For the entire non-residential sector the MELISA tables give a value of 112 GW, but this is exclusive ballast power. Using the MELISA ballast factors the total inclusive ballast power is 121 GW. This also includes outdoor lighting. As a rough estimate, all HID lamps are used outdoor, corresponding to 16 GW (including ballast). This leaves for indoor 106 GW.

to 0.032, with the exception of parkings that have 0.022). In part this could also be caused by the assumption that all sectors have the same efficacy of 60 luminaire lumens per circuit Watt.

- 4- As regards entire buildings/sectors, the installed power density is highest for office buildings (9.8 W/m^2 @ 60 lm/W luminaire efficacy), followed by Education (8.5 W/m^2), Industry (8.1 W/m^2) and Sports (7.7 W/m^2). By far the lowest density is found for parkings (1.3 W/m^2).
- 5- As regards room/activity types, the spread in Pjlx values is higher, ranging from $0.024 \text{ W/m}^2/\text{lux}$ for open offices to 0.036 for small shops (again, parkings have 0.022). The difference between open offices (0.024) and cellular offices (0.032-0.033) is noteworthy.
- 6- As regards room/activity types, the installed power density is highest for meeting rooms (13.8 W/m^2 @ 60 lm/W luminaire efficacy), small offices (13.4), kitchens (13.0), cellular offices (12.9), laboratories (12.4), examination/treatment rooms (11.6) and open offices (11.1). The smallest values are estimated for parkings (1.3 W/m^2 @ 60 lm/W luminaire efficacy), store rooms/warehouses (2.3), churches (3.5), circulation areas (3.7) and hospital wards/bedrooms (4.4).

Table 0-26 Room indexes, Upward flux fractions and estimated Power densities P_{jlx} ($W/m^2/lux$) according to prEN 15193 table C.1. Last columns show the estimate for the EU-28 installed total lighting power and its density per m^2 . (Valid for MF=0.8, 60 luminaire lumens per circuit Watt, reflection coefficients 0.7/0.5/0.2; source: VHK 2015).

cyan fields are inputs, can be changed	power estimate, reference case 1							power estimate, reference case 2							power estimate, reference case 3							average P_{jlx} $W/m^2/lux=W/lm$	correction factor F _{mf}	EU-28 installed power GW (@ 60 lm/W)	installed power density W/m^2 (@ 60 lm/W)
	width m	length m	height m	room index k	UFF %	P_{jlx} $W/m^2/lux=W/lm$	weight (% of area)	width m	length m	height m	room index k	UFF %	P_{jlx} $W/m^2/lux=W/lm$	weight (% of area)	width m	length m	height m	room index k	UFF %	P_{jlx} $W/m^2/lux=W/lm$	weight (% of area)				
Total Manufacturing / Industry																						0.0292	1.0	20.0	8.1
Production Area	4.0	10.0	2.0	1.4	30%	0.0326	20%	32.0	32.0	8.0	2.0	20%	0.0275	50%	16.0	100.0	5.0	2.8	10%	0.0229	30%	0.0271	1.0	12.8	8.7
Reception / Circulation Areas	1.8	24.8	2.8	0.6	10%	0.0344	30%	3.0	20.0	2.8	0.9	20%	0.0334	40%	10.0	10.0	4.0	1.3	10%	0.0283	30%	0.0322	1.0	0.9	3.7
Common toilets, showers, wardrobes				0.6	30%	0.0404	20%	3.0	4.0	2.0	0.9	30%	0.0370	40%	5.0	10.0	3.0	1.1	10%	0.0292	40%	0.0345	1.0	1.6	6.4
Offices	2.5	3.0	2.0	0.7	30%	0.0391	10%	3.6	4.5	2.0	1.0	30%	0.0356	40%	3.6	4.5	2.0	1.0	10%	0.0300	50%	0.0332	1.0	3.3	13.3
Technical Service Rooms	2.5	3.0	2.0	0.7	30%	0.0391	20%	3.6	4.5	2.0	1.0	30%	0.0356	60%	5.0	10.0	3.0	1.1	10%	0.0292	20%	0.0350	1.0	1.4	5.8
Total Retail & Wholesale / Trade																						0.0319	1.0	13.6	5.7
Shops < 30 m2	4.0	4.0	2.0	1.0	30%	0.0356	30%	3.0	6.0	2.2	0.9	30%	0.0364	60%	4.0	7.0	2.5	1.0	10%	0.0299	10%	0.0355	1.0	6.4	9.9
Shops > 30 m2	6.0	6.0	2.2	1.4	30%	0.0330	20%	6.0	12.0	2.2	1.8	20%	0.0282	40%	10.0	20.0	2.5	2.7	10%	0.0231	40%	0.0271	1.0	3.1	7.6
Reception / Circulation Areas	1.8	24.8	2.8	0.6	10%	0.0344	10%	3.0	20.0	2.8	0.9	20%	0.0334	50%	10.0	10.0	4.0	1.3	10%	0.0283	40%	0.0314	1.0	1.6	3.6
Common toilets and wardrobes				0.6	30%	0.0404	20%	3.0	4.0	2.0	0.9	30%	0.0370	40%	5.0	10.0	3.0	1.1	10%	0.0292	40%	0.0345	1.0	0.7	6.4
Storeroom / Warehouse	4.0	4.0	2.0	1.0	30%	0.0356	20%	4.0	8.0	3.0	0.9	20%	0.0338	30%	10.0	40.0	4.0	2.0	10%	0.0249	50%	0.0297	1.0	1.8	2.3
Hotel & Restaurant (total)																						0.0310	1.0	4.9	6.5
Rooms (excl. toilet/shower)	3.0	4.0	2.2	0.8	30%	0.0379	40%	4.0	5.0	2.2	1.0	20%	0.0327	30%	4.0	8.0	2.5	1.1	10%	0.0295	30%	0.0338	1.0	0.9	6.5
Toilet/Shower in rooms	2.0	3.0	2.0	0.6	30%	0.0404	50%	2.5	4.0	2.0	0.8	20%	0.0351	40%	3.0	5.0	2.2	0.9	10%	0.0313	10%	0.0373	1.0	0.2	6.9
Common toilets/wardrobes				0.6	30%	0.0404	20%	3.0	4.0	2.0	0.9	30%	0.0370	40%	5.0	10.0	3.0	1.1	10%	0.0292	40%	0.0345	1.0	0.2	6.4
Reception/ Circulation areas	1.8	24.8	2.8	0.6	10%	0.0344	50%	3.0	20.0	2.8	0.9	20%	0.0334	30%	10.0	10.0	4.0	1.3	10%	0.0283	20%	0.0329	1.0	0.2	3.8
Breakfast / Eating areas	4.0	6.0	2.0	1.2	30%	0.0340	30%	5.0	8.0	2.0	1.5	20%	0.0294	40%	6.0	10.0	2.2	1.7	10%	0.0260	30%	0.0298	1.0	1.5	5.2
Coffeshops, Bars, Discotheques	4.0	6.0	2.0	1.2	30%	0.0340	30%	5.0	8.0	2.0	1.5	20%	0.0294	40%	6.0	10.0	2.2	1.7	10%	0.0260	30%	0.0298	1.0	0.3	4.3
Offices	2.5	3.0	2.0	0.7	30%	0.0391	10%	3.6	4.5	2.0	1.0	30%	0.0356	40%	3.6	4.5	2.0	1.0	10%	0.0300	50%	0.0332	1.0	0.2	13.3
Meeting Rooms	4.5	3.6	2.0	1.0	30%	0.0356	20%	9.0	7.2	2.0	2.0	20%	0.0275	60%	9.0	7.2	2.0	2.0	10%	0.0249	20%	0.0286	1.0	0.4	13.2
Kitchen	4.0	6.0	2.0	1.2	30%	0.0340	40%	16.0	16.0	2.0	4.0	30%	0.0253	50%	16.0	16.0	2.0	4.0	10%	0.0207	10%	0.0283	1.0	0.8	13.0

cyan fields are inputs, can be changed	power estimate, reference case 1							power estimate, reference case 2							power estimate, reference case 3							average Pjlx W/m2/lux=W/lm	correction factor Fmf	EU-28 installed power GW (@ 60 lm/W)	installed power density W/m2 (@ 60 lm/W)
	width m	length m	height m	room index k	UFF %	Pjlx W/m2/lux=W/lm	weight (% of area)	width m	length m	height m	room index k	UFF %	Pjlx W/m2/lux=W/lm	weight (% of area)	width m	length m	height m	room index k	UFF %	Pjlx W/m2/lux=W/lm	weight (% of area)				
Technical areas	2.5	3.0	2.0	0.7	30%	0.0391	20%	3.6	4.5	2.0	1.0	30%	0.0356	60%	5.0	10.0	3.0	1.1	10%	0.0292	20%	0.0350	1.0	0.2	5.8
Education Total																						0.0313	1.0	11.0	8.5
Creche, play area	4.0	6.0	2.8	0.9	30%	0.0370	30%	5.0	8.0	2.8	1.1	20%	0.0320	40%	6.0	10.0	2.8	1.3	10%	0.0278	30%	0.0322	1.0	0.2	9.0
(Pre-)Primary resting area	4.0	6.0	2.2	1.1	30%	0.0348	30%	5.0	8.0	2.2	1.4	30%	0.0328	40%	6.0	10.0	2.2	1.7	30%	0.0312	30%	0.0329	1.0	0.4	6.3
Class Rooms	4.0	6.0	2.0	1.2	30%	0.0340	20%	5.0	8.0	2.0	1.5	20%	0.0294	60%	6.0	10.0	2.0	1.9	10%	0.0254	20%	0.0295	1.0	3.6	8.3
Meeting Rooms	4.5	3.6	2.0	1.0	30%	0.0356	50%	9.0	7.2	2.0	2.0	20%	0.0275	30%	9.0	7.2	2.0	2.0	10%	0.0249	20%	0.0310	1.0	2.3	14.3
Library	4.0	4.0	2.0	1.0	30%	0.0356	20%	4.0	8.0	3.0	0.9	20%	0.0338	50%	5.0	12.0	3.0	1.2	10%	0.0287	30%	0.0326	1.0	0.4	9.0
Teacher's Room	3.0	4.0	2.0	0.9	30%	0.0370	30%	4.0	6.0	2.0	1.2	20%	0.0313	40%	5.0	8.0	2.0	1.5	10%	0.0268	30%	0.0316	1.0	0.2	8.9
Computer education area	4.0	6.0	2.0	1.2	30%	0.0340	20%	5.0	8.0	2.0	1.5	30%	0.0320	60%	6.0	10.0	2.0	1.9	30%	0.0305	20%	0.0321	1.0	0.4	9.0
Reception/ Circulation Area	1.8	24.8	2.8	0.6	10%	0.0344	10%	3.0	20.0	2.8	0.9	20%	0.0334	70%	10.0	10.0	4.0	1.3	10%	0.0283	20%	0.0325	1.0	0.8	3.7
Common toilets / wardrobes				0.6	30%	0.0404	10%	3.0	4.0	2.0	0.9	30%	0.0370	40%	5.0	10.0	3.0	1.1	10%	0.0292	50%	0.0334	1.0	0.4	6.2
Standard Offices	2.5	3.0	2.0	0.7	30%	0.0391	10%	3.6	4.5	2.0	1.0	30%	0.0356	40%	3.6	4.5	2.0	1.0	10%	0.0300	50%	0.0332	1.0	1.8	13.3
Technical Service Rooms	2.5	3.0	2.0	0.7	30%	0.0391	20%	3.6	4.5	2.0	1.0	30%	0.0356	60%	5.0	10.0	3.0	1.1	10%	0.0292	20%	0.0350	1.0	0.4	5.8
Hospitals/Healthcare Total																						0.0300	1.0	6.6	7.3
Wards / Bedrooms	4.0	6.0	2.0	1.2	30%	0.0340	20%	4.0	12.0	2.0	1.5	20%	0.0296	40%	6.0	12.0	2.2	1.8	10%	0.0256	40%	0.0289	1.0	0.8	4.4
Dayroom / Eating Room	4.0	6.0	2.0	1.2	30%	0.0340	20%	5.0	8.0	2.0	1.5	20%	0.0294	40%	6.0	10.0	2.2	1.7	10%	0.0260	40%	0.0290	1.0	0.3	5.1
Examination / Treatment Rooms	3.0	4.0	2.0	0.9	10%	0.0313	20%	4.0	6.0	2.0	1.2	10%	0.0286	60%	5.0	8.0	2.2	1.4	10%	0.0274	20%	0.0289	1.0	2.1	11.6
Waiting Area	3.0	4.0	2.0	0.9	30%	0.0370	30%	4.0	6.0	2.0	1.2	20%	0.0313	50%	5.0	8.0	2.2	1.4	10%	0.0274	20%	0.0322	1.0	0.7	6.1
Reception / Circulation Areas	1.8	24.8	2.8	0.6	10%	0.0344	10%	3.0	20.0	2.8	0.9	20%	0.0334	70%	10.0	10.0	4.0	1.3	10%	0.0283	20%	0.0325	1.0	0.5	3.7
Common toilets, wardrobes, showers				0.6	30%	0.0404	10%	3.0	4.0	2.0	0.9	30%	0.0370	40%	5.0	10.0	3.0	1.1	10%	0.0292	50%	0.0334	1.0	0.5	6.2
Standard offices	2.5	3.0	2.0	0.7	30%	0.0391	10%	3.6	4.5	2.0	1.0	30%	0.0356	40%	3.6	4.5	2.0	1.0	10%	0.0300	50%	0.0332	1.0	0.7	13.3
Laboratories	4.0	6.0	2.0	1.2	10%	0.0286	20%	5.0	8.0	2.0	1.5	10%	0.0268	50%	6.0	10.0	2.2	1.7	10%	0.0260	30%	0.0269	1.0	0.8	12.4
Technical Service / Production Areas	2.5	3.0	2.0	0.7	30%	0.0391	20%	3.6	4.5	2.0	1.0	30%	0.0356	60%	5.0	10.0	3.0	1.1	10%	0.0292	20%	0.0350	1.0	0.2	5.8
Offices Total																						0.0290	1.0	20.8	9.8
Cellular office	2.5	3.0	2.0	0.7	30%	0.0391	0%	3.6	4.5	2.0	1.0	30%	0.0356	40%	3.6	4.5	2.0	1.0	10%	0.0300	60%	0.0322	1.0	8.5	12.9

cyan fields are inputs, can be changed	power estimate, reference case 1							power estimate, reference case 2							power estimate, reference case 3							average Pjlx W/m2/lux=W/lm	correction factor Fmf	EU-28 installed power GW (@ 60 lm/W)	installed power density W/m2 (@ 60 lm/W)
	width m	length m	height m	room index k	UFF %	Pjlx W/m2/lux=W/lm	weight (% of area)	width m	length m	height m	room index k	UFF %	Pjlx W/m2/lux=W/lm	weight (% of area)	width m	length m	height m	room index k	UFF %	Pjlx W/m2/lux=W/lm	weight (% of area)				
Open Plan Office (Landscape office)	10.0	10.0	2.0	2.5	30%	0.0284	20%	16.0	16.0	2.0	4.0	30%	0.0253	40%	16.0	16.0	2.0	4.0	10%	0.0207	40%	0.0241	1.0	6.8	11.1
Reception/ Circulation Area	1.8	24.8	2.8	0.6	10%	0.0344	50%	3.0	20.0	2.8	0.9	20%	0.0334	30%	10.0	10.0	4.0	1.3	10%	0.0283	20%	0.0329	1.0	1.6	3.8
Common toilets / wardrobes / showers				0.6	30%	0.0404	20%	3.0	4.0	2.0	0.9	30%	0.0370	40%	5.0	10.0	3.0	1.1	10%	0.0292	40%	0.0345	1.0	0.9	6.4
Meeting Rooms	4.5	3.6	2.0	1.0	30%	0.0356	30%	9.0	7.2	2.0	2.0	20%	0.0275	50%	9.0	7.2	2.0	2.0	10%	0.0249	20%	0.0294	1.0	2.3	13.5
Copying, Server, Archive, Technical areas	2.5	3.0	2.0	0.7	30%	0.0391	20%	3.6	4.5	2.0	1.0	30%	0.0356	60%	5.0	10.0	3.0	1.1	10%	0.0292	20%	0.0350	1.0	0.7	6.5
Sports Total																						0.0292	1.0	4.2	7.7
Sports Hall	33.0	18.0	7.6	1.5	10%	0.0268	50%	37.0	33.0	7.6	2.3	10%	0.0241	30%	54.0	33.0	9.1	2.3	10%	0.0242	20%	0.0254	1.0	2.0	8.1
Common toilets / wardrobes / showers				0.6	30%	0.0404	10%	3.0	4.0	2.0	0.9	30%	0.0370	40%	5.0	10.0	3.0	1.1	10%	0.0292	50%	0.0334	1.0	0.6	6.2
Reception/ Circulation Area	1.8	24.8	2.8	0.6	10%	0.0344	40%	3.0	20.0	2.8	0.9	20%	0.0334	40%	10.0	10.0	4.0	1.3	10%	0.0283	20%	0.0328	1.0	0.2	3.8
Mensa, Restaurant, Bar, Resting area	4.0	6.0	2.0	1.2	30%	0.0340	40%	5.0	8.0	2.0	1.5	20%	0.0294	50%	6.0	10.0	2.2	1.7	10%	0.0260	10%	0.0309	1.0	0.4	5.7
Offices	2.5	3.0	2.0	0.7	30%	0.0391	30%	3.6	4.5	2.0	1.0	30%	0.0356	40%	3.6	4.5	2.0	1.0	10%	0.0300	30%	0.0350	1.0	0.9	14.0
Parking in structures																						0.0216	1.0	0.4	1.3
public access	15.0	25.0	2.5	3.8	30%	0.0257	20%	15.0	50.0	2.8	4.1	20%	0.0229	20%	30.0	50.0	2.8	5.0	10%	0.0196	60%	0.0214	1.0	0.3	1.3
private access (offices)	15.0	25.0	2.5	3.8	30%	0.0257	30%	15.0	50.0	2.8	4.1	20%	0.0229	40%	30.0	50.0	2.8	5.0	10%	0.0196	30%	0.0227	1.0	0.0	1.4
Stations, Airports, similar (Total)																						0.0310	1.0	0.7	6.5
passenger/client (waiting) area	4.0	6.0	2.2	1.1	30%	0.0348	20%	6.0	8.0	2.2	1.6	20%	0.0293	30%	10.0	20.0	2.8	2.4	10%	0.0238	50%	0.0277	1.0	0.2	5.3
reception and circulation areas	1.8	24.8	2.8	0.6	10%	0.0344	10%	3.0	20.0	2.8	0.9	20%	0.0334	60%	10.0	10.0	4.0	1.3	10%	0.0283	30%	0.0320	1.0	0.1	3.7
customs and security	2.5	3.0	2.0	0.7	30%	0.0391	20%	3.6	4.5	2.0	1.0	30%	0.0356	30%	5.0	10.0	3.0	1.1	10%	0.0292	50%	0.0331	1.0	0.1	13.2
common toilets, wardrobes, etc				0.6	30%	0.0404	10%	3.0	4.0	2.0	0.9	30%	0.0370	40%	5.0	10.0	3.0	1.1	10%	0.0292	50%	0.0334	1.0	0.1	6.2
offices	2.5	3.0	2.0	0.7	30%	0.0391	10%	3.6	4.5	2.0	1.0	30%	0.0356	40%	3.6	4.5	2.0	1.0	10%	0.0300	50%	0.0332	1.0	0.2	13.3
Entertainment and news (Total)																						0.0300	1.0	3.8	6.2
Video and Movie production and Cinemas																						0.03	1.0	0.9	5.7
Radio and TV																						0.03	1.0	0.9	8.4

cyan fields are inputs, can be changed	power estimate, reference case 1							power estimate, reference case 2							power estimate, reference case 3										
	width m	length m	height m	room index k	UFF %	Pjlx W/m2/lux=W/lm	weight (% of area)	width m	length m	height m	room index k	UFF %	Pjlx W/m2/lux=W/lm	weight (% of area)	width m	length m	height m	room index k	UFF %	Pjlx W/m2/lux=W/lm	weight (% of area)	average Pjlx W/m2/lux=W/lm	correction factor Fmf	EU-28 installed power GW (@ 60 lm/W)	installed power density W/m2 (@ 60 lm/W)
Theater, Dancing, Amusementpark																						0.03	1.0	2.0	5.7
Miscellaneous (Total)																						0.0300	1.0	1.5	5.2
Prisons																						0.03	1.0	0.2	5.7
Fire service activities																						0.03	1.0	0.0	5.7
Waste disposal / sewage																						0.03	1.0	0.2	5.7
Political and religious (incl. churches)																						0.03	1.0	0.5	3.5
Libraries, musea, zoo																						0.03	1.0	0.6	8.4
Total Non-Residential																						0.0300	1.0	87	7.4
MELISA 2013 indoor (different lm/W)																								106	9.0
implied factor FL from EN 15193																								1.21	

Table 0-27 Estimate of installed lighting power for non-residential buildings based on building areas, lighting requirements at task level, and Power densities Pjlx (W/m²/lux) according to prEN 15193 table C.1. Last columns show the estimate for the EU-28 installed total lighting power and its density per m². (Valid for MF=0.8, 60 luminaire lumens per circuit Watt, reflection coefficients 0.7/0.5/0.2; source: VHK 2015).

Summary per type of building	% of total area	EU-28 Area M m2	Lighting Requirements Task area lux	Fca	EU-28 lm required at task level Giga lm	% of total lumen	average Pjlx W/m2/lux =W/lm	correction factor Fmf	EU-28 installed power GW @60 LL/W	installed power density W/m2 @60 LL/W	% of total power @60 LL/W
Offices Total	18.0%	2115	389	87%	718	24.6%	0.029	1.0	20.8	9.8	23.8%
Total Manufacturing / Industry	20.9%	2461	403	69%	685	23.5%	0.029	1.0	20.0	8.1	22.9%
Total Retail & Wholesale / Trade	20.2%	2382	197	91%	425	14.6%	0.032	1.0	13.6	5.7	15.5%
Education Total	11.1%	1302	306	88%	352	12.1%	0.031	1.0	11.0	8.5	12.6%
Hospitals/Healthcare Total	7.7%	907	308	79%	219	7.5%	0.030	1.0	6.6	7.3	7.5%
Hotel & Restaurant (total)	6.4%	754	255	82%	158	5.4%	0.031	1.0	4.9	6.5	5.6%
Sports Total	4.6%	544	362	73%	143	4.9%	0.029	1.0	4.2	7.7	4.8%
Entertainment and news (Total)	5.2%	617	217	95%	127	4.3%	0.030	1.0	3.8	6.2	4.4%
Miscellaneous (Total)	2.5%	294	184	93%	50	1.7%	0.030	1.0	1.5	5.2	1.7%
Stations, Airports, similar (Total)	0.9%	107	238	88%	22	0.8%	0.031	1.0	0.7	6.5	0.8%
Parking in structures	2.5%	290	75	82%	18	0.6%	0.022	1.0	0.4	1.3	0.4%
Total Non-Residential (indoor)	100%	11773	305	81%	2918	100 %	0.030	1.0	87	7.4	100%
MELISA 2013 (different LLm/W)									106	9.0	

Table 0-28 Estimate of installed lighting power for non-residential rooms/zones based on building areas, lighting requirements at task level, and Power densities P_{lx} (W/m²/lux) according to prEN 15193 table C.1. (for MF=0.8, 60 Lm/W; source: VHK 2015).

Summary per type of room/activity	% of total area	EU-28 Area M m2	Lighting Requirements Task area lux	Fca	EU-28 required task level Giga lm	% of total lumen	average P _{lx} W/m2/lux =W/lm	correction factor Fmf	EU-28 power GW @60 LL/W	power density W/m2 @60 LL/W	% of total power @60 LL/W
manufacturing area	12.5%	1476	500	64%	472	16.2%	0.027	1.0	12.8	8.7	14.7%
offices (open space)	5.2%	609	500	92%	280	9.6%	0.024	1.0	6.8	11.1	7.7%
offices (cellular)	5.6%	660	500	80%	264	9.0%	0.032	1.0	8.5	12.9	9.7%
offices (general, small)	4.5%	525	500	80%	210	7.2%	0.033	1.0	7.0	13.4	8.0%
circulation areas	13.8%	1620	125	92%	186	6.4%	0.032	1.0	6.0	3.7	6.9%
Shops < 30 m2	5.5%	643	300	93%	180	6.2%	0.036	1.0	6.4	9.9	7.3%
meeting rooms	3.1%	362	500	92%	166	5.7%	0.030	1.0	5.0	13.8	5.7%
Class rooms and similar	4.9%	573	289	93%	155	5.3%	0.030	1.0	4.7	8.1	5.3%
toilets, showers, wardrobes	7.0%	829	200	93%	153	5.3%	0.034	1.0	5.3	6.3	6.0%
Shops > 30 m2	3.4%	402	300	93%	113	3.9%	0.027	1.0	3.1	7.6	3.5%
technical / service areas	4.3%	502	203	85%	86	3.0%	0.035	1.0	3.0	6.0	3.4%
eating / drinking areas	4.2%	496	200	86%	85	2.9%	0.030	1.0	2.5	5.1	2.9%
Sports Hall	2.1%	242	500	64%	77	2.7%	0.025	1.0	2.0	8.1	2.3%
Examination / Treatment Rooms	1.5%	180	500	80%	72	2.5%	0.029	1.0	2.1	11.6	2.4%
Theater, Dancing, Amusementpark	3.0%	358	200	95%	68	2.3%	0.030	1.0	2.0	5.7	2.3%
Storeroom / Warehouse	6.6%	774	100	78%	60	2.1%	0.030	1.0	1.8	2.3	2.0%
waiting areas	1.5%	179	214	95%	36	1.2%	0.031	1.0	1.1	6.3	1.3%
Libraries, musea, zoo	1.0%	112	381	73%	31	1.1%	0.031	1.0	1.0	8.7	1.1%
Laboratories	0.6%	66	500	92%	31	1.0%	0.027	1.0	0.8	12.4	0.9%
Radio and TV	0.9%	107	300	93%	30	1.0%	0.030	1.0	0.9	8.4	1.0%
Hospital wards/bedrooms	1.6%	191	300	51%	29	1.0%	0.029	1.0	0.8	4.4	1.0%
Video and Movie production and Cinemas	1.3%	152	200	95%	29	1.0%	0.030	1.0	0.9	5.7	1.0%
Kitchens	0.5%	60	500	92%	27	0.9%	0.028	1.0	0.8	13.0	0.9%
Hotel rooms (excl toilet/shower)	1.2%	138	300	64%	27	0.9%	0.034	1.0	0.9	6.5	1.0%
Political and religious (incl. churches)	1.3%	152	125	92%	17	0.6%	0.030	1.0	0.5	3.5	0.6%
Parking in structures	2.5%	290	75	82%	18	0.6%	0.022	1.0	0.4	1.3	0.4%
Waste disposal / sewage	0.3%	37	200	95%	7	0.2%	0.030	1.0	0.2	5.7	0.2%
Prisons	0.3%	34	200	95%	6	0.2%	0.030	1.0	0.2	5.7	0.2%
Fire service activities	0.0%	4	200	95%	1	0.0%	0.030	1.0	0.0	5.7	0.0%
Total Non-Residential (task level)	100%	11773	305	81%	2918	100%	0.030	1.0	87.4	7.4	100%

F5 Determination of Operating Hours

As regards operating hours for lighting in non-residential buildings, EN 15193 starts from potential hours during which some form of lighting might be necessary, split in daytime hours (tD) and night-time hours (tN), see Table 0-16.

The potential daytime hours (tD) are reduced in function of the availability of daylight, and in function of the presence of control systems that can dim or switch-off lights accordingly. This is expressed by means of the daylight dependency factor Fd.

The potential night-time hours (tN) and the (reduced) daytime hours (tD*Fd) can be further reduced in function of the degree of occupancy of the rooms/buildings considered, and in function of the presence of control systems that can detect the presence/absence, and dim or switch-off lights accordingly. This is expressed by means of the occupancy dependency factor Fo.

As a consequence, the effective operating hours are computed as:

$$t_{oper} = Fo * (Fd * tD + tN) \quad (\text{hours/year})$$

In addition prEN 15193 foresees a constant illuminance factor Fc. The installed lighting power has been overdesigned (with respect to requirements) by a factor (1/MF) to account for the degradation of the lighting products (and of the reflection by their surroundings) with time. This implies that initially there would be more light available than required, and consequently lights should be dimmed to the required level to minimise energy consumption. The amount of dimming would then decrease with time, to compensate for the degradation of the lighting system. This could be done automatically by means of 'constant illuminance control'. The average amount of dimming for compensation of degradation is reflected by the factor Fc:

- Fc = 1.0, if no dimming system is installed
- Fc = (1+MF)/2, if there is a dimming system, but no automatic control
- Fc = 1-0.5*Fcc*(1-MF), in case of automatic control with efficiency Fcc.

As the effects of occupancy- and daylight-dimming act on the operating hours, it would be logical to make Fc also act on these hours. Alternatively, Fc could be conceived as reducing the power, as dimming actually does, but dimming effects would then be partially accounted on operating hours and partially on power, which is somewhat confusing.

For the moment the factor Fc has NOT been applied in the values shown in this note, but it is considered when comparing values with those from the MELISA model.

F5.1 Potential Operating Hours

The potential operating hours have been taken from prEN 15193 table B.2.3.2 (see Table 0-16 of this note). The following remarks can be made regarding these hours:

- The standard explains that: "The values are based on the estimated time people likely to occupy or be in the premises and will require some form of illumination." This seems to assume that if there are no people there is no lighting. This is not always true: in some occasions lights may intentionally be left on, even if at a lower level, for security reasons or for publicity ¹⁵.

¹⁵ The impression is that in many shops the window lights remain on longer than the shop opening times, so that people can still see the advertised goods.

- The values in the table are presented as default values, but it is not stated anywhere that they are median or average values. For building types that have more or less defined closure and opening times, such as offices, education buildings, restaurants, sports facilities and (maybe) retail, the table values could be reasonable averages.
- For building types/sectors where a relevant number of buildings never really close completely, this is more doubtful. Many hospitals, hotels and manufacturing factories (continuous processing) never really close, and it is not clear how this has been handled. For hospitals there are even night-time lighting requirements in EN 12464-1 (50 lux for corridors; 5 lux for wards) that do not seem to be captured by the EN 15193 hours.
- In reality, tD and tN could be chosen in any desired way, as long as the occupancy factors F_o correctly consider these periods, e.g. $tD+tN = 4000+2000$ with $F_o=0.5$ is the same as $tD+tN = 2000+1000$ with $F_o=1.0$.
- The use of the EN 15193 default potential hours as average EU-28 hours, as done in this note, is therefore rather doubtful¹⁶. Anyway the exercise in this note has been performed, also to satisfy a curiosity.

The following additional remarks apply regarding the use of potential operating hours in this note (see Table 0-29 for reference):

- In prEN 15193, the potential hours for hotels and restaurants are different, while in this note these buildings have been considered together as one category. As shown in Table 0-29, for some room types the hotel-hours have been used, for some the restaurant-hours, and for some an average based on underlying area information.
- For some room/building types no reference information was available for potential operating hours. These have been estimated as specified below.
- For private-parkings (near offices), video and movie production, radio and tv studios, waste disposal, libraries, museums and zoos, the same potential hours have been assumed as for office buildings (2250/250).
- For theatres, dancing, amusement parks, the same potential hours have been assumed as for restaurants (1250/1250).
- For public-parkings, stations and airports, an average 6 hour night-time closure has been assumed, during which lighting is never required. In a rough estimate it has been assumed that on average daytime and night-time are 12 hours/day each, leading to $tD=4380$ h/a and $tN=2190$ h/a.
- For prisons and fire service activities, the same potential hours have been assumed as for hotels (3000/2000), respectively with absence factors 0.0 and 0.8.

¹⁶ Additional occupancy pattern reference data are available in prEN 15251:2014, but they are limited to some types of buildings, and too generic for use in this study. In addition they do not correspond with the data in EN 15193, e.g. for restaurants EN 15251 foresees lighting from 7 o'clock in the morning until midnight for all days of the week, including weekends. This would lead to considerably more than the $tD+tN = 1250+1250$ h/a from EN 15193.

- For political and religious buildings, including 200 000 churches, it is extremely difficult to estimate the potential operating hours. At the end $tD/tN = 2500/1500$ h/a was decided, with an absence factor of 0.5.

F5.2 Occupancy dependent factor

The occupancy dependent factor F_o depends on the absence factor F_a and the occupancy control factor F_{oc} .

The absence factor F_a reflects the part of the potential operating hours (NOT the part of the entire year) that a given room is not occupied. These data have mainly been taken from prEN 15193 table E.2 (see Table 0-17 in this note). Other absence factors have been estimated as shown in Table 0-29.

The occupancy control factor F_{oc} reflects how the control system (if present) reacts to the absence of persons in the room. Its value varies from 1.0 for manual control (simple on/off switch) to 0.8 for the best automatic system with presence/absence detection, automatic switch-off and manual switch-on. Both extreme values have been considered.

The occupancy dependent factor ' $F_o = 1 - F_a$ ' for the best automatic control system, essentially implies that lights are off when the room is not occupied. For other less efficient control systems, lights will only be dimmed, or they will remain on, even if the room is not occupied. In particular, for the manual control system (on/off switch), for absence factors of 0.2 or below, $F_o = 1$ and the absence does not have any effect.

In formula: $F_o = \text{MIN} \{ 1 - [(1 - F_{oc}) * F_a / 0.2] ; (F_{oc} + 0.2 - F_a) ; [7 - (10 + F_a)] * (F_a - 1) \}$

For further information see prEn 15193-1, annex E, figure E.1 and table E.3.

F5.3 Daylight dependent factor

The daylight dependent factor expresses which part of the lighting requirement can be fulfilled by means of daylight: only the remaining part needs to be integrated with artificial lighting. This means that in the presence of daylight, the artificial lights can be turned-off or dimmed, even during the potential operating hours.

The daylight dependent factor $F_d = 1 - F_{ds} * F_{dc}$, where F_{ds} represents the availability of daylight in the room and F_{dc} represents the reaction of the control system to the presence of the daylight. Note that:

- $F_d = 1$ means no daylight use (all light is artificial)
- $F_d = 0$ means all lighting by daylight (no artificial light).

Notwithstanding its name, F_d indicates the part of time that artificial lighting is being used.

For a specific room in a specific building in a specific place in Europe the determination of the daylight dependent factor is not an easy task, see prEN 15193 annex F. It is even more difficult to estimate an EU-28 average daylight contribution for a generic room of a certain type (e.g. circulation area) in a building of a certain type (e.g. office building).

Anyway an attempt has been made, based on the following assumptions ¹⁷:

¹⁷ It is not feasible to explain all details of the daylight contribution calculation here: see prEN 15193 annex F for details.

- daylight availability classification (table F.1): as average for EU, only 'low' ($D_{ca}=2-4\%$) and 'medium' ($D_{ca}=4-6\%$) are considered. For some rooms, 'no daylight availability' has also been considered, but in these cases $F_d=1$ and no further calculations are required.
- luminous exposure H_{dir}/H_{glob} , average for EU : 0.42 (table F.2)
- average latitude for EU-28: 50 degrees (Frankfurt) ($45 < \gamma < 60$ for some tables)
- average facade orientation: slightly better than east/west; more or less corresponds to random use of all orientations, but slightly more south-oriented.
- average 75% of time no sun shading (SNA), 25% of time sun shading (SA), both for facade and roof-lights
- for F_d s in absence of sun-shading system, in tables F.4, F5, F6, used effective glazing transparency (τ_{eff}) $0.7 \cdot 0.7 \cdot 0.9 \cdot 0.85 = 0.4$ ($D=0.4 \cdot D_{ca}$) 'low' ($D=1\%$) 'medium' ($D=2\%$)
- type of shading system: 50% glare protect (1), 20% auto-operated (2), 10% light guides (3), 20% no protection (4)
- roof lights: use 45 degree inclination values
- daylight responsive control: consider 'manual' (worst option) and 'automated, dimmed, no standby losses, no switch-on' (best automated option). For 100 lux use 300 lux F_{dc} values.

Using the above assumptions, the following values have been derived for F_d :

Facade

Low Daylight availability

manual controls	0.66	0.74	0.81	(for 100, 300, 500 lux)
best auto controls	0.47	0.59	0.67	(for 100, 300, 500 lux)

Medium Daylight availability

manual controls	0.58	0.65	0.76	(for 100, 300, 500 lux)
best auto controls	0.35	0.46	0.60	(for 100, 300, 500 lux)

Roof lights

Low Daylight availability

manual controls	0.52	0.60	0.70	(for 100, 300, 500 lux)
best auto controls	0.25	0.37	0.47	(for 100, 300, 500 lux)

Medium Daylight availability

manual controls	0.46	0.49	0.56	(for 100, 300, 500 lux)
best auto controls	0.17	0.21	0.27	(for 100, 300, 500 lux)

Note that the daylight factors also depend on the required lighting level. Higher lighting requirements typically have higher daylight factors, meaning that artificial lighting is used for a longer time. This is also intuitive: if lighting requirements are low (100 lux), it will be more often possible to satisfy them using only daylight; if lighting requirements are high (500 lux), it will be more often necessary to integrate with artificial lighting.

Regarding the daylight factors reported in Table 0-29, the following explanations are given:

- The reference for the lighting requirement is the Task Area lux (column 4 of Table 0-21):
 - $E_{task} < 200$ lux: the daylight factor for 100 lux is used
 - $200 \leq E_{task} < 400$ lux: the daylight factor for 300 lux is used
 - $E_{task} \geq 400$ lux: the daylight factor for 500 lux is used
- Low availability columns: contain the lowest estimate for daylight availability, i.e. the highest daylight factors (longer time for artificial lighting). For room types that are not exceptionally dark (on average), the F_d values are those reported above for 'low availability', corresponding to Dca 2-4%. For room types that have been considered exceptionally dark (on average) the reported values are a weighted average between $F_d=1$ ('no daylight availability') and the F_d values reported above for 'low availability' (F_{dlow}), typically with weight $> 50\%$ for $F_d=1$.
- Medium availability columns: contain the highest estimate for daylight availability, i.e. the lowest daylight factors (shorter time for artificial lighting). For room types that are not exceptionally dark (on average), the F_d values are those reported above for 'medium availability', corresponding to Dca 4-6%. For room types that have been considered exceptionally dark (on average) the reported values are a weighted average between $F_d=1$ ('no daylight availability') and the F_d values reported above for 'low availability' (F_{dlow}), typically with weight $< 50\%$ for $F_d=1$.
- 'Manual' and 'best auto' columns: 'manual' reflects the worst option for the daylight responsive control, i.e. a simple on/off switch commanded manually. 'Best auto' : reflects the best option for the daylight responsive control, i.e. 'automated, dimmed, no standby losses, no switch-on'.
- Manufacturing areas: assumed 25% façade lighting and 75% roof lights.
- Reception and circulation areas, shops, video/movie studio, theatre, libraries, museums, prisons: low is $50\% * (F_d=1)$ and $50\% * (F_{dlow})$; medium is $0\% * (F_d=1)$ and $100\% * (F_{dlow})$.
- Toilets, showers, wardrobes, technical areas, parkings: low is $90\% * (F_d=1)$ and $10\% * (F_{dlow})$; medium is $50\% * (F_d=1)$ and $50\% * (F_{dlow})$.

F5.4 Estimate for Operating Hours

Effective operating hours are computed as:
(hours/year)

$$t_{oper} = F_o * (F_d * t_D + t_N)$$

Table 0-29 (full list), Table 0-30 (summary for building types) and Table 0-31 (summary for room types) report four values for effective operating hours, depending on daylight availability and presence of control systems:

- Low daylight availability
 - o manual control system (both for occupancy control and daylight control)
 - o best automated control system (both for occupancy control and daylight control)

- Medium daylight availability
 - o manual control system (both for occupancy control and daylight control)
 - o best automated control system (both for occupancy control and daylight control)

Conclusions:

- 1- Based on the potential lighting operating hours and occupancy factors from prEN 15193, and VHK estimates of daylight dependency factors, the average EU-28 effective lighting operating hours for non-residential buildings are estimated between 2538 and 2739 h/a when manual occupancy and daylight controls are assumed, and between 1858 and 2120 h/a when best automated controls are assumed.
- 2- The EU-28 average control system for occupancy dependent and daylight dependent lighting is currently expected to be closer to the manual system than to the best automated system. This leads to an estimate between 2300 and 2600 h/a.
- 3- The above estimates do NOT take into account the beneficial effects of constant illuminance control, that is used to dim the initially over-dimensioned lighting capacity in function of the degree of degradation of the lighting products and room surfaces with time. Assuming that at least half of the installations allow such a dimming (either manual or automatic), a correction factor not higher than $F_c = 0.95$ ¹⁸ can be applied to the operating hours, leading to an estimate for the average EU-28 effective lighting operating hours for non-residential buildings between 2200 and 2500 h/a (full power equivalent hours).
- 4- For non-residential indoor lighting (excluding HID lamps, assumed to be used mainly in outdoor lighting) the MELISA model for 2013 shows an installed-power-weighted average operating time of 1467 h/a. This average mainly results from¹⁹:

- LFL	57.9 GW	2200 h/a
- CFLni	4.4 GW	1600 h/a
- CFLi	14.5 GW	500 h/a
- Halogen lamps	22.3 GW	450 h/a
- GLS incandescent lamps	6.1 GW	450 h/a
- 5- The difference between the two estimates confirms that lighting operating hours for the indoor non-residential sector are among the most difficult lighting parameters to establish.
 As stated before, it is not certain that the potential operating hours of EN 15193 (from which the 2200-2500 h/a estimate derives) are EU-28 averages, and their status and background should be further clarified. In addition the occupancy and daylight factors used in the estimate have a high degree of uncertainty.
The MELISA value of 1467 h/a seems to be on the low side, but comparing it with the values from measuring campaigns as reported in the Task 3 report table 42 of the Light Sources study, it seems to be quite reasonable.

¹⁸ If all installations allowed manual dimming, considering that a maintenance factor of $MF=0.8$ has been assumed, the factor would be $F_c=(1+0.8)/2=0.9$. The beneficial effect is assumed to be halved, so the factor becomes 0.95.

¹⁹ Installed powers are reported inclusive ballast power.

- 6- As regards building types, the highest annual operating hours are estimated for stations/airports (2849-4736 h/a), retail sector (3454-4416 h/a) and healthcare sector (2699-3854 h/a). The lowest hours have been found for Education (668-1248 h/a) and Offices (1158-1869 h/a).
- 7- As regards room/activity types, the highest annual operating hours are estimated for Shops (3770-4610 h/a), Prisons (3770-4610 h/a), Laboratories (3040-4430 h/a) and Hospital wards/bedrooms (3380-4220 h/a). The lowest hours have been found for Technical/Service areas (461-1078 h/a), Class rooms (706-1359), Meeting rooms (855-1499) and Libraries and Museums (871-1581 h/a).

Table 0-29 Potential operating hours, occupancy factors, estimated daylight factors and effective operating hours, based on prEN 15193. (source: VHK 2015)

cyan fields are inputs, can be changed green fields are based on formulas but can be changed if desired	potential daytime hours, tD h/a	potential nighttime hours, tN h/a	absence factor FA	occupancy control factor Foc		occupancy dependency factor Fo		Daylight Dependency Factor				effective operating hours (h/a)			
								low availability		medium availability		low availability		medium availability	
				manual	best auto	manual	best auto	manual control	best auto	manual control	best auto control	manual control	best auto	manual control	best auto control
Total Manufacturing / Industry												3048	2220	2806	1922
Production Area	2500	1500	0.10	1.0	0.8	1.0	0.9	0.73	0.52	0.61	0.35	3319	2520	3025	2143
Reception / Circulation Areas	2500	1500	0.20	1.0	0.8	1.0	0.8	0.83	0.74	0.66	0.47	3575	2670	3150	2140
Common toilets, showers, wardrobes	2500	1500	0.70	1.0	0.8	0.5	0.3	0.97	0.96	0.87	0.80	1968	1169	1838	1046
Offices	2500	1500	0.30	1.0	0.8	0.9	0.7	0.81	0.67	0.76	0.60	3173	2223	3060	2100
Technical Service Rooms	2500	1500	0.90	1.0	0.8	0.3	0.1	0.97	0.96	0.87	0.80	1181	390	1103	349
Total Retail & Wholesale / Trade												4416	4034	4034	3454
Shops < 30 m2	3000	2000	0.00	1.0	0.8	1.0	1.0	0.87	0.80	0.74	0.59	4610	4385	4220	3770
Shops > 30 m2	3000	2000	0.00	1.0	0.8	1.0	1.0	0.87	0.80	0.74	0.59	4610	4385	4220	3770
Reception / Circulation Areas	3000	2000	0.00	1.0	0.8	1.0	1.0	0.83	0.74	0.66	0.47	4490	4205	3980	3410
Common toilets and wardrobes	3000	2000	0.50	1.0	0.8	0.7	0.5	0.97	0.96	0.87	0.80	3445	2439	3227	2193
Storeroom / Warehouse	3000	2000	0.40	1.0	0.8	0.8	0.6	0.88	0.81	0.76	0.63	3712	2663	3424	2325
Hotel & Restaurant (total)												2328	1832	2211	1687
Rooms (excl. toilet/shower)	3000	2000	0.60	1.0	0.8	0.6	0.4	0.74	0.59	0.65	0.46	2532	1508	2370	1352
Toilet/Shower in rooms	3000	2000	0.90	1.0	0.8	0.3	0.1	0.97	0.96	0.87	0.80	1477	488	1383	439
Common toilets/wardrobes	1985	1565	0.50	1.0	0.8	0.7	0.5	0.97	0.96	0.87	0.80	2449	1734	2304	1572
Reception/ Circulation areas	1985	1565	0.30	1.0	0.8	0.9	0.7	0.83	0.74	0.66	0.47	2891	2117	2588	1749
Breakfast / Eating areas	1250	1250	0.00	1.0	0.8	1.0	1.0	0.74	0.59	0.65	0.46	2175	1988	2063	1825
Coffeeshops, Bars, Discotheques	1250	1250	0.00	1.0	0.8	1.0	1.0	0.74	0.59	0.65	0.46	2175	1988	2063	1825
Offices	1985	1565	0.40	1.0	0.8	0.8	0.6	0.81	0.67	0.76	0.60	2538	1737	2459	1654
Meeting Rooms	3000	2000	0.40	1.0	0.8	0.8	0.6	0.81	0.67	0.76	0.60	3544	2406	3424	2280
Kitchen	1250	1250	0.00	1.0	0.8	1.0	1.0	0.96	0.93	0.91	0.84	2453	2418	2381	2294
Technical areas	1985	1565	0.98	1.0	0.8	0.1	0.0	0.97	0.96	0.87	0.80	210	69	198	63
Education Total												1248	787	1138	668

cyan fields are inputs, can be changed green fields are based on formulas but can be changed if desired	potential daytime hours, tD h/a	potential nighttime hours, tN h/a	absence factor FA	occupancy control factor Foc		occupancy dependency factor Fo		Daylight Dependency Factor				effective operating hours (h/a)			
				manual	best auto	manual	best auto	low availability		medium availability		low availability		medium availability	
								manual control	best auto	manual control	best auto control	manual control	best auto	manual control	best auto control
Creche, play area	1800	200	0.40	1.0	0.8	0.8	0.6	0.74	0.59	0.65	0.46	1226	757	1096	617
(Pre-)Primary resting area	1800	200	0.40	1.0	0.8	0.8	0.6	0.74	0.59	0.65	0.46	1226	757	1096	617
Class Rooms	1800	200	0.30	1.0	0.8	0.9	0.7	0.74	0.59	0.65	0.46	1379	883	1233	720
Meeting Rooms	1800	200	0.50	1.0	0.8	0.7	0.5	0.81	0.67	0.76	0.60	1161	703	1098	640
Library	1800	200	0.40	1.0	0.8	0.8	0.6	0.81	0.67	0.76	0.60	1326	844	1254	768
Teacher's Room	1800	200	0.40	1.0	0.8	0.8	0.6	0.74	0.59	0.65	0.46	1226	757	1096	617
Computer education area	1800	200	0.30	1.0	0.8	0.9	0.7	0.74	0.59	0.65	0.46	1379	883	1233	720
Reception/ Circulation Area	1800	200	0.60	1.0	0.8	0.6	0.4	0.83	0.74	0.66	0.47	1016	609	833	418
Common toilets / wardrobes	1800	200	0.70	1.0	0.8	0.5	0.3	0.97	0.96	0.87	0.80	977	578	883	489
Standard Offices	1800	200	0.30	1.0	0.8	0.9	0.7	0.81	0.67	0.76	0.60	1492	984	1411	896
Technical Service Rooms	1800	200	0.98	1.0	0.8	0.1	0.0	0.97	0.96	0.87	0.80	117	39	106	33
Hospitals/Healthcare Total												3854	2957	3654	2699
Wards / Bedrooms	3000	2000	0.00	1.0	0.8	1.0	1.0	0.74	0.59	0.65	0.46	4220	3770	3950	3380
Dayroom / Eating Room	3000	2000	0.20	1.0	0.8	1.0	0.8	0.74	0.59	0.65	0.46	4220	3016	3950	2704
Examination / Treatment Rooms	3000	2000	0.40	1.0	0.8	0.8	0.6	0.81	0.67	0.76	0.60	3544	2406	3424	2280
Waiting Area	3000	2000	0.00	1.0	0.8	1.0	1.0	0.74	0.59	0.65	0.46	4220	3770	3950	3380
Reception / Circulation Areas	3000	2000	0.00	1.0	0.8	1.0	1.0	0.83	0.74	0.66	0.47	4490	4205	3980	3410
Common toilets, wardrobes, showers	3000	2000	0.50	1.0	0.8	0.7	0.5	0.97	0.96	0.87	0.80	3445	2439	3227	2193
Standard offices	3000	2000	0.30	1.0	0.8	0.9	0.7	0.81	0.67	0.76	0.60	3987	2807	3852	2660
Laboratories	3000	2000	0.20	1.0	0.8	1.0	0.8	0.81	0.67	0.76	0.60	4430	3208	4280	3040
Technical Service / Production Areas	3000	2000	0.98	1.0	0.8	0.1	0.0	0.97	0.96	0.87	0.80	295	98	277	88
Offices Total												1869	1302	1745	1158
Cellular office	2250	250	0.30	1.0	0.8	0.9	0.7	0.81	0.67	0.76	0.60	1865	1230	1764	1120
Open Plan Office (Landscape office)	2250	250	0.10	1.0	0.8	1.0	0.9	0.81	0.67	0.76	0.60	2073	1582	1960	1440
Reception/ Circulation Area	2250	250	0.30	1.0	0.8	0.9	0.7	0.83	0.74	0.66	0.47	1906	1333	1562	915
Common toilets / wardrobes / showers	2250	250	0.50	1.0	0.8	0.7	0.5	0.97	0.96	0.87	0.80	1709	1204	1545	1019
Meeting Rooms	2250	250	0.50	1.0	0.8	0.7	0.5	0.81	0.67	0.76	0.60	1451	879	1372	800
Copying, Server, Archive, Technical areas	2250	250	0.60	1.0	0.8	0.6	0.4	0.95	0.92	0.87	0.80	1430	926	1325	816
Sports Total												3145	2307	3026	2168
Sports Hall	2000	2000	0.30	1.0	0.8	0.9	0.7	0.81	0.67	0.76	0.60	3258	2338	3168	2240

cyan fields are inputs, can be changed green fields are based on formulas but can be changed if desired	potential daytime hours, tD h/a	potential nighttime hours, tN h/a	absence factor FA	occupancy control factor Foc		occupancy dependency factor Fo		Daylight Dependency Factor				effective operating hours (h/a)			
				manual	best auto	manual	best auto	low availability		medium availability		low availability		medium availability	
								manual control	best auto	manual control	best auto control	manual control	best auto	manual control	best auto control
Common toilets / wardrobes / showers	2000	2000	0.50	1.0	0.8	0.7	0.5	0.97	0.96	0.87	0.80	2764	1959	2618	1795
Reception/ Circulation Area	2000	2000	0.20	1.0	0.8	1.0	0.8	0.83	0.74	0.66	0.47	3660	2776	3320	2352
Mensa, Restaurant, Bar, Resting area	2000	2000	0.00	1.0	0.8	1.0	1.0	0.74	0.59	0.65	0.46	3480	3180	3300	2920
Offices	2000	2000	0.40	1.0	0.8	0.8	0.6	0.81	0.67	0.76	0.60	2896	2004	2816	1920
Parking in structures												2343	1150	2179	1023
public access	4380	2190	0.80	1.0	0.8	0.4	0.2	0.97	0.95	0.86	0.79	2568	1268	2390	1128
private access (offices)	2250	250	0.95	1.0	0.8	0.2	0.1	0.97	0.95	0.86	0.79	364	119	329	101
Stations, Airports, similar (Total)												4736	3267	4381	2849
passenger/client (waiting) area	4380	2190	0.25	1.0	0.8	1.0	0.8	0.74	0.59	0.65	0.46	5160	3581	4785	3154
reception and circulation areas	4380	2190	0.25	1.0	0.8	1.0	0.8	0.83	0.74	0.66	0.47	5534	4057	4827	3186
customs and security	4380	2190	0.20	1.0	0.8	1.0	0.8	0.91	0.84	0.81	0.67	6154	4678	5738	4100
common toilets, wardrobes, etc.	4380	2190	0.50	1.0	0.8	0.7	0.5	0.97	0.96	0.87	0.80	4519	3195	4200	2836
offices	4380	2190	0.60	1.0	0.8	0.6	0.4	0.81	0.67	0.76	0.60	3443	2050	3311	1927
Entertainment and news (Total)												2208	1872	2007	1596
Video and Movie production and Cinemas	2250	250	0.20	1.0	0.8	1.0	0.8	0.87	0.80	0.74	0.59	2208	1631	1915	1262
Radio and TV	2250	250	0.20	1.0	0.8	1.0	0.8	0.74	0.59	0.65	0.46	1915	1262	1713	1028
Theatre, Dancing, Amusement park	1250	1250	0.00	1.0	0.8	1.0	1.0	0.87	0.80	0.74	0.59	2338	2244	2175	1988
Miscellaneous (Total)												2301	1666	2086	1398
Prisons	3000	2000	0.00	1.0	0.8	1.0	1.0	0.87	0.80	0.74	0.59	4610	4385	4220	3770
Fire service activities	3000	2000	0.80	1.0	0.8	0.4	0.2	0.74	0.59	0.65	0.46	1688	754	1580	676
Waste disposal / sewage	2250	250	0.20	1.0	0.8	1.0	0.8	0.74	0.59	0.65	0.46	1915	1262	1713	1028
Political and religious (incl. churches)	2500	1500	0.50	1.0	0.8	0.7	0.5	0.66	0.47	0.58	0.35	2205	1338	2065	1188
Libraries, museums, zoo	2250	250	0.40	1.0	0.8	0.8	0.6	0.87	0.80	0.74	0.59	1766	1223	1532	947
Total Non-Residential (indoor)												2739	2120	2538	1858
MELISA 2013 indoor												1467			

Table 0-30 Estimate of effective operating hours, per non-residential building type, based on prEN 15193 potential hours and occupancy factors, and VHK-estimated daylight factors. (source: VHK 2015)

Summary per type of building	effective operating hours (h/a)			
	low daylight availability		medium daylight availability	
	manual control	best auto control	manual control	best auto control
Offices Total	1869	1302	1745	1158
Total Manufacturing / Industry	3048	2220	2806	1922
Total Retail & Wholesale / Trade	4416	4034	4034	3454
Education Total	1248	787	1138	668
Hospitals/Healthcare Total	3854	2957	3654	2699
Hotel & Restaurant (total)	2328	1832	2211	1687
Sports Total	3145	2307	3026	2168
Entertainment and news (Total)	2208	1872	2007	1596
Miscellaneous (Total)	2301	1666	2086	1398
Stations, Airports, similar (Total)	4736	3267	4381	2849
Parking in structures	2343	1150	2179	1023
Total Non-Residential (indoor)	2739	2120	2538	1858

Table 0-31 Estimate of effective operating hours, per non-residential room/activity type, based on prEN 15193 potential hours and occupancy factors, and VHK-estimated daylight factors. (source: VHK 2015)

Summary per type of room	effective operating hours (h/a)			
	low daylight availability		medium daylight availability	
	manual control	best auto control	manual control	best auto control
manufacturing area	3319	2520	3025	2143
offices (open space)	2073	1582	1960	1440
offices (cellular)	1865	1230	1764	1120
offices (general, small)	2779	1918	2677	1808
circulation areas	3115	2579	2717	2036
Shops < 30 m2	4610	4385	4220	3770
meeting rooms	1499	930	1424	855
Class rooms and similar	1359	867	1215	706
toilets, showers, wardrobes	2303	1529	2147	1363
Shops > 30 m2	4610	4385	4220	3770
technical / service areas	1078	521	1004	461
eating / drinking areas	2642	2302	2498	2105
Sports Hall	3258	2338	3168	2240
Examination / Treatment Rooms	3544	2406	3424	2280
Theatre, Dancing, Amusement park	2338	2244	2175	1988
Storeroom / Warehouse	3712	2663	3424	2325
waiting areas	3811	3133	3548	2785
Libraries, museums, zoo	1581	1063	1415	871
Laboratories	4430	3208	4280	3040
Radio and TV	1915	1262	1713	1028
Hospital wards/bedrooms	4220	3770	3950	3380
Video and Movie production and Cinemas	2208	1631	1915	1262
Kitchens	2453	2418	2381	2294
Hotel rooms (excl. toilet/shower)	2532	1508	2370	1352
Political and religious (incl. churches)	2205	1338	2065	1188
Parking in structures	2343	1150	2179	1023
Waste disposal / sewage	1915	1262	1713	1028
Prisons	4610	4385	4220	3770
Fire service activities	1688	754	1580	676
Total Non-Residential (indoor)	2739	2120	2538	1858

F6 Determination of Lighting Energy

The total EU-28 annual lighting energy for non-residential buildings is computed by multiplication of the total EU-28 installed power (chapter E4) and the annual operating hours (chapter E5). Considering that four estimates have been made for the operating hours, there are also four estimates for the energy, depending on the average quantity of daylight available in the EU buildings (low, medium) and on the type of lighting control for occupancy and daylight dependent lighting (manual, best automated option).

The results are shown in Table 0-32 (full list), Table 0-33 (summary per building type) and Table 0-34 (summary per room/activity type). All results are inclusive ballasts, but exclusive special purpose lamps, controls and standby. Effects of factors F_c (dimming for over-design) and FL (average efficacy) are NOT included in the table values, see comments below. The following conclusions can be drawn:

- 1- Based on data from prEN 15193 and VHK estimates, the annual energy for indoor lighting of EU-28 non-residential buildings is estimated between 222 and 240 TWh/a when manual occupancy and daylight controls are assumed, and between 162 and 185 TWh/a when best automated controls are assumed.
- 2- The EU-28 average control system for occupancy dependent and daylight dependent lighting is currently expected to be closer to the manual system than to the best automated system. This leads to an energy estimate between 200 and 230 TWh/a.
- 3- The above estimates do NOT take into account the beneficial effects of constant illuminance control. Considering a factor $F_c=0.95$ (see conclusions in E5.4), the estimate for the EU-28 annual lighting energy for non-residential buildings is between 190 and 220 TWh/a.
- 4- The above estimate is valid for an efficacy of 60 luminaire lumen per circuit Watt. As explained in E4.3, if the MELISA mix of lamp types is considered (with lower average efficacy), the installed power would be $FL=1.28$ times higher and consequently the annual energy would be 240-280 TWh/a.
- 5- For non-residential indoor lighting (excluding HID lamps, assumed to be used mainly in outdoor lighting) the MELISA model for 2013 shows an annual lighting energy of 155 TWh/a (inclusive ballasts; exclusive special purpose lamps, controls and standby).
- 6- The overall average energy density (LENI) for EU-28 non-residential buildings is 14-20 kWh/m²/a (not corrected for F_c and FL). The corresponding 2013-value from MELISA is 13 kWh/m²/a.
- 7- The difference between the two estimates derives almost entirely from a difference in operating hours, see remarks in E5.4.
- 8- As regards building types/sectors, the highest lighting energy is estimated for manufacturing/industry (38-61 TWh/a), for the retail sector (47-60 TWh/a) and for office buildings (24-39 TWh/a). The highest energy density is found for stations/airports (18-31 kWh/m²/a) and for hospital/healthcare (20-28 kWh/m²/a). Excluding parkings, the lowest energy density is found for educational buildings (6-11 kWh/m²/a).

- 9- As regards room/activity types, the highest annual lighting energy is estimated for manufacturing areas (27.5-42.5 TWh/a), although this is exceeded if the three office types are taken together (31.9-49.4 TWh/a). The highest energy density is found for laboratories (38-55 kWh/m²/a), small shops (38-46 kWh/m²/a) and examination/treatment rooms (26-41 kWh/m²/a). Low density values are found for parkings (1-3 kWh/m²/a), technical/service areas (3-6), political activities/churches (4-8) and warehouses (5-9).

Table 0-32 Installed power (GW), Operating hours (h/a), Annual lighting energy (TWh/a) and Energy density (kWh/m²/a, LENI), EU-28 totals for non-residential buildings (indoor), based on data in prEN 15193 and VHK estimates. Power and Energy are valid for MF=0.8 and 60 luminaire lumens per circuit Watt. Ballasts and control gears are included. Special purpose lamps, controls and standby are excluded. (source: VHK 2015)

Full list	EU-28 installed power GW @60 LL/W	installed power density W/m ² @60 LL/W	effective operating hours (h/a)				annual lighting energy (Twh/a) @60 LL/W				lighting energy density (kWh/m ² /a) @60 LL/W			
			low daylight availability		medium daylight availability		low daylight availability		medium daylight availability		low daylight availability		medium daylight availability	
			manual control	best auto control	manual control	best auto control	manual control	best auto control	manual control	best auto control	manual control	best auto control	manual control	best auto control
Total Manufacturing / Industry	20.0	8.1	3048	2220	2806	1922	60.9	44.4	56.1	38.4	24.8	18.0	22.8	15.6
Production Area	12.8	8.7	3319	2520	3025	2143	42.5	32.3	38.8	27.5	28.8	21.9	26.3	18.6
Reception / Circulation Areas	0.9	3.7	3575	2670	3150	2140	3.3	2.4	2.9	1.9	13.2	9.9	11.6	7.9
Common toilets, showers, wardrobes	1.6	6.4	1968	1169	1838	1046	3.1	1.8	2.9	1.6	12.6	7.5	11.7	6.7
Offices	3.3	13.3	3173	2223	3060	2100	10.4	7.3	10.0	6.9	42.1	29.5	40.6	27.8
Technical Service Rooms	1.4	5.8	1181	390	1103	349	1.7	0.6	1.6	0.5	6.8	2.3	6.4	2.0
Total Retail & Wholesale / Trade	13.6	5.7	4416	4034	4034	3454	60.0	54.8	54.8	46.9	25.2	23.0	23.0	19.7
Shops < 30 m ²	6.4	9.9	4610	4385	4220	3770	29.5	28.1	27.0	24.1	45.9	43.6	42.0	37.5
Shops > 30 m ²	3.1	7.6	4610	4385	4220	3770	14.1	13.4	12.9	11.5	35.0	33.3	32.0	28.6
Reception / Circulation Areas	1.6	3.6	4490	4205	3980	3410	7.3	6.8	6.5	5.6	16.2	15.2	14.4	12.3
Common toilets and wardrobes	0.7	6.4	3445	2439	3227	2193	2.5	1.8	2.3	1.6	22.0	15.6	20.6	14.0
Storeroom / Warehouse	1.8	2.3	3712	2663	3424	2325	6.6	4.7	6.1	4.1	8.6	6.1	7.9	5.4
Hotel & Restaurant (total)	4.9	6.5	2328	1832	2211	1687	11.4	9.0	10.8	8.3	15.1	11.9	14.4	11.0
Rooms (excl. toilet/shower)	0.9	6.5	2532	1508	2370	1352	2.3	1.4	2.1	1.2	16.5	9.9	15.5	8.8
Toilet/Shower in rooms	0.2	6.9	1477	488	1383	439	0.3	0.1	0.3	0.1	10.2	3.4	9.6	3.0
Common toilets/wardrobes	0.2	6.4	2449	1734	2304	1572	0.4	0.3	0.4	0.3	15.6	11.1	14.7	10.0
Reception/ Circulation areas	0.2	3.8	2891	2117	2588	1749	0.5	0.4	0.5	0.3	10.9	8.0	9.8	6.6
Breakfast / Eating areas	1.5	5.2	2175	1988	2063	1825	3.2	3.0	3.1	2.7	11.3	10.4	10.7	9.5
Coffeeshops, Bars, Discotheques	0.3	4.3	2175	1988	2063	1825	0.7	0.7	0.7	0.6	9.4	8.6	8.9	7.9
Offices	0.2	13.3	2538	1737	2459	1654	0.4	0.3	0.4	0.3	33.7	23.0	32.6	21.9
Meeting Rooms	0.4	13.2	3544	2406	3424	2280	1.5	1.0	1.5	1.0	46.6	31.7	45.0	30.0
Kitchen	0.8	13.0	2453	2418	2381	2294	1.9	1.9	1.8	1.8	32.0	31.5	31.1	29.9
Technical areas	0.2	5.8	210	69	198	63	0.0	0.0	0.0	0.0	1.2	0.4	1.1	0.4

Full list	EU-28 installed power GW @60 LL/W	installed power density W/m ² @60 LL/W	effective operating hours (h/a)				annual lighting energy (Twh/a) @60 LL/W				lighting energy density (kWh/m ² /a) @60 LL/W			
			low daylight availability		medium daylight availability		low daylight availability		medium daylight availability		low daylight availability		medium daylight availability	
			manual control	best auto control	manual control	best auto control	manual control	best auto control	manual control	best auto control	manual control	best auto control	manual control	best auto control
Education Total	11.0	8.5	1248	787	1138	668	13.8	8.7	12.6	7.4	10.6	6.7	9.6	5.7
Creche, play area	0.2	9.0	1226	757	1096	617	0.3	0.2	0.2	0.1	11.1	6.8	9.9	5.6
(Pre-)Primary resting area	0.4	6.3	1226	757	1096	617	0.5	0.3	0.4	0.2	7.7	4.7	6.9	3.9
Class Rooms	3.6	8.3	1379	883	1233	720	5.0	3.2	4.5	2.6	11.4	7.3	10.2	5.9
Meeting Rooms	2.3	14.3	1161	703	1098	640	2.6	1.6	2.5	1.5	16.6	10.0	15.7	9.1
Library	0.4	9.0	1326	844	1254	768	0.5	0.3	0.5	0.3	12.0	7.6	11.3	6.9
Teacher's Room	0.2	8.9	1226	757	1096	617	0.3	0.2	0.2	0.1	10.9	6.7	9.7	5.5
Computer education area	0.4	9.0	1379	883	1233	720	0.6	0.4	0.5	0.3	12.4	7.9	11.1	6.5
Reception/ Circulation Area	0.8	3.7	1016	609	833	418	0.9	0.5	0.7	0.4	3.8	2.3	3.1	1.6
Common toilets / wardrobes	0.4	6.2	977	578	883	489	0.4	0.2	0.4	0.2	6.0	3.6	5.5	3.0
Standard Offices	1.8	13.3	1492	984	1411	896	2.7	1.8	2.5	1.6	19.8	13.1	18.7	11.9
Technical Service Rooms	0.4	5.8	117	39	106	33	0.0	0.0	0.0	0.0	0.7	0.2	0.6	0.2
Hospitals/Healthcare Total	6.6	7.3	3854	2957	3654	2699	25.4	19.5	24.1	17.8	28.0	21.5	26.5	19.6
Wards / Bedrooms	0.8	4.4	4220	3770	3950	3380	3.6	3.2	3.3	2.9	18.7	16.7	17.5	15.0
Dayroom / Eating Room	0.3	5.1	4220	3016	3950	2704	1.4	1.0	1.3	0.9	21.4	15.3	20.0	13.7
Examination / Treatment Rooms	2.1	11.6	3544	2406	3424	2280	7.4	5.0	7.1	4.7	40.9	27.8	39.6	26.3
Waiting Area	0.7	6.1	4220	3770	3950	3380	2.9	2.6	2.7	2.3	25.8	23.1	24.2	20.7
Reception / Circulation Areas	0.5	3.7	4490	4205	3980	3410	2.2	2.0	1.9	1.6	16.8	15.7	14.9	12.7
Common toilets, wardrobes, showers	0.5	6.2	3445	2439	3227	2193	1.7	1.2	1.6	1.1	21.3	15.1	19.9	13.6
Standard offices	0.7	13.3	3987	2807	3852	2660	2.6	1.8	2.5	1.7	52.9	37.2	51.1	35.3
Laboratories	0.8	12.4	4430	3208	4280	3040	3.6	2.6	3.5	2.5	54.8	39.7	53.0	37.6
Technical Service / Production Areas	0.2	5.8	295	98	277	88	0.1	0.0	0.1	0.0	1.7	0.6	1.6	0.5
Offices Total	20.8	9.8	1869	1302	1745	1158	38.8	27.1	36.3	24.1	18.4	12.8	17.1	11.4
Cellular office	8.5	12.9	1865	1230	1764	1120	15.9	10.5	15.0	9.5	24.1	15.9	22.7	14.4
Open Plan Office (Landscape office)	6.8	11.1	2073	1582	1960	1440	14.0	10.7	13.2	9.7	23.0	17.5	21.7	16.0
Reception/ Circulation Area	1.6	3.8	1906	1333	1562	915	3.0	2.1	2.5	1.5	7.2	5.0	5.9	3.5
Common toilets / wardrobes / showers	0.9	6.4	1709	1204	1545	1019	1.6	1.1	1.5	1.0	10.9	7.7	9.9	6.5
Meeting Rooms	2.3	13.5	1451	879	1372	800	3.3	2.0	3.1	1.8	19.6	11.9	18.6	10.8
Copying, Server, Archive, Technical areas	0.7	6.5	1430	926	1325	816	1.0	0.6	0.9	0.6	9.3	6.0	8.6	5.3

Full list	EU-28 installed power GW @60 LL/W	installed power density W/m2 @60 LL/W	effective operating hours (h/a)				annual lighting energy (Twh/a) @60 LL/W				lighting energy density (kWh/m2/a) @60 LL/W			
			low daylight availability		medium daylight availability		low daylight availability		medium daylight availability		low daylight availability		medium daylight availability	
			manual control	best auto control	manual control	best auto control	manual control	best auto control	manual control	best auto control	manual control	best auto control	manual control	best auto control
Sports Total	4.2	7.7	3145	2307	3026	2168	13.1	9.6	12.6	9.1	24.1	17.7	23.2	16.6
Sports Hall	2.0	8.1	3258	2338	3168	2240	6.4	4.6	6.2	4.4	26.5	19.0	25.8	18.2
Common toilets / wardrobes / showers	0.6	6.2	2764	1959	2618	1795	1.7	1.2	1.7	1.1	17.1	12.1	16.2	11.1
Reception/ Circulation Area	0.2	3.8	3660	2776	3320	2352	0.9	0.7	0.8	0.6	13.8	10.5	12.5	8.9
Mensa, Restaurant, Bar, Resting area	0.4	5.7	3480	3180	3300	2920	1.3	1.2	1.2	1.1	19.9	18.2	18.9	16.7
Offices	0.9	14.0	2896	2004	2816	1920	2.7	1.9	2.7	1.8	40.5	28.0	39.4	26.9
Parking in structures	0.4	1.3	2343	1150	2179	1023	0.9	0.4	0.8	0.4	3.1	1.5	2.9	1.4
public access	0.3	1.3	2568	1268	2390	1128	0.9	0.4	0.8	0.4	3.4	1.7	3.2	1.5
private access (offices)	0.0	1.4	364	119	329	101	0.0	0.0	0.0	0.0	0.5	0.2	0.5	0.1
Stations, Airports, similar (Total)	0.7	6.5	4736	3267	4381	2849	3.3	2.3	3.0	2.0	30.7	21.1	28.4	18.4
passenger/client (waiting) area	0.2	5.3	5160	3581	4785	3154	1.2	0.8	1.1	0.7	27.1	18.8	25.2	16.6
reception and circulation areas	0.1	3.7	5534	4057	4827	3186	0.7	0.5	0.6	0.4	20.3	14.9	17.7	11.7
customs and security	0.1	13.2	6154	4678	5738	4100	0.4	0.3	0.4	0.3	81.5	61.9	75.9	54.3
common toilets, wardrobes, etc.	0.1	6.2	4519	3195	4200	2836	0.3	0.2	0.3	0.2	27.9	19.8	26.0	17.5
offices	0.2	13.3	3443	2050	3311	1927	0.7	0.4	0.7	0.4	45.7	27.2	43.9	25.6
Entertainment and news (Total)	3.8	6.2	2208	1872	2007	1596	8.4	7.1	7.6	6.1	13.6	11.5	12.4	9.8
Video and Movie production and Cinemas	0.9	5.7	2208	1631	1915	1262	1.9	1.4	1.7	1.1	12.6	9.3	10.9	7.2
Radio and TV	0.9	8.4	1915	1262	1713	1028	1.7	1.1	1.5	0.9	16.1	10.6	14.4	8.6
Theatre, Dancing, Amusement park	2.0	5.7	2338	2244	2175	1988	4.8	4.6	4.4	4.1	13.3	12.8	12.4	11.3
Miscellaneous (Total)	1.5	5.2	2301	1666	2086	1398	3.5	2.5	3.2	2.1	11.9	8.6	10.7	7.2
Prisons	0.2	5.7	4610	4385	4220	3770	0.9	0.8	0.8	0.7	26.3	25.0	24.1	21.5
Fire service activities	0.0	5.7	1688	754	1580	676	0.0	0.0	0.0	0.0	9.6	4.3	9.0	3.9
Waste disposal / sewage	0.2	5.7	1915	1262	1713	1028	0.4	0.3	0.4	0.2	10.9	7.2	9.8	5.9
Political and religious (incl. churches)	0.5	3.5	2205	1338	2065	1188	1.2	0.7	1.1	0.6	7.6	4.6	7.1	4.1
Libraries, museums, zoo	0.6	8.4	1766	1223	1532	947	1.0	0.7	0.9	0.5	14.8	10.3	12.9	8.0
Total Non-Residential (task level)	87	7.4	2739	2120	2538	1858	240	185	222	162	20.3	15.7	18.8	13.8
MELISA 2013 non-residential (lamp level)	121						218							
MELISA 2013 outdoor (all HID)	16						63							
MELISA 2013 indoor (lamp level)	106	9.0	1467				155				13.1			

Table 0-33 Building Summary, Installed power (GW), Operating hours (h/a), Annual lighting energy (TWh/a) and Energy density (kWh/m2/a, LENI), EU-28 totals for non-residential buildings (indoor), based on data in prEN 15193 and VHK estimates. Power and Energy are valid for MF=0.8 and 60 luminaire lumens per circuit Watt. Ballasts and control gears are included. Special purpose lamps, controls and standby are excluded. (source: VHK 2015)

Summary per type of building	EU-28 installed power GW @60 LL/W	installed power density W/m2 @60 LL/W	effective operating hours (h/a)				annual lighting energy (Twh/a) @60 LL/W				lighting energy density (kWh/m2/a) @60 LL/W			
			low daylight availability		medium daylight availability		low daylight availability		medium daylight availability		low daylight availability		medium daylight availability	
			manual control	best auto control	manual control	best auto control	manual control	best auto control	manual control	best auto control	manual control	best auto control	manual control	best auto control
Office buildings	20.8	9.8	1869	1302	1745	1158	39	27	36	24	18	13	17	11
Manufacturing / Industry	20.0	8.1	3048	2220	2806	1922	61	44	56	38	25	18	23	16
Retail & Wholesale / Trade	13.6	5.7	4416	4034	4034	3454	60	55	55	47	25	23	23	20
Educational buildings	11.0	8.5	1248	787	1138	668	14	9	13	7	11	7	10	6
Hospitals/Healthcare	6.6	7.3	3854	2957	3654	2699	25	19	24	18	28	21	27	20
Hotels & Restaurants	4.9	6.5	2328	1832	2211	1687	11	9	11	8	15	12	14	11
Sports buildings	4.2	7.7	3145	2307	3026	2168	13	10	13	9	24	18	23	17
Entertainment and news	3.8	6.2	2208	1872	2007	1596	8	7	8	6	14	12	12	10
Miscellaneous buildings	1.5	5.2	2301	1666	2086	1398	3	3	3	2	12	9	11	7
Stations, Airports, similar	0.7	6.5	4736	3267	4381	2849	3	2	3	2	31	21	28	18
Parking in structures	0.4	1.3	2343	1150	2179	1023	1	0	1	0	3	2	3	1
Total Non-Residential	87	7.4	2739	2120	2538	1858	240	185	222	162	20	16	19	14
MELISA 2013	106	9.0	1467				155				13.1			

Table 0-34 Room Summary, Installed power (GW), Operating hours (h/a), Annual lighting energy (TWh/a) and Energy density (kWh/m2/a, LENI) (source: VHK 2015)

Summary per type of room	EU-28 installed power GW @60 LL/W	installed power density W/m2 @60 LL/W	effective operating hours (h/a)				annual lighting energy (Twh/a) @60 LL/W				lighting energy density (kWh/m2/a) @60 LL/W			
			low daylight availability		medium daylight availability		low daylight availability		medium daylight availability		low daylight availability		medium daylight availability	
			manual control	best auto control	manual control	best auto control	manual control	best auto control	manual control	best auto control	manual control	best auto control	manual control	best auto control
manufacturing area	12.8	8.7	3319	2520	3025	2143	42.5	32.3	38.8	27.5	29	22	26	19
offices (open space)	6.8	11.1	2073	1582	1960	1440	14.0	10.7	13.2	9.7	23	18	22	16
offices (cellular)	8.5	12.9	1865	1230	1764	1120	15.9	10.5	15.0	9.5	24	16	23	14
offices (general, small)	7.0	13.4	2779	1918	2677	1808	19.5	13.4	18.8	12.7	37	26	36	24
circulation areas	6.0	3.7	3115	2579	2717	2036	18.7	15.5	16.3	12.2	12	10	10	8
Shops < 30 m2	6.4	9.9	4610	4385	4220	3770	29.5	28.1	27.0	24.1	46	44	42	38
meeting rooms	5.0	13.8	1499	930	1424	855	7.5	4.7	7.1	4.3	21	13	20	12
Class rooms and similar	4.7	8.1	1359	867	1215	706	6.3	4.0	5.7	3.3	11	7	10	6
toilets, showers, wardrobes	5.3	6.3	2303	1529	2147	1363	12.1	8.0	11.3	7.2	15	10	14	9
Shops > 30 m2	3.1	7.6	4610	4385	4220	3770	14.1	13.4	12.9	11.5	35	33	32	29
technical / service areas	3.0	6.0	1078	521	1004	461	3.2	1.6	3.0	1.4	6	3	6	3
eating / drinking areas	2.5	5.1	2642	2302	2498	2105	6.7	5.8	6.3	5.3	14	12	13	11
Sports Hall	2.0	8.1	3258	2338	3168	2240	6.4	4.6	6.2	4.4	27	19	26	18
Examination / Treatment Rooms	2.1	11.6	3544	2406	3424	2280	7.4	5.0	7.1	4.7	41	28	40	26
Theatre, Dancing, Amusement park	2.0	5.7	2338	2244	2175	1988	4.8	4.6	4.4	4.1	13	13	12	11
Storeroom / Warehouse	1.8	2.3	3712	2663	3424	2325	6.6	4.7	6.1	4.1	9	6	8	5
waiting areas	1.1	6.3	3811	3133	3548	2785	4.3	3.5	4.0	3.1	24	20	22	18
Libraries, museums, zoo	1.0	8.7	1581	1063	1415	871	1.5	1.0	1.4	0.8	14	9	12	8
Laboratories	0.8	12.4	4430	3208	4280	3040	3.6	2.6	3.5	2.5	55	40	53	38
Radio and TV	0.9	8.4	1915	1262	1713	1028	1.7	1.1	1.5	0.9	16	11	14	9
Hospital wards/bedrooms	0.8	4.4	4220	3770	3950	3380	3.6	3.2	3.3	2.9	19	17	17	15
Video and Movie production and Cinemas	0.9	5.7	2208	1631	1915	1262	1.9	1.4	1.7	1.1	13	9	11	7
Kitchens	0.8	13.0	2453	2418	2381	2294	1.9	1.9	1.8	1.8	32	32	31	30
Hotel rooms (excl. toilet/shower)	0.9	6.5	2532	1508	2370	1352	2.3	1.4	2.1	1.2	17	10	15	9
Political and religious (incl. churches)	0.5	3.5	2205	1338	2065	1188	1.2	0.7	1.1	0.6	8	5	7	4
Parking in structures	0.4	1.3	2343	1150	2179	1023	0.9	0.4	0.8	0.4	3	2	3	1
Waste disposal / sewage	0.2	5.7	1915	1262	1713	1028	0.4	0.3	0.4	0.2	11	7	10	6
Prisons	0.2	5.7	4610	4385	4220	3770	0.9	0.8	0.8	0.7	26	25	24	21
Fire service activities	0.0	5.7	1688	754	1580	676	0.0	0.0	0.0	0.0	10	4	9	4
Total Non-Residential	87.4	7.4	2739	2120	2538	1858	240	185	222	162	20	16	19	14

ANNEX G MEERP GUIDELINE TASK 4

The MEErP ²⁰ prescribes the following topics to be addressed in Task 4, Technologies: Identify, retrieve and analyse data, report on

Technical product description

illustrated with data on performance, price, resources/emissions impact of

- 4.1.1 Existing products (working towards definition of Base Cases)
- 4.1.2 Products with standard improvement (design) options
- 4.1.3 Best Available Technology BAT (best of products on the market)
- 4.1.4 Best Not yet Available Technology BNAT (best of products in field tests, labs, etc.)

Production, distribution and end-of-life

specifically regarding

- 4.2.1 Product weight and Bills-of-Materials (BOMs), preferably in EcoReport format (see Task 5)
- 4.2.2 Assessment of the primary scrap production during sheet metal manufacturing
- 4.2.3 Packaging materials
- 4.2.4 Volume and weight of the packaged product
- 4.2.5 Actual means of transport employed in shipment of components, sub-assemblies and finished products
- 4.2.6 Materials flow and collection effort at end-of-life (secondary waste), to landfill/ incineration/ recycling/ re-use (industry perspective)
- 4.2.7 Technical product life (time-to-failure of critical parts)

Recommendations

for

- 4.3.1 refined product scope from the technical perspective (e.g. exclude special applications for niche markets)
- 4.3.2 barriers and opportunities for Ecodesign from a technical perspective
- 4.3.3 the typical design cycle for this product and thus approximately appropriate timing of measures

²⁰ MEErP 2011, Methodology for Ecodesign of Energy-related Products, part 1: Methods and part 2: Environmental policies and data, René Kemna (VHK) November 28th 2011

ANNEX H STAKEHOLDER COMMENTS RECEIVED ON FIRST DRAFT TASK 0-1 (2015)

European Commission
DGENER
att. Mr. Paul van Tichelen

24. August 2015
Ref. SFC
Building and Energy Efficiency

By e-mail

The Danish Energy Agency (DEA) regrets it has not been possible before now to comment the Task 1 of the Lot 37 Ecodesign Preparatory Study on Lighting Systems. We hope that the comments will be useful for the study team anyway.

Please find the Stakeholder comments form (20150824_DEA Comments Lot37 Task 1 Comment Form.pdf) and the technical note "Lighting System Efficiency" (4785int033-Lighting_System_Efficiency.pdf)

Our comments primarily concern issues of in-coherence between the definition of the relevant primary parameter, the functional unit and its mathematical expression.

The main source of in-coherence between the three is a lack of clear distinction between the required illuminance being the primary parameter and the actual illuminance in the mathematical expressions of the functional unit. The technical note "Lighting System Efficiency" illustrates the differences and points to the coherent mathematical definition and method.

ÅF Lighting et al. did a development work in 2014-2015 for DIN under the Commission mandate M/485 to elaborate a method for a "most energy efficient Utilization Factor" to be used for product benchmark information on road lighting luminaires according to regulation 245/2009. This work has convinced us that a parameter based on the minimum required average illuminance is the only possibility for a good lighting system efficiency parameter. A NWIP for EN 13201-6 "Tables of the most energy efficient useful utilisation, utilisation and utilization factor" has been drafted in CEN TC 169 WG12 and should be included in the list of standards.

We look forward to see the next draft task reports.

Prepared by Peder Øbro poe@afhh.dk, ÅF Lighting/ÅF – Hansen & Henneberg for The Danish Energy Agency, DEA

Yours sincerely

Signe Friis Christensen



DG ENER Lot 37: Ecodesign Preparatory Study on Lighting Systems

Organization: Danish Energy Agency, DEA (represented by ÅF Lighting)	Name: Peder Øbro	Date: 24-08-2015
--	-------------------------	-------------------------

Task #	Section #	Page #	Topic	Comment	Proposed change	Reply study team
1	General Chapter 1 1.1 to 1.3	2-17	Energy efficiency of lighting systems	The basic definition of the relevant primary parameter for 'tertiary lighting systems' is "the <u>required</u> illumination (E [lx])" (illuminance). We agree with this definition. We find in inconsistent though that the definition of the functional unit and other efficiency parameters are based on the <u>actual</u> illuminance as the "actual illuminance" $\geq$ "required illuminance". Due to this a functional unit like the Lighting Power Density LPD is not uniquely related to the power consumption of the system and this is not appropriate. Please see the explanatory note "Lighting System Efficiency" <4785int033-Lighting_System_Efficiency.pdf> accompanying these comments.	Define the functional units e.g. the Lighting System Efficacy as is done for the Installation Efficacy in Annex B of FprEN 13201-5:2015 based on the <u>required</u> illuminance.	Agreed Has been done in the extend possible, taking into account differences in terminology in current drafts between prEN 13201-5 and EN15193 and aiming at a unified approach.
1	1.3.1	2-5	Figure 1-1, 1-2 and 1-3	When changing the definition of the functional unit to be Lighting System Efficacy or Installation Efficacy the figures are not valid any longer.	Revise the figures according to the change of definition of the functional unit.	Agreed Figures have been updated towards efficacy of system

Task #	Section #	Page #	Topic	Comment	Proposed change	Reply study team
1	1.3.3.1	11 and 12	The relevant primary parameter is: “The functional or useful luminous flux (Φ [lm]) per square meter equal to the required illumination (E [lx]) as calculated with secondary performance parameters as defined in standards <u>Notes:</u> · This functional unit is equivalent to the so-called ‘Lighting Power Density’ (LPD) [W/(m²·lx)] (Pr EN 13201-5) or ‘Lighting Energy Numerical Indicator’ (LENI) (kWh/m² per year) (EN 15193). · For an area where luminance is used instead of illuminance, the following conversion formula is used: · $E = L/Q_0$ where, E is the average illuminance L is the average luminance specified in cd/m² Q₀ is the average	1. It should be explained that the topic actually is only relevant for ‘tertiary lighting systems’ where lighting requirements apply. 2. It is very appropriate and stringent to base the definition (in bold) on “the <u>required</u> illumination (E [lx]) ...” (our underlining). We interpret this as the illuminance <u>required</u> in a standard, code or regulation for the task or relevant area. 3. Anyhow the parameter definition and the parameter specifications below the “<u>Notes:</u>” are not coherent as neither of the parameters are based on or dependent on the <u>required</u> illuminance. The Lighting Power Density (called Power Density <u>Indicator</u> [W/(m²·lx)] in FprEN 13201-5:2015) is based on the <u>actual</u> illuminance which often is larger than the required illuminance. This parameter should not be used because it makes installations look more efficient than they really are. Instead the Installation Luminous Efficacy [lm/W] (FprEN 13201-5:2015 Annex B) should be used. The LENI [W/m²] according to EN 15193 is not dependent on the illuminance at all, so it is not related to the relevant primary parameter but is a power or energy consumption parameter.	For ‘tertiary’ lighting systems designed to meet lighting requirements, the relevant primary parameter is: The functional or useful luminous flux (Φ [lm]) per square meter equal to the required illumination (E [lx]) as calculated with secondary performance parameters as defined in standards <u>Notes:</u> The functional unit as [useful lm per W] is: $\sum_{i=1}^n (\bar{E}_{i,min} \cdot A_i) / P$ where $\bar{E}_{i,min}$ is the minimum required average illuminance A_i is the sub-area to which the minimum required average illuminance applies P is the system power of the lighting installation used to light the relevant areas In case of street lighting for an area where luminance is used instead of illuminance, the following conversion formula is appropriate: · $E_{i,min} = L_{i,min} / 0,07$ where $L_{i,min}$ is the required minimum average luminance [cd/m²] (Annex B of FprEN 13201-5) For indoor lighting systems the ‘Lighting Energy Numerical Indicator’ (LENI) (kWh/m² per year) (EN 15193).is used as an lighting energy consumption parameter which	Agreed to clearly define ‘the minimum maintained illuminance’ as reference (added) Agreed to delete LENI from the notes.



Task #	Section #	Page #	Topic	Comment	Proposed change	Reply study team
			luminance coefficient (e.g. 0.07 for asphalt)"	We recommend LENI is left out and is replaced by an explanation. 5. The conversion of luminance to illuminance should be done in accordance with FprEN 13201-5:2015 Annex B: · $E = L/0,07$	is not equivalent to the functional unit.	
1	1.3.3.2	15	secondary performance parameters	The equations Functional unit [useful lm/W] (bottom of page 15) are not coherent with the relevant primary parameter (page 11-12) as the equations are not based on the <u>required</u> but on the actual illuminance. This is inappropriate as the actual illuminance in practice is often <u>higher</u> than the required illuminance. Therefore we recommend: 1. To introduce a couple of new parameters: The correction factor C_L from FprEN 13201-5:2015 and the Useful Utilance from prEN 13201-6:2015 being developed under the Commission mandate M/485 by CEN TC 169 WG12. 2. The equations Functional unit [useful lm/W] (at the bottom of page 15) is corrected and named "Lighting System Efficacy". For street lighting this is identical to the Installation Luminous Efficacy.	1. The following secondary parameters should be added: ▪ Correction and conversion factor for over lighting and for luminance or hemispherical illuminance based lighting designs C_L ratio of the luminous flux just sufficient to comply with the lighting requirements received by the reference surface to the (actual) luminous flux received by the reference surface. The luminous flux sufficient to comply with the lighting requirements is: $\bar{E}_{min} * A$ where $\bar{E}_{min}$ is the required minimum average illuminance. For road lighting requirements based on luminance: $\bar{E}_{min} = \bar{L}_{min}/0,07$ For requirements based on hemispherical illuminance: $\bar{E}_{min} = \bar{E}_{hs}/0,65$ ▪ Useful Utilance U_U ratio of the luminous flux just sufficient to comply with the lighting requirements received by the reference surface to the sum of the individual total fluxes	OK Parameters added Formulas will be updated in line with the reviewed figures and approach



Task #	Section #	Page #	Topic	Comment	Proposed change	Reply study team
					of the luminaires of the installation. The following relation apply: $U_U = C_L * U$ 2. Corrected formulas: The formulas to calculate the functional unit from the secondary lighting system performance parameters (see also Figure 1-1) is: Functional unit [useful lm/W] = $C_L * U * RSMF * LOR * LMF * \eta_{lamp} * LLMF * \eta_{gear} * BGF$ Or in the case of an LED luminaire (LOR=1, LMF includes LLMF, $\eta_{ls} * \eta_{power} = \eta_{luminaire}$ and U_U may be known directly): Functional unit [useful lm/W] = $U_U * RSMF * LMF * \eta_{luminaire} * BGF$	
1	1.4.1	27-28	Description of prEN 13201-5: 'Road lighting-Part 5: Energy performance indicators.'	1.The description is not based on the latest standard: FprEN 13201-5:2015 2. The last part "In Annex A on Energy efficiency benchmarking calculations reference designs are included ..." is not appropriate and should be deleted. 3. The standard has a major gap that should be described. For information: Denmark has voted against this standard.	1. The text should be based on the standard version, FprEN 13201-5:2015 or later. 2. Please delete the last part starting with: "In Annex A on Energy efficiency benchmarking calculations reference designs ..." including the Figure 1-12 3. Please describe the major gaps as: Potential gaps in EN 13201-5: The mandatory Annex A of the standard is not appropriate. Neither the PDI or the AECI (ECly) are real benchmark parameters for efficiency because: PDI does not account for over	Text updated based on the latest version and your input Note: Might need to be updated again when the final is available.



Task #	Section #	Page #	Topic	Comment	Proposed change	Reply study team
					lighting or good/bad adaption between the luminaire intensity distribution and the reflection table. Further the PDI and the AECI does not include <u>all</u> the reference sub-areas. Areas of strips for calculation of the edge illuminance ratio are excluded from the calculation of energy performance indicators although requirements apply to these strips so they should be included. Only the informative annexes B and C are appropriate. The mandatory parts of FprEN 13201-5:2015 are considered to be in conflict with the requirement in Commission Regulation 245/2009 for tables of most energy efficient utilization factors, UF and in conflict with Commission Mandate M/485 for facilitating the ecodesign regulation 245/2009 in this respect.	
1	1.4.1	27-28	prEN 13201-6:2015 Road Lighting - Part 6: Tables of the most energy efficient useful utilance, utilance and utilization factor	Description of this standard should be inserted. It is being developed under the Commission mandate M/485 including a preparatory study 2014-2015. The development of the standard is going on in CEN TC 169 WG12.	prEN 13201-6:2015 Road Lighting - Part 6: Tables of the most energy efficient useful utilance, utilance and utilization factor This standard is being developed under the Commission mandate M/485 including also a preparatory study 2014-2015. The standard facilitates a requirement for product information in the Commission Regulation 245/2009 ANNEX VII	Standard added Functional unit of the study updated in line with the remarks



Task #	Section #	Page #	Topic	Comment	Proposed change	Reply study team
					(on Street Lighting), 3. LUMINAIRE BENCHMARKS, clause 3.2: “(b) Utilisation Factor values for standard road conditions in tabular form for the defined road class. The table contains the most energy efficient UF values for different road widths, different pole heights, maximum pole distances, luminaire overhang and inclination, as appropriate for the given road class and luminaire design; (c)...” The standard and the preparatory study (M/485) are coherent with the <u>Annex B</u> of FprEN 13201-5:2015 and with the functional unit as defined in 1.3.3.2. <i>(Editorial: After the correction of 1.3.3.2 as explained above)</i>	

Lighting System Efficiency

Review of ecodesign functional unit for Lighting Systems

Technical note supporting comments to the ENER Lot 37 Ecodesign Preparatory Study Task 1

by Peder Øbro, ÅF Lighting on behalf of the Danish Energy Agency

Lighting energy efficiency parameters

For an energy efficiency parameter to be used as the functional unit in ecodesign it is a crucial condition that it is uniquely related to the power consumption of the system considered.

A functional unit for energy efficiency must be [service_performance to power] or [(service_performance × time) to energy]. The reciprocal may also be used as for instance [power to service_performance]

For lighting the functional unit is [useful lm per W].

The Lighting Power Density, LPD have been proposed as a reciprocal functional unit in the Lot 37 Ecodesign Preparatory Study Task 1. It is defined in FprEN 13201-5:2015 4. but as demonstrated below the LPD is not uniquely related to the power consumption of the system. The reason is that any lighting level above the required level is considered as useful if the LPD is used as functional unit.

A parameter based on the required average illuminance should be used instead. It may be called Installation Luminous Efficacy as in Annex B of FprEN 13201-5:2015, but it may also be called Lighting System Efficacy or Useful Efficacy. The symbol η_{system} is used here. By using this parameter, only the required lighting level is considered as useful.

The mathematical definitions of the two parameters for a simple case with only one relevant area are shown in the Table 1 below together with examples illustrating essential properties of the parameters.

The two parameters are not reciprocal as indicated in Figure 1-2 of the Preparatory Study on Lighting Systems - Lot 37 Task 1 report, but they are related as:

$$\eta_{system} = \frac{\bar{E}_{min}}{E_{av}} \cdot \frac{1}{LPD}$$

where

$\bar{E}_{min}$ is the required minimum average illuminance on the relevant area

E_{av} is the actual (calculated) average illuminance on the relevant area

Only the units of the two parameters are reciprocal as: [W/lm] and [lm/W]

The definition of a η_{system} may easily be extended to more complex cases with several relevant areas (surfaces) being subject to lighting requirements

Illustrating examples

Consider three examples of lighting systems for the same relevant area (in a rectangular room) all optimized to comply with the same lighting requirement. The systems have differ-

ent luminaires, A, B and C. Therefore the systems provide different Average Illuminance and use different System Power.

3 rows of luminaires are found to be the optimal choice for all the three luminaires. Differences are demonstrated in the Table 1 below.

Table 1 Examples of 3 lighting systems with different luminaires, A, B and C for the same room and the same lighting requirements

Area and lighting requirements				
Relevant area [m²]	A	90		
Required avarage illuminance [lx]	Emin	300		
Required uniformity	U0min	0,4		
Minimum maintained luminous flux required	Φmin = Emin*A	27000		
Installation and performance				
Luminaire – Lighting system		A	B	C
Luminaire power [W]	PI	32	32	32
Luminaire luminous flux [lm]	ΦI	3250	3500	3250
Luminaire Efficacy [lm/W]	ηI = ΦI/PI	101,6	109,4	101,6
Maintenance Factor	N	18	15	15
Number of luminaires	MF = LMF*LLMF	0,8	0,8	0,8
System power [W]	P = N*PI	576	480	480
Actual average illuminance [lx]	Eav	365	315	303
Actual uniformity	U0	0,4	0,5	0,4
Utilance	U = Eav*A/(N*ΦI)	0,702	0,675	0,699
Useful Utilance	U _U = Emin*A/(N*ΦI)	0,577	0,643	0,692
Lighting Power Density [W/(m²·lx)] = [W/lm]	LPD = P/(Eav*A)	0,0175	0,0169	0,0176
Power Density [W/m²]	PD = P/A	6,40	5,33	5,33
Lighting System Efficacy alias Installation Luminous Efficacy alias Usefull Efficacy [lm/W]	ηsystem = Emin*A/P	46,88	56,25	56,25

Luminaire A:

The luminous intensity distribution is too narrow and not optimal for the uniformity so 6 luminaires are required in each row making 18 luminaires where B and C only need 15 luminaires. Based on the LPD, the efficiency of A seems just as good as that of C but that is not true because the System Power and the Power Density of A are higher than those of C.

Luminaire B:

The luminaire efficacy [lm/W] is the highest of the three but the intensity distribution is wider so more light is spilled outside the relevant area. To obtain the required average illuminance 15 luminaires are needed (5 in each row). Based on the LPD, the efficiency of B is

better than that of C but that is not true because the system Power and the Power Density are not lower than those of C.

Luminaire C:

The luminaire luminous flux and the intensity distribution balance both the average luminance and the uniformity with good accuracy on the required values. Based on the LPD, the efficiency of C is a bit worse than that of A but that is not true because the system Power and the Power Density are lower than that of A.

A true efficiency parameter that can be used as the functional unit for ecodesign must be able to rank different solutions for the same case unambiguously in the same order as ranked according to lowest system power.

The Table 2 below illustrates that the Lighting Power Density does not comply with this requirement.

Table 2 Analysis of ranking order according to different parameters

Ranking order of the lighting systems A, B and C according to -		
lowest System Power	P [W]	B = C better than A
lowest Power Density	PD [W/m ²]	B = C better than A
lowest Lighting Power Density	LPD [W/(m ² ·lx)]	B better than A being better than C
highest Lighting System Efficacy	η_{system} [lm/W]	B = C better than A

As seen from the three examples only the parameter Lighting System Efficacy, η_{system} follows the system power and the power density accurately (however reciprocally). Therefore only the Lighting System Efficacy should be used as functional unit for lighting systems.

The problem with the LPD is that it does not reveal the power consumption caused by over lighting.

Further the Lighting Power Density does not reveal the savings from dimming or from adjustment of the average illuminance to the required illuminance! This is illustrated by the following examples.

Examples with adjustable lighting level

If the luminaires are adjustable then the average illuminance can be adjusted to exactly meet the required value: $E_{av} = E_{avd} = \bar{E}_{min}$.

The Table 3 shows the results when the three systems A, B and C are adjusted down to provide exactly the required illuminance.

Note: This adjustment is not the same as dimming in cases where dimming is implied by a temporary change of the required illuminance, $\bar{E}_{min}$.

Table 3 Examples of the 3 lighting systems with flux adjusted to just meet the required average illuminance. For clarity the luminaire efficacy is assumed to be constant.

Area and lighting requirements				
Relevant area [m²]	A	90		
Required avarage illuminance [lx]	Emin	300		
Required uniformity	U0min	0,4		
Minimum maintained luminous flux required	Φmin = Emin*A	27000		
Installation and performance – adjusted luminous flux and power				
Luminaire – Lighting system		A	B	C
Luminaire power [W]	PI	26	26	26
Adjusted luminaire power	PId	26,30	30,48	31,68
Adjusted Luminaire luminous flux [lm]	ΦId	2671,2	3333,3	3217,8
Luminaire Efficacy [lm/W]	Etald=ΦId/PId	101,6	109,4	101,6
Number of luminaires	N	18	15	15
Maintenance factor	MF = LMF*LLMF	0,8	0,8	0,8
Adjusted System power [W]	Pd	473,42	457,14	475,25
Actual average illuminance [lx]	Eavd	300,00	300,00	300,00
Actual uniformity	U0	0,4	0,5	0,4
Utilance	U = Eavd*A/(N*ΦId)	0,562	0,540	0,559
Useful Utilance	U _U = Emin*A/(N*ΦId)	0,562	0,540	0,559
Lighting Power Density [W/(m²·lx)] = [W/lm]	LPDd =Pd/(Eavd*A)	0,0175	0,0169	0,0176
Power Density [W/m²]	PDd = Pd/A	5,26	5,08	5,28
Lighting System Efficacy alias Installation Luminous efficacy alias Usefull efficacy [lm/W]	ηsystem,d = Emin*A/Pd	57,03	59,06	56,81

Comparing the two tables Table 1 and Table 3 it is seen that the Lighting Power Density, LPD does not change when the luminaire flux is adjusted although the system power goes down, so the LPD does not reveal the savings by adjustment (or dimming)!

The Lighting System Efficacy, η_{system} goes up reciprocally to the system power going down when the luminaire flux is adjusted downwards, and it still ranks the systems A, B and C in the same order as ranked according to lowest system power. This shows that The Lighting System Efficacy serves as a better efficiency parameter as shown in Table 4.

Table 4 Analysis of ranking order according to different parameters for the 3 lighting systems with flux adjusted to just meet the required average illuminance. For clarity the luminaire efficacy is assumed to be constant.

Ranking order of the lighting systems A, B and C according to -		
lowest System Power	P_d [W]	B better than A being better than C
lowest Power Density	PD_d [W/m ²]	B better than A being better than C
lowest Lighting Power Density	LPD [W/(m ² ·lx)]	B better than A being better than C
highest Lighting System Efficacy	η_{system} [lm/W]	B better than A being better than C

Concluding remarks

Using the LPD as functional unit implies that lighting above the required level is regarded as useful. This makes a bias in the efficiency rating of lighting systems making poorly designed systems look just as efficient as optimally designed systems just meeting the requirements.

Only a parameter as the η_{system} has appropriate properties for a fair and accurate functional unit.



Task #	Section #	Page #	Topic	Comment	Proposed change	Reply study team
					glare strategy o Light level follows above strategy Add these methods / functions in the context and remove the question marks.	
1	1.4.2	26	EN 15232	EN 15232 is currently undergoing a revision under the mandate M/480 however the lighting applications are not really taken into account since the contribution of those expert groups are little – and in the TC 247 / TC 371 little expertise in lighting is available. Would be great if lighting systems experts could join either M/480 activities and/or TC 247 maintenance work – including calculation methods in referenced standards. New Light controls functions to be taken into considerations: Development of advanced lighting controls functions in BACs: mostly the last developments are around adapting the light intensity to occupancy, Unoccupied/standby/ occupied functions with either dimming or partial light switch off: this typically with standby occupancy with presence detection in the building (access control) or level of occupancy (number of people in the room; CCTV,	Agree that the EE functions in EN 15232:2012 (and in the M/480-version) will need to be updated with available technologies and code of practices. Need for update of EN15232 in terms of Light Controls after current work in progress updates.	Eu.bac comment is included in the revised text to encourage participation



Task #	Section #	Page #	Topic	Comment	Proposed change	Reply study team
				people counting e.g. in public buildings, museum, stations) - Easy of reprogramming for the building user to change occupancy modes, avoid fixed programming on a bus - Coupling of shade control with light control like in France - the number of new control technologies available at light point (knx, web-lights, PoE) to be considered - The integration of monitoring functions of light control ratio (% of light switched off or dimmed during the year) in the Bacs		
1	1.5.1.1 Table 1-2	47	BACS – EN 15232 reference	It is not clear why LS and BACS are placed in the same table. EPBD should integrate the application of efficient light equipment, efficient LS and efficient BACS light control functions (under the base of EN 15232) in new and existing buildings	Modify in the title of the table: building automated and control systems to building automation and control systems. Both light equipment and BACS norms and efficiency standards need to be integrated in EPBD	The proposed edit has been done. The reason to include BACS within this table is that they are also one of the LS improvement options but they are often treated as a separate issue within EPBD regs.
1	1.4.5	45	List of standards with gaps	EN 15232 should be mentioned.	Put EN 15232 in the list.	Now added
1	1.6.6.10	84	Reference to EN 15232	Old reference used. EN 15232 is being edited right now in the M/480 and in roughly 8 months from now we'll be having a new version.	Update reference to EN 15232: 2012	New section discussing mandates added + reference



DG ENER Lot 37: Ecodesign Preparatory Study on Lighting Systems

Organization: IALD	Name: NICOLÁS FUENTES COLOMER	Date: 29 May 2015
------------------------------	---	-----------------------------

Task #	Section #	Page #	Topic	Comment	Proposed change	Reply study team
0 & 1	1. 1	1	OBJECTIVE	As a general comment, the members of the IALD would like to emphasise that the Study should completely address Lighting quality, especially the interplay of lighting and human factors. Energy efficiency, eco-design and lighting quality should together in shaping effective energy policy. Lighting quality's goal is to achieve the optimum balance between practical and aesthetic issues, taking into account human needs, the environment and building-related issues such as safety, energy codes and style. With this overarching idea, we have addressed several aspects of the study from the point of view of the profession of independent lighting designers.		noted text updated and also Similar comments from Lighting Europe are taken into account



Stakeholder comments form

0 & 1	1. 1	1	OBJECTIVE	The importance of light within the built environment is entirely described from the energy use point of view.	“Lighting provides a significant contribution to the experience of buildings. As well as basic requirements to fulfil tasks, the general lighting of buildings provides visibility, orientation and wayfinding. Current research shows that lighting has specific non–visual effects that influence mood, attention and wakefulness. These need to be considered in lighting system design to ensure the wellbeing of building users.”	
	1. 1	1	OBJECTIVE	The effects of outdoor lighting are not fully addressed. In outdoor lighting, quality (and quantity of light) differs vastly by age and culture/nationality. Comfort levels for young adults may differ entirely from elder people. For northern people an under lit almost atmospheric park or outdoor area is totally acceptable both in terms of security and comfort. This is not	“Outdoor lighting must provide effective illumination relevant to the task. These include place-making, orientation and wayfinding . Consideration of visual comfort is important as is avoiding unnecessary upward lighting, light trespass and	

Stakeholder comments form



				the case in Southern European countries.	glare. Consideration of the non visual effects of light are also necessary not only for humans but for the effect on the ecology of the area where light is used.”	
0 & 1	1	4	References to EN12464-1:2011	The suggestion that target levels in this standard should be the basis has some risks associated with it. The greatest risk being over illumination and therefore considerable energy wastage. This is particularly common in buildings designed before a final user or tenant is known. Under these circumstances there has been practice to light entire floor plates to task lighting levels as positions of workstations are not known at the design stage. Also, EN 12464-1 has detailed tables see below for healthcare lighting. Please also note design criteria from EN12464-1:2011: 4 Lighting design criteria 4.1 Luminous environment <i>For good lighting practice it is essential that as well as the required illuminances, additional qualitative and quantitative needs are satisfied.</i>	We would propose including the full design criteria from EN 12464-1:2011 for clarity of intent . These standards also deal with health care related issues: ANSI/IESNA RP-29-06: Lighting for Hospital and Health Care Facilities And CIBSE Lighting Guide 2: Hospitals and healthcare buildings	

Stakeholder comments form



				<i>Lighting requirements are determined by the satisfaction of three basic human needs:</i> <i>☐ visual comfort, where the workers have a feeling of well-being; in an indirect way this also contributes to a higher productivity level and a higher quality of work;</i> <i>visual performance, where the workers are able to perform their visual tasks, even under difficult circumstances and during longer periods;</i> <i>safety.</i> <i>Main parameters determining the luminous environment with respect to artificial light and daylight are:</i> <i>luminance distribution;</i> <i>illuminance;</i> <i>directionality of light, lighting in the interior space;</i> <i>variability of light (levels and colour of light);</i> <i>colour rendering and colour appearance of the light;</i> <i>glare;</i> <i>flicker.</i> <i>Values for illuminance and its uniformity, discomfort glare and colour rendering index are given in Clause 5;</i> <i>other parameters are described in Clause 4.</i> <i>NOTE In addition to the lighting there are other visual ergonomic parameters which influence visual performance,</i> <i>such as:</i>		
--	--	--	--	--	--	--

Stakeholder comments form



				<i>the intrinsic task properties (size, shape, position, colour and reflectance properties of detail and background),</i> <i>ophthalmic capacity of the person (visual acuity, depth perception, colour perception),</i> <i>intentionally improved and designed luminous environment, glare-free illumination, good colour rendering, high</i> <i>contrast markings and optical and tactile guiding systems can improve visibility and sense of direction and locality.</i> <i>See CIE Guidelines for Accessibility: Visibility and Lighting Guidelines for Older Persons and Persons with</i> <i>Disabilities.</i> <i>Attention to these factors can enhance visual performance without the need for higher illuminance.</i>		
0 & 1	1	5	Excluded systems	We would recommend including light art works and light art installations as excluded.	“For example, lighting systems designed to make themselves visible for purposes of signage or displays including works of art that are self illuminating or relay on specific illumination to achieve the artists required outcome”	Agreed, text added.



Stakeholder comments form

0 & 1	1. 3. 2. 1	5	Applicatio n areas	We would recommend including Building identity Lighting in outdoor non-public lighting as a specific application		
0 & 1	1. 3. 3. 1	1 1	Primary and secondary performan ce parameter s	The described parameters relate to luminaires rather than the overall lighting system as described above. Performance parameters should include user satisfaction and wellbeing in addition to quantification of illuminance. No account is taken of the system design including controls and switching that are core elements of the system as described above. The ability of luminaires to be controllable as part of the system is an essential element.		Agreed They originated from the previous study but will be updated note: control system parameters are included, will be aligned with EN 15193
0 & 1	1. 4. 2	2 1	CIE 97(2005)	Calculation of Maintenance Factors remains an area where the experience of the lighting designer could provide a more comprehensive solution. The values stated are not necessarily conservative. In use the majority of lighting installations do not receive adequate maintenance and cleaning. Current marketing trends suggesting that LED luminaires require little or no maintenance could potentially contribute to worsening the situation. Currently recommended lighting levels are based on the end of life performance of a	Consider including Maintenance and operation of lighting systems after being placed in use to ensure they are operated according to the design intent and achieve designed energy use in operation. Considering mandating systems maintenance according to assumptions or	This remark is added Keep the suggested policy measure in mind for later Task 7.



Stakeholder comments form

				lighting system. This results in over dimensioning when the lifetime of the system is expected to be very long.	decisions used to inform the design process.	
0 & 1	1. 4. 2	2 1	CIE 154(2003)	Same considerations as above for CIE 97(2005)		See previous
0 & 1	1. 4. 2	2 3	EN15193(2007)	We would recommend LENI for assessing actual energy use for lighting. It would be appropriate for LENI to form the base measure for the efficiency of lighting systems. Issues remain about setting benchmark standards for design. The current benchmarks (2007) are behind best current practice and best achievable. Keeping these values updated would require frequent review in line with technology , practice and other standards development. Adding additional factors (Fcu0 & (Fre) are likely to increase apparent complexity and therefore increase resistance to uptake of the calculation. An additional flexible factor		Scope figures are updated in line with LENI as suggested The optional Fcu0&Fce for flexibility will be included in the study. Also after discussion with other stakeholders: Another option is to suggest this factor for EN 15232(building automation only)



Stakeholder comments form

				could be provided to be used by designers in specific appropriate cases much as the factors for scene setting exist in the current calculation method.		
0 & 1	1. 4. 2	2 7	EN 15232	Lighting control system development is currently outpacing the ability of standards to keep up with the potential. Mandating adherence to standards such as these risks inhibiting new developments and consequent energy savings. Using a measure such as LENI allows for a technologically blind assessment of energy used		Noted Statement added to the text
0 & 1	1. 4. 2	2 8	EN 13201-5	Different models and standards are used to calculate un-metered lighting supplies for street and road lighting in different countries. As these will be the basis for investment decisions, and closely match actual energy used, a full study of these would be necessary to understand the real effects and impacts of regulation in this area.		Noted Will be further done in later tasks.



Stakeholder comments form

0 & 1	1. 4. 2	3 3	EN 12464- 1	Potential Gap: All the illuminances recommended are based on recommended reflectances 4.2.2 Reflectance of surfaces <i>Recommended reflectances for the major interior diffuse surfaces are:</i> <i>ceiling: 0,7 to 0,9;</i> <i>walls: 0,5 to 0,8;</i> <i>floor: 0,2 to 0,4.</i> <i>NOTE The reflectance of major objects (like furniture, machinery, etc) should be in the range of 0,2 to 0,7.</i> Architects and interior designers are not required to meet these requirements. The effect of lighting measured in illuminance will vary according to the reflectances of surfaces with the result that the illuminances in the standard can be either too low or too high to meet the visual requirements of the workplace or other space. In respect of good design practice, reconfigurable spaces should be designed with fixed lighting that meets the		We understand the following: Gap: All illuminances are a result of calculations based on recommended reflectances (this remark is also added in EN 15193 that refers for method 1 to EN 12464) Other text added
-------------	---------------	--------	----------------	---	--	--

Stakeholder comments form



				requirements for background area or immediately surrounding area depending on the size and nature of the space with task lighting provided separately related to furnishing. This would reduce the practice of over lighting entire floor plates to task level and result in very considerable energy savings.		
0 & 1	1. 4. 2	3 5	EN 12193	In large venues and stadia lighting levels are determined by requirements for televising. These are increasing significantly to allow for High Definition and instant slow motion replay. Lighting to achieve these levels is frequently installed permanently, therefore control systems and management are required to ensure lower levels are used whenever possible.		Text added
0 & 1	1. 6. 6. 2	7 9	Redesign Option	Regarding design targets, a maximum of +5% over the design target still results in over lighting at switch on and for the majority of the project life by over 25% when maintenance factor is incorporated and there is no control system tasked with maintaining specific illuminances.		Text in line with this remark is added in option for control system



Stakeholder comments form

0 & 1	1. 6. 6. 7	7 9	Operation and maintenan ce	Propose adding an option for mandating operation and maintenance of lighting system according to the design intent for the installation. This can reduce calculated maintenance factors and therefore initial and total energy in use for the life of the lighting system		This option is added in the text. Detailed calculations are shifted to task 4.
0 & 1	1. 6. 7	8 4	Conclusion	Typically Hospitals and public education establishments are designed with a high priority placed on energy efficiency in lighting. It is challenging that the proposed energy savings would be achieved by regulation as these are already being designed in for new build and refurbishment projects. Commercial developments, office and retail show the largest opportunity for system level savings as prime cost rather than cost in use drives these projects. Hotels and Restaurants require lighting system design to focus on the aesthetic qualities of light with style and fashion dictating much of the design trend. Systems regulation on maintenance and operation would be most effective here.		Thanks added to the text



Additional questions to DG ENER Lot 37 on Lighting Systems

Organization: LightingEurope	Name: Kay Rauwerdink	Date: July 27 th 2015
--	--------------------------------	--

#	Question	Answer	Reply study team
1	<i>Could you ask the convenor of EN 15193-1 & 2 to send us the latest working version on which we can build our work (if possible <1/8)?</i>	Convenor is Lou Bedocs: will be able to release to you the recast draft standard prEN15193-1 by end of July but the Technical report and Spreadsheet will not be available till September as they require major restructuring and content improvements. The recast will include the responses to comments from enquiry.	OK, done
2	<i>Could you ask the convenor of EN 12464 to send us the latest working version on which we can build our work (if possible <1/8)?</i>	Convenor is Peter Dehoff: WG 2 has just started to work on NWIP (new work item proposals) and is waiting for a further new work item to start revising EN 12464-1.	noted, our gaps will be sent
3	<i>Could you ask the convenor of EN 13201-5 to send us the final voted versions on which we can build our work (if possible <1/8)?</i>	As the Convenorship of Steve Austin for WG 12 is formally not decided yet, Soh��il Moghtader (chair of CEN/TC-169) enclosed the latest document of prEN 13201-5. He asks to strictly limit the access for other experts than Vito or EC. Please be aware that during the Formal Vote some editorial comments were received which still needs to be discussed and decided whether to be included in the document. Therefore this document is not the final EN 13201-5 but the most current document available.	Received Isn't it the final? (contacts Steve) CL definition OK?
4	It would be nice having gaps in above mentioned EN standards already included in your comments (31/5), e.g. there is a gap.. in EN .. and there is work in progress on ..	It is of little use to document the potential gaps in the prEN standards as the working documents are changing in structure and content in response to comments and inputs received from enquiry and WG members. To follow development need to join the WG.	noted, but the study contract requires this also
5	<u>prEN 15193-1&2</u> It is useful to have several examples for verification, is it possible to look at CIE 171 on 'Test Cases for Assessment of Accuracy of Lighting Computer Programs'?	Please note the EU mandate on EPB matters demands the production of software to support the implementation of these standards and to show the fulfilment of the EPB requirements. Already there is an established task group and are busy in the development of the software. With the software there will be test cases but not exclusive to lighting. There will be a spreadsheet on lighting energy estimation but only to cover method 2. The TR will	Noted, we should add the mandate in Task 1 (study will follow method 1)



#	Question	Answer	Reply study team
		contain worked examples and benchmark indicators. The EPB software process will have nothing to do with CIE 171 as lighting will only be a small part. Similarly the lighting spreadsheet is only required to prove the workings of the calculation methods.	
6	<u>prEN 15193-1&2</u> When comparing EN 15193 with EN 13201-5 it would be useful to see how parameters, definitions and acronyms can be streamlined as much as possible between prEN 15193-1&2 and EN 13201-5. Can this be done?	Unfortunately the prEN13201-5 recently rejected the LENI route for energy requirement estimation of road lighting and the TG invented its own terms. However, the process is very similar and just needs conversion of the new terminology. In TC169 the WGs work independently so any plans for alignment is a matter CEN/TC169 to resolve. CELMA produced a LENI calculation procedure for outdoor lighting but was rejected by the CEN/TC169WG12 part 5 TG and NSBs have accepted the difference.	noted text will be added (despite this the study will attempt to harmonize as much as possible)
7	<u>prEN 15193-1&2</u> Is it possible to have the experimental data that is behind the factors? IHMO: it is worth elaborating the measurement method with a more detailed analysis (e.g. to derive FD, FO, ..).	The new standard will still only specify the methodology for calculating the energy requirements for lighting. It will not define or specify the lighting design process and will not specify targets or limits for energy for lighting. The CEN default data were obtained from studies made in several countries and the results were published in various publications. Most of the publications will be listed in the bibliography of the TR. The new standard will also permit the use of National default values for which templates for the data will be given in Annex A. The standard will not have LENI target values but the TR will give examples. The Technical Report will also give some information on lighting design process and considerations. It will also give examples of default data and generate LENI values for some building types. This revised standard will be part of the family of standards that specify methods to calculate the energy requirements of buildings for the EPB Certification. The standard will indicate its relationship with the OAS and other Technical services standards. The standards will not give target values as these specifications are Member states responsibility.	OK we consult the references in annexes of part 2 Noted also UK has LENI targets



#	Question	Answer	Reply study team
8	<u>EN 12464</u> Progress and field experience is welcome related to verification procedures. In section 6.2 (illuminance) is stated 'When verifying conformity to the illuminance requirements the measurement points shall coincide with any design points or grids used', how much points and how much work is related to this? Is this sometimes done in the field? Can fast screening methods with a more limited set of measurements be considered?	The number and distance of grid points is defined in section 4.4 Illuminance grid. As the distance is related to room size it is already optimised. This is the basis for field measurements. To reduce the measurement points means to reduce accuracy of measurement data. No "short measurement" is considered in the standard. But it can be done "for orientation" in the field, but not for verifying the calculation.	noted verification procedure could be added in EN 12464 revision (is a gap) Will be communicated to Peter Dehoff
9	<u>EN 15193</u> We are looking for reference design calculations according to EN 15193, more specific (input from manufacturers is welcome): If possible, identical to the CIE 171 test cases? (to verify if this make sense). Some new reference calculations for offices in line with the previous office lighting study(lot 8) but the best solution available today and EN 15193 data, i.e.: Cellular office L=5.4 m, B =3.6 m (one side with window), 2.8 m ceiling height, 0.8m work plane height, window height 2 m from ceiling(oriented SE), reflectances (ceiling 0.7, wall 0.3, floor 0.2) Open plan office L= 16.2 m (one side with window), B =10.8 m, 2.8 m ceiling height, 0.8m work plane height, window height 2 m from ceiling(oriented SE), reflectances (ceiling 0.7, wall 0.3, floor 0.2) The reference calculations can be either in Dialux or Relux.	EN12464-1 provides design criteria for indoor lighting schemes. There is no standard that defines how lighting scheme design is carried out. This lack is a hot topic of discussion in TC169. EN15193 assumes that the lighting scheme has been designed to fulfil the requirements of EN12464. EN15193 gives the calculation method to estimate the energy required by the designed lighting scheme when operated with lighting controls built into luminaires. The proposals made in lot8 and here are not part of the work item for WG9 as such calculations can be made by any individuals. The crucial parameters of Occupancy, Daylight availability and Lighting Control system are specific to an installation and cannot be standardised. The new EU software will enable all calculations on EPB to be made at concept stage, comprehensive design stage and post installation.	Noted (scheme = define task and surrounding area?) We started our own calculations on selected test cases based on the standards



#	Question	Answer	Reply study team
10	<u>EN 13201</u> We are looking for reference design calculations according to EN 13201, more specific (input from manufacturers is welcome): Is it possible to have some benchmark calculations (Best Available) from several manufacturers(>2) in accordance with 'Annex A on Energy efficiency benchmarking calculations' for; Type A.5 class P4 (table A5) which is close to category slow traffic in previous lot 9 Type A.4 class M3 (table A4) which is close to category mixed traffic in previous lot 9 Type A.8 class M2 (table A8) which is close to category fast traffic in previous lot 9 The reference calculations can be either in Dialux, Relux or Ulysse.	The prCENTR 15193-2 will give sample calculations for areas and buildings to guide the user of the standard. There will also be an Excel spreadsheet to help with the calculation steps. It is important to understand that EN15193 is not a specification standard. It only gives standardised methods for estimating the energy requirements for lighting.	question was on EN 13201 We follow the provided version of "/13201 of interest is Annex B installation luminous efficacy with its decomposition into subsystems. Herein correction factor CI is unclear, does this also apply to illumination classes (P,C)? The issue is (& comment DEA(DK)) to correct for Erequired/Einstalled?



DG ENER Lot 37: EcoDesign Preparatory Study on Lighting Systems

Organization: LightingEurope	Name: VITO	Date: 19 October 2015
--	-------------------	------------------------------

Task #	Section #	Page #	Topic	Comment	Proposed change	Reply study team
Chapter 0 #1	0.3	Page 18	Second paragraph	"... used for the production of artificial lighting from the power supply in household lighting and tertiary lighting." Tertiary sector of economy deals with application such as Office, school but not INDUSTRY and Agriculture, so a different term should be used to avoid misunderstanding	to be replaced by: "... used for the production of artificial lighting from the power supply in residential lighting and non-residential lighting." Note: because residential means household and other similar applications. This is the terminology to be used within the revision of EN 15193	Agreed that 'Tertiary' should be replaced. For discussion: ' the UK building regulation part L defines 'domestic' and 'non-domestic' to be compared with 'residential'?
LightingEurope would prefer 'residential' and 'non-residential'. The problem with 'domestic' and 'non-domestic' is that applications such as residential homes for students or senior citizens are not really domestic but neither are they non-domestic. They are residential however.						agreed, modified where possible
Chapter 0 #2	0.3	Page 18	Luminaire description	An apparatus which distributes, filters or transforms the light transmitted from one or more lamps.....	An apparatus which distributes, filters or transforms the light transmitted from one or more light sources Proposal from (FP): Clarity may help, so please use the complete definition (with note) from EN 60598-1:	Agreed, work in progress Note: are standards aligned with the IEC online terminology service: http://www.electropedia.org?



Task #	Section #	Page #	Topic	Comment	Proposed change	Reply study team
					1.2.1 luminaire apparatus which distributes, filters or transforms the light transmitted from one or more lamps and which includes all the parts necessary for supporting, fixing and protecting the lamps, but not the lamps themselves, and where necessary, circuit auxiliaries together with the means for connecting them to the supply Note 1 to entry: A luminaire with integral non-replaceable lamps is regarded as a luminaire, except that the tests are not applied to the integral lamp or integral self ballasted lamp.	
The first working draft of prEN12665 (Light and lighting. Basic terms and criteria for specifying lighting requirements) has been circulated to CEN/TC 169 WG1. It generally aligns with the CIE international lighting vocabulary with a few exceptions. Furthermore, CIE / IEC are currently doing an update process to align the documents from each organisation (CIE S 017:2011 is the newer document). Example: luminaire description under proposed change.						noted
Chapter 0 #3	0.3	Page 18		What other descriptions to be taken into account?		Further updates are welcome
We remove this comment.						OK
Chapter 0 #4	0.3	18		General use of the terms lamps and light sources is confused and should be corrected		Further updates are welcome



Task #	Section #	Page #	Topic	Comment	Proposed change	Reply study team
Due to the increasing use of LED technology the terms lamp and light source are no longer interchangeable. CIE DIS 024/E:2015 defines: - LED lamp – LED light source incorporating one or more LED package(s) or LED module(s) and provided with one or more cap(s) - LED light source – electric light source based upon LED technology EN 62504:2014 defines - LED lamp as LED light source provided with (a) cap(s) incorporating one or more LED module(s) and possibly including one or more of the following; electrical, optical, mechanical, and thermal components, interfaces and controlgear - It also includes the note A LED lamp is designed so that it can be replaced by an ordinary person (as defined in IEC 60050-826, 826.18.03) So the main differentiator is the cap and ease of replacement.						added to text
Chapter 0 #5	0.4	Page 19		Implement quality parameters for LED e.g. CRI, CCT, SDMC....	Should be added to the document. Ideally follow the IEC performance standard and mention this standard in the text.	Agreed intro text added + more parameters of the standards will be added.
With reference to IEC 62722-2-1 Luminaire performance Part 2-1 Particular requirements for LED luminaires and EN 13032-4 data in question are: - Photometric code - Rated input luminaire power (W) - Rated Luminaire Luminous Flux (lm) - LED Luminaire Luminous Efficacy (lm/W) - Correlated Color Temperature, CCT (K) - Color Rendering Index, CRI (Ra 8) - initial/maintained - Chromaticity tolerance (CDCM) - within steps of MacAdam ellipses - initial/maintained - Rated life (h) and the related lumen maintenance factor (L_x) - Failure fraction (B_y) corresponding to rated life - Useful Nominal lifetime (L_xB_y/hours) - Rated ambient temperature (t_a) - Luminous Intensity Distribution (cd/1000lm)						added to text

Task #	Section #	Page #	Topic	Comment	Proposed change	Reply study team
Chapter 1 #6	1.1	Page 21	OBJECTIVE	Description product category and the system boundaries of the playing field for ecodesign for lighting systems and this from a functional, technical and environmental point of view.	This in principle describes the scope of the EBDP. Our task should be only to focus on the savings by lighting system Do we address the whole building or only lighting systems?	The focus is the lighting system taking the interaction into account, text updated e.g.: ..This study focuses on the lighting system but will take for buildings energy related interactions with other building systems into account. ..
Yes that's true. Illumination could support heating during heating period. Otherwise during summertime cooling must compensate illumination heating energy. So far this is intended to be regulated by the relevant standards construction and exactly that's the problem, because interaction between EN 15193 and the other relevant standards is not solved yet.						noted
Chapter 1 #7	1.3.1	Page 25	Products excluded	Exit signs are excluded, what about other emergency lighting luminaires part as exit signs of emergency lighting systems. LightingEurope Emergency Lighting WG to give its comments by April 24th Lighting systems designed for other purposes than providing illumination. For example, lighting systems designed to make themselves visible for purposes of signage or displays (e.g. traffic lights, exit signs, television sets, tablets, ...). luminous signs for advertisement? All types or back lighted boxes are in the scope? Christmas lighting chain?	Exit signs are excluded but what about other emergency lighting luminaires, that are a part, as exit signs, of emergency lighting systems. Please specify the intention for excluding (or not) luminous signs for advertisement (all types or back lighted boxes only), Christmas lighting chain, ...	Text modified and added: ..Please note that emergency lighting equipment directly related to illumination in buildings are proposed to be within the scope, see also EN 15193.
Emergency lighting should be treated carefully with respect to energy efficiency. Whilst there is no excuse for inefficient						noted



Task #	Section #	Page #	Topic	Comment	Proposed change	Reply study team
systems it is a safety critical system so should not be legislated into problems. <u>Revised comments & proposed changes:</u> Comment: Exit signs are excluded but all other emergency lighting luminaires should also be excluded. Revert to http://ec.europa.eu/energy/en/topics/energy-efficient-products/lighting "Lighting products are subject to EU energy labelling and ecodesign requirements. Emergency lighting and some LEDs designed for very specific uses and sold in very small quantities per year (less than 200), are excluded from these regulations." Proposed Change: To clearly stated that emergency lighting luminaires are excluded. Comment: What's about luminous signs for advertisement, all types of back lighted boxes, Christmas lighting chains? Proposed Change: To clearly specify the intention for excluding (or not) luminous signs for advertisement (all types of back lighted boxes only), Christmas lighting chains,...						text and figures updated
Chapter 1 #8	1.3.1	Page 25	Paragraph after Fig 1-1	"In this study it is the intention to look at the application level of lighting." Repetition; nearly the same as in chapter 0.3		Noted, but the document structure requires such repetition. To be kept in mind that they are kept in line.
No further comments.						OK

Task #	Section #	Page #	Topic	Comment	Proposed change	Reply study team
Chapter 1 #9	1.3.1	Page 25	Paragraph before Fig 1-2	Tertiary sector of economy deals with application such as Office, school but not INDUSTRY and Agriculture, so a different term should be used to avoid misunderstanding	Replace the term "tertiary" to read: " In non-residential lighting, system design is often based on minimum performance levels sourced from standards. "	Agreed to replace Tertiary. Maintain where reference is made to existing regulation. Choice between 'Non-residential' or 'Non-domestic'?
See also comment under #1. No further comments.						OK
Chapter 1 #10	1.3.2.1	Page 26		There should be a clear differentiation between street lighting and traffic route lighting. The inclusion of tunnel lighting implies that traffic route lighting is included but this is not indicated		Agreed to do, is it possible to have more detailed definition of traffic route versus street lighting?
Traffic route lighting is where motorised traffic is the predominant user with little or no pedestrians / cyclists / etc. Typically associated with lighting class M from PD CEN/TR 13201-1:2014. Street lighting is residential or amenity lighting where traffic is significantly mixed or predominantly non-motorised. Typically associated with lighting class P from PD CEN/TR 13201-1:2014.						text added
Chapter 1 #11	1.3.2.2	Page 26	Luminaire description	An apparatus which distributes, filters or transforms the light transmitted from one or more lamps..... "The first sentence is not understood: The luminaire level of the lighting system is denoted by the light blue in Figure 1-1 or by orange when the light source is fixed and integrated into the luminaire."	An apparatus which distributes, filters or transforms the light transmitted from one or more light sources Further to this, please add the NOTE: Note- A luminaire with integral non-replaceable lamps is regarded as a luminaire, except that the tests are not applied to the integral lamp or integral self ballasted lamp	The luminaire level of the lighting system is denoted by the light blue in Figure 1 -1. A "luminaire" is defined as an "apparatus which distributes, filters or transforms the light transmitted from one or light sources.". Note: A luminaire with integral non-replaceable lamps is regarded as a luminaire, except that the tests are not applied to the integral lamp or integral self ballasted lamp?
We prefer a better clarification what you mean with these luminaire types and also what standard to test against.						figures and text updated



Task #	Section #	Page #	Topic	Comment	Proposed change	Reply study team
<u>Revised comments & proposed changes:</u> Comment: The first sentence is not understood: "The luminaire level of the lighting system is denoted by the light blue in Figure 1-1 or by orange when the light source is fixed and integrated into the luminaire." Proposed change: To clarify the meaning and also what standard to test against. Comment: A "luminaire" is defined..... Proposed change: Revert to the comment for Chapter 0, section 0.3, Page 18, Some descriptions of system components.						
Chapter 1 #12	1.3.2.3	Page 27	Constant illumination level	Constant illumination level also adjusts to the levels of daylight, dimming or switching off the lighting when sufficient daylight is available		To verify & discuss (definitions of EN 15193 should be introduced? Fco covers close fitting to the minimum required setting? (according to prEN 15193)
Because constant illumination controls monitor the light on the task they cannot differentiate between the source of the light, e.g. artificial or natural light.						added
Chapter 1 #13	1.3.2.3.1	Page 26 – Page 28	Examples of lighting control system for indoor lighting	To review the descriptions of the different control systems		Under consideration: can and should we use those of prEN 15193 & 13201?
Yes, please refer as much as possible to definitions used in prEN12665, prEN15193 and EN13201.						done

Task #	Section #	Page #	Topic	Comment	Proposed change	Reply study team
Chapter 1 #14	1.3.2.4	Page 29	DIALux	Description of DIALux and RELUX to possibly recommendation for system calculation	State parameters software needs to address	OK, will be more documented (could refer to future Task 3)
This is not so difficult. Software from DIAL can already calculate lighting energy consumption according to EN 15193, but not in interaction with the other energy consumption equipment in the building.						added
Chapter 1 #15	1.3.2.5	Page 30		Short description of Lighting Control Systems like DALI, DMX512, ZigBee and LEDOTRON	As well known in the meantime more systems will be implemented	Make sure the document is future-proofed. Text added: This is a relative new area wherein also often new technologies and standards are introduced to the market
We can refer to well established tools for Germany DIALux or Relux. Calculations with lighting can be performed with quick software tools. Examples are available, made in existing buildings.						see previous
Chapter 1 #16	1.3.3.2	Page 35	Formula for explaining maintenance factor	Formula to calculate the functional unit (Wartungsfaktor) from the secondary lighting system	To note	Noted Under consideration to add MF in accordance with ZVEI, which is more in line with LED
The German national lighting association ZVEI will not publish a MF document. A new ZVEI Guide for planning LED will be published in short time and will be translated into English. For detailed calculations on MF the guide refers to calculation tables in the German LiTG report. There is also a Swedish proposal.						noted
Chapter 1 #17	1.3.3.2	Page 35	Formulae	The formulae should either use UF and LOR or U without LOR. The use of U and LOR accounts for the LOR twice. LMF does not account for LLMF in formula 2. LMF accounts for date and aging of reflective materials within the luminaire. LLMF accounts for the		Formulae to be checked Note: UF= UxLOR (therefore only accounted once). Nevertheless we will move to new aronyms for LOR and U based on the most recent standards prEN15193,

Task #	Section #	Page #	Topic	Comment	Proposed change	Reply study team
				effects of aging of the light source. Formula 2 is not for the case of LED, it is for the case of absolute photometry. A LED luminaire presented as relative photometry would have to use equation 1. The use of different efficiency factors between the equations confuses them. The difference between equation 1 and equation 2 should essentially be the LOR. However equation 1 could still be applicable for absolute photometry as the LOR=1 will have no effect.		EN13201-6(2015), EN12665(2011) (η_R, ...). Figures will be updated accordingly
The IEC defines utilisation as “ratio of the luminous flux received by the reference surface to the sum of the individual output fluxes of the luminaires of the installation”. Because it is the individual fluxes of the luminaires it implicitly includes the LOR.						OK
Chapter 1 #18	1.3.3.2	Page 36	Other units in draft PrEN 15193 must be converted	EN 15193 and EN 13201-5 in principle use similar functional units Comment (TG) Add LED Luminaires and absolute photometry (lm/W) Implement quality parameters for LED Add SDMC (Mac Adam ellipses)	To note	SDMC + other definitions are welcome
Reference to EN 13032-4 <i>Rating and tolerance of LED-luminaire data</i>: In most LED luminaires the LED light sources cannot be separated from the luminaire. Therefore, LED luminaires are measured in so called “absolute photometry”. Output data of an LED luminaire measurement are raw data at laboratory test conditions and are corrected and reported for standard test conditions (see clause 4). Other definitions see also remarks under point # 5. Within the German national lighting association ZVEI a special guide for using absolute photometry within LED illumination is finalized and will be published in due time. All ZVEI Guides can be free downloaded from the ZVEI website.						please provide when available



Task #	Section #	Page #	Topic	Comment	Proposed change	Reply study team
Chapter 1 #19	1.3.3.2	Page 36	Operational lifetime	The use of the F factor confuses the issue regarding LED. The use of B and C would be more precise.	Consider ZVEI LED guide. Use LxBy as standard	To do, add more text and discriminate LED, for other light sources formulas procured from lot 8&8 = similar to economic model in CIE 115 (to check)
F failure factor related to 'group' or 'spot' replacement as mentioned in the CIE 115. So linked to the cost model. Please check against new IEC lifetime metric for LED based products mentioned in IEC 62717 Ed. 1.0 ANNEX C Explanation of recommended LED product lifetime metrics.						LED parameters from this standard added
Chapter 1 #20	1.4.2	Page 41	CIE (97)2005	Identified gap: The example values included are conservative, which results in over dimensioning lighting systems. Updates might be needed for LED luminaires which were not detailed in this guideline (2005) ZVEI has a 'Guide to Reliable Planning with LED Lighting Terminology, Definitions and Measurement Methods: Bases for Comparison' where also the Lamp Survival Factor (LSF) is taken into account for lighting systems using multiple LED sources. This could be included in an update.	It is of little use to document potential gaps in the prEN standards as the documents are changing in response to comments received during enquiry.	Is there a revision ongoing?
We remove comment ... <i>it is of little use</i> ... since it is not appropriate here. CIE 97:2005 is on the list of CIE Division 3 as requiring an update but currently is not being worked upon. Revision is foreseen in ISO/TC-274.						OK
Chapter 1 #21	1.4.2	Page 42	CIE (154)2003	Identified gap: Updates might be needed for LED luminaires which were not detailed in this guideline (2007). ZVEI has a 'Guide to Reliable Planning with LED Lighting Terminology, Definitions and Measurement Methods: Bases for Comparison' where also the Lamp Survival	It is of little use to document potential gaps in the prEN standards as the documents are changing in response to comments received during enquiry.	idem

Task #	Section #	Page #	Topic	Comment	Proposed change	Reply study team
				Factor (LSF) is taken into account for lighting systems using multiple LED sources. This could be included in an update.		
We remove comment ... <i>it is of little use</i> ... since it is not appropriate here. CIE 154:2003 is on the list of CIE Division 4 as requiring an update but currently is not being worked upon. Revision is foreseen in ISO/TC-274.						added
Chapter 1 #22	1.4.2	Page 51	EN 13032-1	Identified gaps: Despite of this accepted European standard, in practice the sector often uses another similar file format (EULUMDAT, IES, CIBSE, ..). A photometry file reduces a luminaire to a point source which can be inaccurate to model a distributed light source such as a large LED panel luminaire (e.g. OLED), therefore more sophisticated file formats are being developed (e.g. IES TM-25-13).		Please specify
Some programs use specific file formats to overcome this. Dialux (ULD files) and Relux (ROLF files) allow the photometry to be attached to a model of the luminaire, ensuring the correct position of the luminous emitting areas within the luminaire geometry. For basic photometric file formats the photometry is spread over the luminous area specified within the file, centred upon the centre of the luminaire dimensions. So, for example, a street lantern with the light source positioned at the end of a body containing control gear, spigot mounting mouldings, etc. would have the luminous aperture positioned central to the full body which would be somewhere over the gear compartment. This is because the photometric file conveys the size of the luminaire and the size of the luminous aperture but not any geometric relationship between the two.						added

Task #	Section #	Page #	Topic	Comment	Proposed change	Reply study team
Chapter 1 #23	1.4.2	Page 53	EN 12464-1	Potential gaps in EN 12464-1: Reference could be made to EN 15232 and that task areas and their surrounding areas can change over the life time of a building, therefore a building management system could reconfigure flexible the illumination levels and provide additional savings. It is unclear if and how these savings are modelled. Areas where much changes can be expected over the building life time could be identified (e.g. open plan office) and a recommendations for building management systems could be included.	It is of little use to document potential gaps in the prEN standards as the documents are changing in response to comments received during enquiry.	To be verified if there is a review planned
We remove comment ... <i>it is of little use</i> ... since it is not appropriate here. There is a revision of EN 12464 planned in CEN/TC 169 for 2015/2016.						
Chapter 1 #24	1.5.1.1	Page 67	Table 1-2: Summary of current EU policy instruments as they are and could be applied to lighting systems (LS) and building automated control systems (BACS)	Good overview about existing systems Overall it is clear that the existing EU policy framework contains plenty of levers and opportunities that could be applied to the promotion of energy efficient lighting systems however that the application of these is variable and generally not targeted at lighting systems per se	This table is very difficult to understand and is confusing	We are considering ways to make the table clearer and welcome suggestions
It should be selected that only that levers and opportunities are listed which could apply to lighting systems. At the moment it is completely overloaded.						
Chapter 1 #25	1.5.1.6	Page 73	Certification: 'Member States shall ensure that an energy performance	Certification refers mainly to following articles of the recast EPBD21: -Article 11 'Energy Performance Certificates';	This should be watched carefully. Behind this cost intensive structures of certification schemes could be set in force. This would be profitable market	Certification is a very important topic as it will drive industry and project practice. This needs careful definition as to who is responsible and who is

Task #	Section #	Page #	Topic	Comment	Proposed change	Reply study team
			certificate is issued for (a) buildings or building units which are constructed, sold or rented out to a new tenant; and (b) buildings where a total useful floor area over 500 m ² is occupied by a public authority and frequently visited by the public. On 9 July 2015, this threshold of 500 m ² shall be lowered to 250 m ² .	Article 12 'Issue of Energy Performance Certificates'; Article 13 'Display of Energy Performance Certificates'. The issuing of EPCs has an important role in the transformation of the building sector. By providing information, potential buyers and tenants can compare buildings/building units. Also recommendations are provided for a cost-effective improvement, encouraging homeowners to refurbish their building to a better energetic standard.	for certification companies and at least hamper the actual project.	liable. Not clear there is any need to change the text here though
We remove this comment.						OK
Chapter 1 #26	1.5.1.6	Page 74	Cost-optimal methodology:	'Member States shall calculate cost-optimal levels of minimum energy performance requirements using the comparative methodology framework established in accordance with paragraph 1 of the recast EPBD and relevant parameters, such as climatic conditions and the practical accessibility of energy infrastructure, and compare the results of this calculation with the minimum energy performance requirements in force.'	This is to be understood that each member state can implement their own system	Yes, although within the constraint that MS should demonstrate their building code requirements are derived using the cost-optimal approach within their specific national circumstances. Is there a proposal to change the text here?
No this has to be considered as an observation, every member state implementing its own system is a possible route.						
Chapter 1 #27	1.5.1.6	Page 75	Impacts of EPBD on lighting systems:	The energy efficiency of lighting is explicitly addressed as a subject, mainly for the non-residential sector, in the 2010 recast of the Energy Performance	If following the EPBD rules for lighting than each member state can implement their own system. In principle what we have today.	Again they can do so providing it complies with the methodological cost-optimality requirements in the Directive. It is an open question how

Task #	Section #	Page #	Topic	Comment	Proposed change	Reply study team
				of Buildings Directive (EPBD)24. Annex I point 3 stipulates that ‘The methodology shall be laid down taking into consideration at least the following aspects: ...(e) built-in lighting installation (mainly in the non-residential sector);’.Annex I point 4 stipulates that ‘The positive influence of the following aspects shall, where relevant in the calculation, be taken into account: ... (d) natural lighting.’. The EPBD recast also explicitly formulates that ‘Member States should use, where available and appropriate, harmonized instruments, in particular testing and calculation methods and energy efficiency classes developed under measures implementing Directive 2009/125/EC’.25 Comment (TG) 1.5.1.12 Green Public Procurement (GPP) – LENI criteria should be implemented (simplified calculation model, see 1.3.1)		much this is the case currently. Again not sure that there’s any need to revise the text here?
We believe the text is suitable, however it will not in all case possible to rule the EPBD in all buildings all over Europe in the same way due to different building forms, climate, building history, etc. Please find some examples from Sweden: updated THE NATIONAL AGENCY FOR PUBLIC PROCUREMENT’S PROCUREMENT CRITERIA FOR INDOOR LIGHTING. To be sure you have the latest versions of the criteria, visit; www.upphandlingsmyndigheten.se/gid/1082/9. www.upphandlingsmyndigheten.se/11013/2.						
Chapter 1 #28	1.5.1.6	Page 75	Examples of country implementations on EPBD related to	-Simple system used in Belgium -System in France -System in Germany and Luxemburg	noted and again as mentioned above, that only a simple system would be accepted	The object in this task is to list who specifies what but not to comment on the appropriateness of these measures

Task #	Section #	Page #	Topic	Comment	Proposed change	Reply study team
			lighting:	DIN V 18599 -Building regulation in UK 1.5.1.12 Green Public Comment (TG) 1.5.1.12 Procurement (GPP) – LENI criteria should be implemented (simplified calculation model, see Swedish model on public procurement based on standard room conditions calculated from the comprehensive method 1.3.1)		at this stage. Therefore we will happily add more details on national specifications in EU MS and welcome any details stakeholders can provide on these
The publication “Implementing the Energy Performance of Buildings Directive” October 2013 is useful for this. It is available electronically (www.epbd-ca.eu). There is also more information about The National Agency for Public Procurement’s procurement criteria on the website. Please contact our helpdesk if you have any questions, upphandlingsstod@uhmynd.se.  UHM_indoor-lighting_20150911_102212.pdf  UHM_indoor-lighting_20150911_102212.pdf  Appendix_LENI-calculations_EN.pdf						
Chapter 1 #29	1.6.6.1	Page 99	system related improvement options are discerned:	1. Redesign the building/room; 2. Change the luminaire and lighting control system and maintain the other surrounding infrastructure, ...); 3. Change the luminaire but not the lighting control system; 4. Retrofit lamp, ballast and optic 5. Retrofit lamp and ballast	It seems the most effective combination would solution 1 and 2. But at least solution 2 should be implemented	This may not be the right place for the text to comment on the most effective solution
Might be, but it must be declared and stated anywhere to give the most effective solution for the architect and planner of the building.						is a task 6 issue, reference is made to later tasks
Chapter 1	1.6.6.2	Page 99	Redesign the building	In this case the redesign includes:		The comment reiterates the



Task #	Section #	Page #	Topic	Comment	Proposed change	Reply study team
#30				• Lighting and building energy balance calculation with optimization; • Choosing windows for daylight entrance; • building the lighting infrastructure i.e. cables, suspension or poles; • choosing and placing luminaires; • choosing and placing lamps or light sources; • choosing and placing ballasts or drivers; • installing the lighting control system; • choosing appropriate surface reflection requirements; • iterative redesign steps to have a close fit to lighting requirements for tertiary lighting as defined in standards EN 12464-1&2 and EN 13201-2, e.g. fit to maximum +5 % above the requirement of 500 lx		existing text – please explain the intended point and if any changes in text are required
For the first step the explanations in the text under the different intends seems sufficient. Maybe the study is not the appropriate place go more in detail.						See previous Reference is made to later tasks
Chapter 1 #31	1.6.6.5	Page 100	Retrofit lamp, ballast and optic improvement option	Not recommended		The text says: "If the luminaires in an installation are equipped with poor optics, only lamps, ballasts and optics can be replaced. In this option the lamp is replaced by a directional light source that partially bypasses the luminaire optics. This is useful in existing luminaires with poor optical efficiency. Replacing a fluorescent lamp by a retrofit LED lamp can be an example of this solution."



Task #	Section #	Page #	Topic	Comment	Proposed change	Reply study team
						Does this address the comment?
With the addition that when using 'retrofit lamp sources' this must be strictly follow the requirements laid down in regulation (EU) 1194/2012.						OK noted
Chapter 1 #32	1.6.6.6	Page 100	Retrofit lamp and ballast improvement option	Not recommended		Same as above
With the addition that when using 'retrofit lamp sources' this must be strictly follow the requirements laid down in regulation (EU) 1194/2012.						OK noted